



SCC-CLERK'S OFFICE
DOCUMENT CONTROL CENTER
2016 APR 29 A 11: 00

2016 APR 29 11:00

Mr. Joel H. Peck, Clerk
Virginia State Corporation Commission
Document Control Center
1300 East Main Street
Tyler Building - First Floor
Richmond, Virginia 23219

Old Dominion Power
Company
State Regulation and Rates
220 West Main Street
PO Box 32010
Louisville, Kentucky 40232
www.lgee-ku.com

Rick E. Lovekamp
Manager - Regulatory
Affairs/Tariffs
T 502-627-3780
F 502-627-3213
rick.lovekamp@lgee-ku.com

VIA OVERNIGHT DELIVERY

April 28, 2016

**RE: Kentucky Utilities Company d/b/a Old Dominion Power Company's
Integrated Resource Plan filing pursuant to Va. Code § 56-597 et
seq.,
Case No. PUE-2016-00 DS3**

Dear Mr. Peck:

Pursuant to §56-597 of the Code of Virginia, Kentucky Utilities Company, d/b/a Old Dominion Power Company ("KU/ODP"), please find enclosed and accept for filing its Integrated Resource Plan ("IRP"). The original and 15 copies of the IRP are enclosed with this letter. One copy of the IRP is being delivered to the Virginia State Corporation Commission's ("Commission") General Counsel under separate cover. The original and each copy of the IRP contain the expurgated or redacted version of the information for which KU/ODP considers to be confidential and with the Motion for Protective Order KU/ODP requests be withheld from public disclosure.

In addition to the IRP, the Companies are filing a Motion for Protective Order requesting that the Commission establish procedures applicable to the use of confidential information in this proceeding. The original and 15 copies of the Motion for Protective Order are enclosed with this letter. One copy of the Motion for Protective Order is being delivered to the Commission's General Counsel under separate cover.


Mr. Joel H. Peck, Clerk
April 28, 2016

160440022

The information which KU/ODP through its Motion for Protective Order requests be withheld from public disclosure is enclosed with this letter. An original and 15 copies of the confidential information is enclosed in 15 separate opaque envelopes each marked "UNDER SEAL." On every document filed under seal, KU/ODP has marked each individual page of the document that contains confidential information, and on each such page has clearly indicated the specific information requested to be treated as confidential by use of highlighting marking. On additional copy of the confidential information is being delivered under seal in an opaque envelope to the Commission's General Counsel under separate cover.

Please confirm your receipt of this filing by placing the stamp of your Office with date received on the extra copy and returning to me in the enclosed envelope. Should you have any questions regarding this information, please contact me at your convenience.

Sincerely,



Rick E. Lovekamp

cc: William H. Chambliss, Commission General Counsel (Confidential Copy)
Kimberly B. Pate, Director, Division of Utility Accounting & Finance (w/encl.)
William F. Stephens, Director, Division of Energy Regulation (w/encl.)
Delegate Terry G. Kilgore, Chairman, House Committee on Commerce and Labor (w/encl.)
Senator John C. Watkins, Chairman, Senate Committee on Commerce and Labor (w/encl.)
Senator Thomas K. Norment, Jr., Chairman, Commission on Electric Utility Regulation (w/encl.)
C. Meade Browder, Jr., Senior Assistant Attorney General, Office of the Attorney General (w/encl.)

ODP 2016 VA IRP SUMMARY

100440002

Kentucky Utilities Company (“KU”) is, at its name implies, a Kentucky-based electric utility with limited operations in Virginia, in which it does business as Old Dominion Power Company (“ODP” or, the “Company”). In Kentucky, KU and its sister utility, Louisville Gas and Electric Company (“LG&E”) (collectively, the “Companies”), collectively serve over 900,000 customer accounts in over 80 of Kentucky’s 120 counties with over 8,000 megawatts (“MW”) of combined generating capacity, all of which is located in Kentucky and is subject to the jurisdiction of the Kentucky Public Service Commission (“Kentucky PSC”); neither KU nor LG&E (nor KU operating as ODP) owns or operates any generating assets in Virginia (indeed, LG&E has no utility assets or customers in Virginia). In contrast to LG&E and KU’s significant Kentucky utility operations, ODP provides retail electric service to approximately 28,000 customers in the Virginia counties of Wise, Lee, Russell, Scott, and Dickenson, supplying those customers with energy from KU and LG&E’s generating assets in Kentucky. The electric load in the ODP service territory in Virginia primarily consists of residential and coal mining operations. The territory is almost entirely rural and mountainous with negligible load growth and represents approximately five percent of KU’s total customer base. KU and ODP’s principal place of business is One Quality Street, Lexington, Kentucky 40507 and ODP maintains a Business Office in the town of Pennington Gap, Virginia and a Business Office and Operations Center in Norton, Virginia.

Recognizing the small scale of ODP’s operations, the Virginia General Assembly exempted ODP from the requirements of the Virginia Electric Utility Regulation Act (VCA §§ 56-576 – 56-596). Nonetheless, ODP is subject to the recently amended requirements of VCA § 56-599 concerning the filing of integrated resource plans (“IRPs”). This filing is intended to satisfy the revised requirement of VCA § 56-599 that each electric utility file an updated IRP with the Virginia State Corporation Commission (“Commission”) by May 1.

ODP
2016 VA IRP SUMMARY

160410092

In Kentucky, LG&E and KU are regulated utilities and are subject to triennial IRP filing requirements. Since LG&E and KU came under common control in 1998, they have filed joint IRPs in Kentucky in 2002, 2005, 2008, 2011, and 2014. LG&E and KU file joint IRPs because they jointly plan and operate their generating and transmission resources, including jointly dispatching their generating units and establishing a common reserve margin for planning, reporting, and operating the joint system. This joint planning and operation allows for potential cost savings, deferral of capacity expenditures, and more efficient use of generating and transmission capacity, all of which benefit customers in the Kentucky and Virginia service territories. Additionally, beginning in 2011, ODP has filed IRPs as required under the Code of Virginia.

Through the resource planning process, LG&E and KU maintain an ongoing commitment to identify and meet customers' future energy needs in the most reliable and economical manner using robust economic and forecasting methodologies. Additional resource planning variables taken into consideration when modeling and developing the IRP include future capacity needs, fuel and energy costs, renewable energy resource options, fuel diversity, technology deployment, and dynamic and evolving environmental regulations. Concerning the latter variable, for example, since the U.S. Environmental Protection Agency issued its final Clean Power Plan in November 2015 uncertainty has existed as to what future carbon-dioxide-emission-reduction requirements will be mandated and implemented by each state.

ODP regularly provides the Commission with ample information to ensure ODP is serving its customers safely, reliably, and economically. For example, each February, ODP files with the

ODP
2016 VA IRP SUMMARY

150440032

Commission an application, testimony, and supporting schedules to recover its forecasted fuel costs through the levelized fuel factor (“LFF”). The fuel costs are adjusted to reflect any over-recovery or under-recovery of fuel costs previously incurred. ODP provides the Commission with exhibits of projected fuel expenses and sources at the point of delivery at the transmission level, projected Virginia jurisdictional kWh sales and fuel expense recovery assuming the LFF remains unchanged, a calculation of the proposed LFF, and an ODP service territory map. Also, forecasted and actual data is provided for fuel expense, generation output, equivalent availability, capacity factors, heat rates, equivalent forced outage rates, dependable capacity ratings, average dispatch cost by generating unit, fuel consumption, heat content in MBtu, average heat content of the primary fuel, and fuel expense in cents per MBtu by generating unit.

Also, LG&E and KU file in Kentucky an Annual Resource Assessment each April, much of which ODP then files annually with the Commission in narrative summaries. The assessment includes annual weather-normalized energy sales, monthly power purchases, actual and weather-normalized monthly coincident peak demands, load shape curves of actual and weather-normalized peak demands, load shape curves showing the number of hours that native load demand exceeded these levels, target and projected reserve margins, forced outages greater than two hours in duration, current and planned scheduled outages or retirements of generating capacity, planned base load or peaking capacity additions to meet native load, transmission energy data, and all planned capacity additions. Therefore, ODP provides the Commission with a significant amount of operational information on an annual basis, which provides the Commission a clear view of LG&E and KU’s operations and planning, enabling the Commission to ensure that ODP will be able to continue to provide safe, reliable, and economical service to its Virginia customers.

ODP
2016 VA IRP SUMMARY

16044092

Finally, it is noteworthy that because KU and LG&E's Kentucky-based generating assets serve ODP's customers in Virginia, the emissions from those generating assets do not and will not affect Virginia's ability to comply with the forthcoming federal Clean Power Plan.

ODP places a strong emphasis on energy conservation through consumer education, employing several methods to disseminate energy efficiency and conservation tips. First, the Company prepares the Power Source newsletter, which customers receive with their monthly bills. Power Source provides ODP customers with proactive and practical energy conservation tips and educational material. Second, the Company's website provides seasonal and year-round information on low-cost and no-cost ways for customers to reduce energy usage, including tips related to lighting, heating and cooling, appliances and electronics, insulation and air sealing, and water usage. Third, the Company provides materials containing energy-efficiency tips at various public gatherings and community festivals.

KU and LG&E have a robust portfolio of successful and cost-effective demand-side-management and energy-efficiency ("DSM-EE") programs that provide benefits to ODP's customers in Virginia. KU and LG&E's DSM-EE programs will provide a cumulative demand reduction of 500 MW and cumulative energy savings of 1.6 million MWh by 2018. Because ODP's Virginia customers receive their energy from KU and LG&E's generating resources in Kentucky—ODP, KU, and LG&E do not own generating resources in Virginia—these demand and energy reductions in Kentucky provide benefits to ODP's Virginia customers in the form of avoided capacity costs and relatively lower energy costs. Also, because KU and LG&E's Kentucky-based generating assets serve ODP's customers in Virginia, the emissions from those generating assets will not impede Virginia's ability to comply with the forthcoming federal Clean Power Plan, regardless of the amount of energy efficiency ODP's customers are able to achieve.

ODP
2016 VA IRP SUMMARY

160410092

Providing ODP's customers with safe and reliable electric service at low rates requires continuous investment in generation, transmission, and distribution facilities. ODP's generation facilities are located in Kentucky and largely burn coal or natural gas to generate electricity. The coal and natural gas are procured through competitive bid practices from domestic suppliers. Due to increasingly stringent environmental regulations applicable to such coal-fired generation, the Companies continue to engage in the most significant environmental-compliance construction program in their history. ODP is largely exempt from the Virginia Electric Utility Restructuring Act. As a result, ODP's cost recovery is limited to a levelized fuel factor and traditional base rate cases. The Utility Restructuring Act's various rate-adjustment riders are not available to ODP. Under these circumstances and with these limitations, ODP currently expects to file traditional base rate cases every two years to recover the cost of these investments.

Notwithstanding the Companies' investment in new gas-fired generation facilities, environmental controls at existing coal-fired generation facilities, and a new 10MW solar photovoltaic facility, ODP's rates have historically been lower than those of any other investor-owned utilities. With the exception of the coal mining industry, ODP's southwestern-Virginia service territory does not have large, energy-intensive industries. Electric sales to the coal mining industry are declining as this industry consolidates and retracts.

ODP regularly meets with state and local stakeholders to support economic development in its service territory, is committed to investing in Virginia to reliably serve its Virginia customers, and continues to maintain two business offices and over 30 employees in Virginia to serve Virginia customers.

ODP
2016 VA IRP SUMMARY

160440092

Additional information is available in the Exhibits noted below.

- Exhibit 1 – Clean Power Plan Status
- Exhibit 2 – Environmental Regulations
- Exhibit 3 – 2015 Resource Assessment (portions considered confidential)
- Exhibit 4 – Schedules 1 – 18 (portions considered confidential)

This IRP represents a snapshot of an ongoing resource planning process using current business assumptions. The planning process is constantly evolving and may be revised as conditions change and as new information becomes available. Before embarking on any final strategic decisions or physical actions, the Companies will continue to evaluate alternatives for providing reliable energy while complying with all regulations in a least-cost manner. Such decisions or actions will be supported by specific analyses and will be subject to the appropriate regulatory approval processes.

150440002

Exhibit 1

Clean Power Plan Status – ODP

The VSCC stated in its Final Order concerning KU/ODP's 2015 IRP:

Furthermore, while we find that KU/ODP's IRP is reasonable and in the public interest for the purposes set forth herein, we also find that additional analysis of several areas should be required in future filings. We recognize that the U.S. Supreme Court's stay of the implementation of the CPP [Clean Power Plan] went into effect after KU/ODP filed its comments on the Staff Report, and this stay may further affect the steps taken in Kentucky regarding the electric generating units located therein. Accordingly, we find that KU/ODP should include in its next IRP filing with the Commission an update regarding the Company's plans and Kentucky's plans to comply with the CPP. This should include: (i) an assessment of the Company's ability to comply with Section 111(d) under a rate-based approach; (ii) an assessment of KU's ability to comply with Section 111 (d) under a mass-based approach; (iii) an assessment of the rate impacts of the final Section 111 (d); and (iv) an update on the status of Kentucky's development of a state implementation plan.¹

Kentucky has consistently opposed the Clean Power Plan ("CPP"). Following the U.S. Environmental Protection Agency's ("EPA") June 2014 publication of its proposed CPP, Kentucky joined 11 other states in a lawsuit opposing the CPP.² In addition, in late 2014 the Kentucky Attorney General filed comments with the EPA opposing the rulemaking,³ and the Kentucky Energy and Environment Cabinet filed comments expressing serious concerns about the proposed rule.⁴ On August 5, 2015, Kentucky joined 15 other states in petitioning the EPA for an administrative stay of the final CPP, which EPA had issued, but not published in the Federal Register, on August 3, 2015.⁵ The EPA did not grant the stay and published the final CPP in the Federal Register on October 23, 2015.⁶ The same day, Kentucky joined 23 other states in filing an action in the U.S. Court of Appeals for the District of Columbia Circuit to hold unlawful and set aside the rule,⁷ and to petition the court for a stay of the CPP during the appeal.⁸

Therefore, it was only over Kentucky's consistent opposition that the final CPP was published in the Federal Register in October 2015. The final Clean Power Plan contains state-

¹ *In re: Kentucky Utilities Company d/b/a Old Dominion Power Company's Integrated Resource Plan filing pursuant to Va. Code § 56-597 et seq.*, VSCC Case No. PUE-2015-00037, Order at 5-6 (Mar. 14, 2016).

² *West Virginia, Commonwealth of Kentucky et al. v. U.S. EPA*, No. 14-1146 (D.C. Cir. 2014); *see also In Re: Murray Energy Corp.*, Case No. 14-1112, consolidated with 14-1151 (D.C. Cir. 2014).

³ Available at http://www.ieca-us.com/wp-content/uploads/Comments-of-Kentucky-Attorney-General-Jack-Conway_12.01.141.pdf.

⁴ Available at http://www.ieca-us.com/wp-content/uploads/KY-Energy-and-Environment-Cabinet-Comments_11.26.14.pdf.

⁵ See http://www.ieca-us.com/wp-content/uploads/16-States-Ask-for-CPP-Hold_08.05.15.pdf.

⁶ 80 Fed. Reg. 64,661 *et seq.* (Oct. 23, 2015).

⁷ Available at [http://www.ago.wv.gov/pressroom/2015/Documents/File-stamped%20petition%2015-1363%20\(M0108546xCECC6\)-c1.pdf](http://www.ago.wv.gov/pressroom/2015/Documents/File-stamped%20petition%2015-1363%20(M0108546xCECC6)-c1.pdf).

⁸ Available at http://www.ieca-us.com/wp-content/uploads/States-Motion-for-Stay_10.23.15.pdf.

specific rate-based and mass-based reduction goals and guidelines for the development, submission and implementation of state implementation plans to achieve the state goals. State-specific goals were calculated from 2012 data by applying EPA's broad interpretation and definition of the Best System of Emissions Reduction, resulting in the most stringent targets to be met in 2030, with interim targets to be met beginning in 2022. The final CPP gives states the option to use a rate-based approach (limit emissions per megawatt hour) or a mass-based approach (limit total tons of emissions per year), and the option to demonstrate compliance through emissions trading and multi-state collaborations. Under the rate-based approach, Kentucky would need to make a 41% reduction from its 2012 emissions rate and under a mass-based approach it would need to make a 36% reduction. These reductions are significantly greater than initially proposed and present significant challenges to the state.

Indeed, because the final emission restrictions for Kentucky are so much more stringent than those EPA initially proposed, in December 2015 Kentucky filed a petition for reconsideration with the EPA, noting, "Many of these changes are so dramatic and unanticipated that it would have been 'impracticable,' if not impossible, for the Commonwealth to raise objections about these changes during the public comment period."⁹ Kentucky's petition further stated that, because the EPA did not conduct state-by-state cost-benefit analyses to determine the impact of its final rule on the economy of each state, "[T]he targets for Kentucky have a devastating effect on ratepayers, the economy, and the standard of living in the Commonwealth and other similarly situated states."¹⁰ The EPA has not ruled on Kentucky's petition.

At this time, Kentucky has not formulated a state plan to comply with the final CPP or committed to formulate such a plan instead of accepting a federal compliance plan. But it currently appears unlikely Kentucky would opt for a federal plan: On January 21, 2016, Kentucky filed comments critical of the proposed federal plan, concluding that the proposed plan "does not provide for the meaningful participation required for rulemaking, it improperly expands statutory authority, increases regulatory uncertainty, and is based upon uncertain and limited analysis."¹¹ The comments further asked the EPA to withdraw the proposed federal plan.¹²

The same day, Kentucky announced it would be seeking a two-year extension of the deadline to file a state compliance plan.¹³ The announcement stated the purpose of seeking the extension was to "allow Kentucky to consider its options and continue its fight against this plan that will harm Kentucky's affordable, reliable electricity and devastate the economy statewide," and "to allow serious legal challenges to progress through the court." The announcement further stated that Kentucky's Energy and Environment Cabinet would conduct public listening sessions across the Commonwealth to gather input concerning how to proceed concerning the CPP.

⁹ Available at

[http://eec.ky.gov/Documents/December%2021%20Petition%20for%20Reconsideration%20of%2011\(d\).pdf](http://eec.ky.gov/Documents/December%2021%20Petition%20for%20Reconsideration%20of%2011(d).pdf).

¹⁰ *Id.*

¹¹ Available at

http://air.ky.gov/SiteCollectionDocuments/GreenhouseGasEmissions_FederalPlanRequirements_Comments.pdf.

¹² *Id.*

¹³ Available at http://energy.ky.gov/Documents/EEC_CPP_Extension_FINAL.pdf.

A few days later, Kentucky did indeed continue its fight against the CPP. Following the January 21, 2016 refusal of the U.S. Court of Appeals for the District of Columbia Circuit to stay the CPP, Kentucky joined 28 other states on January 26, 2016, in seeking a stay from the U.S. Supreme Court.¹⁴ Shortly thereafter on February 9, 2016, the U.S. Supreme Court issued an order staying the CPP pending all appellate review of the CPP, including any review by the Court.¹⁵

The next day, Kentucky issued an announcement applauding the stay and deferring any listening sessions proposed in its January 21 announcement: “Conducting listening sessions at this time is premature because the CPP could change substantially as a result of litigation, or it could be vacated altogether.”¹⁶ Therefore, Kentucky appears to have suspended its work concerning potential CPP compliance plans.

Kentucky’s apparent suspension of work on CPP compliance is consistent with the advice later given by the senior U.S. Senator from Kentucky, Sen. Mitch McConnell, who on March 21, 2016, sent a letter to the National Governors Association recommending that states continue to take a wait-and-see approach to the CPP rather than moving forward with compliance efforts.¹⁷ Notably, Sen. McConnell took the view that the stay granted by the U.S. Supreme Court will cause the deadlines and target dates stated in the final CPP to adjust forward to account for the duration of the stay if the CPP survives all appeals.¹⁸

If the CPP survives the current litigation or the EPA ultimately issues a new and similar rule, Kentucky’s ability to comply with it will be complicated by legislation passed by the Kentucky General Assembly in April 2014 that limits the measures that the Kentucky Energy and Environment Cabinet may consider in setting performance standards to comply with the EPA’s regulations governing greenhouse gas (“GHG”) emissions from existing sources. The legislation, now codified as KRS 224.20-140 *et seq.*, provides that such state GHG performance standards shall be based on emission reductions, efficiency measures, and other improvements available at each power plant, rather than renewable energy, end-use energy efficiency, fuel switching and re-dispatch. These statutory restrictions may make it more difficult for Kentucky to achieve any significant GHG reductions required by the CPP or a successor rule.

In light of the U.S. Supreme Court’s stay and Kentucky’s current position on formulating a CPP compliance plan, there is considerable uncertainty surrounding what the CPP will ultimately require of KU and its sister utility, Louisville Gas and Electric Company (“LG&E”). But it seems likely some changes will have to be made if the CPP survives in its current form. Concerning a rate-based compliance approach, LG&E-KU’s combined CO₂ emission rate in 2012 was 2,112

¹⁴ See <http://www.ago.wv.gov/publicresources/epa/Documents/Final%20States%20SCOTUS%20Stay%20App%20-%20ACTUAL%20%28M0116774xCECC6%29.pdf>.

¹⁵ *West Virginia v. Environmental Protection Agency*, No. 15-1363 (D.C. Cir.), *stay granted* (U.S. Feb. 9, 2016) (No. 15A776).

¹⁶ Available at

<http://ecc.ky.gov/Lists/News%20Releases%202/Energy%20and%20Environment%20Cabinet%20defers%20listenin g%20sessions%20after%20Supreme%20Court%20decision.pdf>.

¹⁷ Available at http://www.mcconnell.senate.gov/public/?a=Files.Serve&File_id=6AB51ED1-3638-4442-85B0-3C56D721861B

¹⁸ *Id.* at 1-2.

lbs/MWh, which was slightly below the Kentucky state average of 2,166 lbs/MWh. But the final CPP's 2030 rate-based target for Kentucky is 1,286 lbs/MWh, 41% less than Kentucky's actual 2012 emission rate. En route to the 2030 target, though, are several less stringent interim average targets: 1,643 lbs/MWh for 2022-24; 1,476 lbs/MWh for 2025-27; and 1,358 lbs/MWh for 2028-29. To comply on a rate-based approach, LG&E and KU may need to modify their current portfolio of generating assets during the next decade, participate in an allowance trading program, or both. It appears likely that other market-based mechanisms such as a single- or multi-state Emission Reduction Credit (ERC) purchase mechanism may be available for consideration by Kentucky. The precise timing and amount of such changes is unknown, and cannot be known with any reasonable certainty until the compliance plan applicable to Kentucky, and therefore to KU and LG&E, is known. Similarly, the rate impacts of CPP compliance cannot be projected with any accuracy at this time, though eventual rate increases resulting from CPP compliance appear highly likely.

A mass-based approach, which Kentucky's Energy and Environment Cabinet currently appears to favor, would require Kentucky to reduce its CO₂ emissions from its 2012 level of 91.4 million tons per year ("TPY") to 63.1 million TPY in 2030, with interim targets of 76.8 million TPY in 2022-24, 69.7 million TPY in 2025-27, and 65.7 million TPY in 2028-29. Based on the Kentucky's Energy and Environment Cabinet's projections of CO₂ emissions from electric generation, which show Kentucky's emissions have been decreasing consistently since 2010, it appears Kentucky may not have to make any major changes to meet a mass-based approach for the first interim target period, i.e., through the end of 2024. Beginning in 2025, though, reductions from projected levels would be necessary. If Kentucky ultimately falls under a mass-based compliance approach, particularly with a single- or multi-state allowance-trading mechanism, it is possible KU may not have to change its current generating fleet significantly to achieve CPP compliance. But as with a rate-based approach, it appears highly likely CPP compliance would result in higher rates for customers due to allowance purchases, capacity changes, or a combination of the two. What those increased costs, and therefore increased rates, might be is unknown at this time, and cannot be known until the compliance plan applicable to Kentucky, and therefore to KU and LG&E, is known.

16044002

Exhibit 2

VA IRP ENVIRONMENTAL REGULATIONS

All environmental considerations applicable to Louisville Gas and Electric Company (“LG&E”) and Kentucky Utilities Company’s (“KU”) (collectively, the “Companies”) electrical generation are addressed with local, Kentucky, and Federal regulatory agencies. Although the Companies do not operate and maintain electrical generating facilities in the Commonwealth of Virginia, descriptions of environmental regulations that affect the Companies’ electrical generating facilities are provided in this section.

Clean Water Act - 316(b) - Regulation of cooling water intake structures

In May 2014, the U.S. Environmental Protection Agency (“EPA”) issued a revised 316(b) regulation. The Companies expect industry and environmental groups will use the court system to challenge the regulation and possibly delay its implementation deadlines. The regulation addresses impingement and entrainment impacts for aquatic species, thus possibly affecting all the Companies’ intake water facilities. Data is currently being collected and will be submitted to the appropriate Virginia agency during the Companies’ National Pollution Discharge Elimination System (“NPDES”) permit renewal process.

Clean Water Act – Effluent Limitation Guidelines (“ELG”)

After ongoing study of the issue, in 2009 EPA determined it would revise the steam-electric industry effluent standards. In June 2010, EPA issued a detailed questionnaire to over 500 utilities across the nation aimed at assisting EPA to revise the standards. Draft regulations were proposed by EPA in May 2013 with final promulgation due in May 2014, but EPA sought and was granted an extension. On November 3, 2015 EPA published the final ELG regulations in the Federal Register. The revised regulations will require major changes to wastewater treatment systems at

existing coal-fired plants, especially facilities with wet scrubbers. New discharge limits will be incorporated into each facility's NPDES water discharge permit between 2018-2023.

Acid Rain Program

The Acid Deposition Control Program was established under Title IV of the Clean Air Act as Amended ("CAAA") and applies to the acid deposition that occurs when sulfur dioxide ("SO₂") and nitrogen oxides ("NO_x") are transformed into sulfates and nitrates and combine with water in the atmosphere to return to the earth in rain, fog, or snow. Title IV's purpose is to reduce the adverse effects of acid deposition through a permanent reduction in SO₂ emissions and NO_x emissions from the 1980 levels in the 48 contiguous states.

Phase II of the CAAA's Acid Deposition Control Program established a cap on annual SO₂ emissions of approximately 8.9 million tons by the year 2000. The legislation obtained these SO₂ emission reductions from electric utility plants of more than 25 MW (known as "affected units") through the use of a market-based system of emission allowances. Once allocated, allowances may be used by affected units to cover SO₂ emissions, banked for future use, or sold to others.

The Acid Deposition Control Program of NO_x under the CAAA is not an allowance-based program, but instead established annual NO_x emission limitations based on boiler type to achieve emission reductions. NO_x emission reduction controls must be in place when the affected unit is required to meet the NO_x standard. The maximum allowable NO_x emission rates for Phase I are 0.45 lb NO_x /MMBtu for tangentially fired boilers and 0.50 lb NO_x /MMBtu for dry-bottom, wall-fired boilers. For Phase II, the maximum allowable NO_x emission rates are 0.40 lb NO_x /MMBtu for tangentially fired boilers and 0.46 lb NO_x /MMBtu for dry-bottom, wall-fired boilers.

All of KU's affected units complied with the Phase II NO_x reduction requirements through a system-wide NO_x emissions averaging plan (average Btu-weighted annual emission limit).

Compliance was achieved through the installation of advanced low NO_x burners on Ghent Units 2, 3 and 4.

All of LG&E's affected units complied with the Phase II NO_x reduction requirements on a "stand-alone" or unit-by-unit NO_x emission limitation basis. All of LG&E's units took advantage of the "early election" compliance option under the NO_x reduction program. EPA allowed "early election" units to use the Phase I NO_x limits, thus avoiding the more stringent Phase II NO_x limits. All of the Companies' generating stations operate below their NO_x compliance obligations.

NO_x SIP Call

The NO_x State Implementation Plan ("SIP") Call was promulgated under Title I of the CAAA of 1990 to control the formation and migration of ozone resulting from the presence of NO_x in the atmosphere. Title I requires all areas of the country to achieve compliance with the National Ambient Air Quality Standards ("NAAQS") for ozone, or ground-level smog. In September 1998, EPA finalized regulations (known as the "NO_x SIP Call") to address the regional transport of NO_x and its contribution to ozone non-attainment in downwind areas. EPA maintained that NO_x emissions from the identified states "contribute significantly" to non-attainment in downwind states and that the SIPs in these states were therefore inadequate and had to be revised. EPA's NO_x SIP Call required 19 eastern states (including Kentucky) and the District of Columbia to revise their SIPs to achieve additional NO_x emissions reductions that EPA believed necessary to mitigate the transport of ozone across the Eastern half of the United States and to assist downwind states in achieving compliance with the ozone standard. The final rule required electric utilities in the 19-state area to retrofit their generating units with NO_x control devices by the ozone season of 2004.

The Companies developed a NO_x SIP Call compliance plan (as outlined in Kentucky PSC Case Nos. 2000-386 and 2000-439), which resulted in compliance with the NO_x reduction requirements at the lowest combined capital and operating-and-maintenance life-cycle costs across the Companies' generation fleet. The plan implemented NO_x emission reduction technologies on a lowest "\$/ton" of NO_x removed basis, to provide flexibility should regulatory or judicial changes affect the level or the timing of the NO_x reduction required.

In fulfillment of the NO_x SIP Call compliance plan, NO_x emissions from the Companies' coal-fired generating units were reduced through the installation of selective catalytic reduction ("SCR") on six of the Companies' generating units. Additional NO_x control technologies (including advanced low-NO_x burners and overfire air systems) were also installed on nearly every generating unit in the system to reduce the NO_x formed in the combustion zone of the boiler. Additionally, neural network software was installed on many of the generating units to enable better control of the boiler combustion process.

Clean Air Interstate Rule / Cross-State Air Pollution Rule

On March 15, 2005, EPA issued the Clean Air Interstate Rule ("CAIR"), which required significant reductions in SO₂ and NO_x emissions in an attempt to bring a number of states and regions into compliance with the NAAQS for PM_{2.5} and eight-hour ozone (smog). But a number of states and other interveners challenged CAIR in court on several grounds, and on July 11, 2008, the U.S. Court of Appeals for the D.C. Circuit vacated CAIR and remanded it to EPA for re-promulgation in a form consistent with the court's opinion.¹ The court placed CAIR back into effect several months later; however, the court's later order still required EPA to promulgate a

¹ *North Carolina v. EPA*, 531 F. 3d 896 (D.C. Cir. 2008).

regulation to replace CAIR.² The CAIR NO_x reduction program began in 2009 and the SO₂ program began in 2010 and included a Phase II beginning in 2015 to further reduce NO_x and SO₂ allowances and associated emissions that can be transported across state lines.

The originally proposed effort by EPA to replace CAIR was referred to as the Clean Air Transport Rule (“CATR”), and was later renamed the Cross-State Air Pollution Rule (“CSAPR”). On August 6, 2011, the EPA published in the federal register the final version of CSAPR. CSAPR included limitations on interstate trading and prescribed a new trading program for SO₂ allowances that did not allow for previously banked allowances to be used in this new program. The reductions prescribed by CSAPR were similar to the Companies’ CAIR reductions. CSAPR included a two-phase program for both NO_x and SO₂, with less reduction of NO_x required by the Companies by 2012 and somewhat less reduction required for 2014 and beyond. The reduction under CSAPR for SO₂ compared with the reduction under CAIR would be somewhat less in 2012 and somewhat more in 2014 and beyond.

Due to subsequent petitions against the CSAPR, primarily concerning issues with EPA methodology of allocations for alleviating states’ contributions to downwind ozone and PM_{2.5} issues, CSAPR was stayed by the D.C. Circuit court in December 2011. On August 12, 2012, the D.C. Court of Appeals vacated CSAPR, remanded it to EPA for rewriting, and ordered EPA to continue to administer CAIR until EPA completed and promulgated necessary revisions to CSAPR.

² *North Carolina v. EPA*, 550 F. 3d 1176, 1178 (D.C. Cir. 2008) (“We therefore remand these cases to EPA without vacatur of CAIR so that EPA may remedy CAIR’s flaws in accordance with our July 11, 2008 opinion in this case.”).

The EPA and a number of environmental groups, states, and others petitioned the D.C. Circuit Court of Appeals for a full court re-hearing of CSAPR. The petition was denied on August 12, 2012. A similar appeal was then filed with the Supreme Court. In June 2013, the Supreme Court agreed to rehear arguments to re-instate CSAPR. The initial arguments were heard in December 2013 with a final decision expected in the spring of 2014. CAIR continued to be implemented until a decision by the Supreme Court in April 2014 reversed the D.C. Circuit ruling overturning CSAPR and remanded the case to the lower court. The D.C. Circuit subsequently granted EPA’s motion to lift the stay of CSAPR. As a result, EPA reinstated CSAPR with Phase 1 beginning January 1, 2015, and Phase 2 beginning January 1, 2017. Allocations for the Companies’ system for Phase 1 of CSAPR were of similar quantity as those from CAIR.

Due to continuing ozone non-attainment issues primarily in the northeast, EPA determined through preliminary modeling that emissions from Kentucky and 8 other states are significantly contributing to downwind ozone attainment issues. On December 3, 2015, the EPA published in the Federal Register their proposed CSAPR Update Rule to further reduce ozone season NO_x emissions from fossil-fired electric generating units beginning in 2017. The reduction of ozone season NO_x allocations for the Companies associated with the proposed rule are approximately 30% below the current CSAPR allocations. The Companies timely submitted comments to the EPA concerning the proposed rule.

Clean Air Visibility Rule

In April 1999, EPA issued final regulations known as the Clean Air Visibility Rule (“CAVR”), formerly known as the Regional Haze Rule, to protect 156 pristine (Class I) areas of the U.S., which are primarily national parks and wilderness areas. The goal of the regulatory program is to achieve natural background levels of visibility, that is, visibility unimpaired by

manmade air pollutants in Class I areas, by 2064. Kentucky has one designated Class I area, Mammoth Cave National Park, and is required to assess visibility impacts to this area.

CAVR gives states flexibility in determining reasonable progress goals for the areas of concern, taking into account the statutory requirements of the CAAA. The final regulation requires all 50 states to reduce emissions of fine particulate matter and other air pollutants, including SO₂ and NO_x, and any other pollutant that can, via airborne transport, travel hundreds of miles and affect visibility in Class I areas. Incremental improvements of visibility in the affected areas are required to be seen early in the next decade.

In June 2001, the EPA proposed guidelines on what constituted Best Available Retrofit Technology (“BART”) for the reduction of regional haze issues. The BART requirement applies to all facilities built between 1962 and 1977 that have the potential to emit more than 250 tons per year (“tpy”) of visibility-impairing pollution. The guidelines are to be used by the states to determine how to set air pollution limits for facilities in 26 source categories, including power plants. EPA’s guidance was remanded back to the agency by the D.C. Circuit to eliminate from the source categories those emission points whose contribution to visibility impairment is negligible. On May 5, 2004, new step-by-step guidance was published for states to implement the rule. The guidance additionally included a determination that emissions of SO₂ and NO_x should not be included in modeling the impact of coal-fired generating units in compliance with the CAIR rule, otherwise referred to as “CAIR equals BART”. The emissions from the Companies’ affected units were evaluated for their potential visibility impact on affected Class I areas. From that data, Mill Creek Units 1-4 were the only units identified as having a significant visibility impact. Following an engineering analysis, it was determined that current plans for control technology installations of dry sorbent injection systems would meet the requirements for BART. This data

along with all other affected facilities information was submitted to the Kentucky Division for Air Quality (“KDAQ”). The Companies submitted a CAVR SIP in December 2007 to EPA and the National Park Service. Subsequently, KDAQ submitted a revision to the SIP on May 27, 2010. With consideration that the CAIR rule was remanded, final approval is pending based on the outcome of re-instatement or replacement of the CSAPR rule as described above.

Additionally, CAVR contains review time periods in which an evaluation is made on how well progress is being made to meet the 2064 goal. Within the review period (15 years) of this report, a review of the progress will be made in 2018 that will include the additional reduction of fine particulate matter and SO₂ emissions associated with the Mercury and Air Toxics Standards (“MATS”) Rule and shutdown of coal-fired units in the region. Depending on that analysis, further steps may be taken by regulators to ensure the 2064 goal can be met.

Following remand of the CAIR rule, EPA determined that for those Electric Generating Units (EGUs) located in states subject to CSAPR, compliance with the SO₂ and NO_x reductions required under CSAPR would represent compliance with the SO₂ and NO_x requirements under BART. Thus, for those CSAPR regulated states, CSAPR compliance equals BART compliance. EPA has since also issued an opinion memorandum that CAIR regulated states can consider units in compliance with CAIR as also in compliance with BART. In addition, KDAQ has stated their agreement that CAIR compliance is equal to BART compliance. With the Supreme Court ruling that re-instated CSAPR, it is expected that EPA will issue some associated discussion of using the CSAPR transport emissions reduction program for demonstration of compliance with the BART visibility regulations.

Hazardous Air Pollutant Regulations

The EPA has developed final rules to establish National Emission Standards for Hazardous Air Pollutants for the coal- and oil-fired electric utility industry. The MATS Rule was published in the Federal Register on February 16, 2012, and set emission limits for mercury, acid gases, toxic metals, and organics including dioxins and furans based on the maximum achievable control technology (“MACT”) for the industry. The emission standards within this rule have instigated multiple installations of pulse jet fabric filters for additional control of particulate matter containing trace amounts of certain toxic metals and the shutdown of older coal-fired generation, some of which is to be replaced with new natural gas combined cycle generation. The compliance date was April 16, 2015; however, the rule allowed the permitting authority to grant up to a one year extension based on submittal of a justifiable request.

To meet emissions compliance limitations with the MATS rule, the Companies are completing the process of installing pulse jet fabric filter systems (“PJFF”) with systems to inject powdered activated carbon (“PAC”) on all coal-fired units with the exception of Trimble County Unit 2 and E.W. Brown Units 1 and 2. The Trimble County Unit 2 currently includes a PJFF with PAC injection as original equipment and E.W. Brown Units 1 and 2 will utilize additives to assist with mercury removal and combine their emissions with the emissions of E.W. Brown Unit 3. Dry sorbent injection systems are being installed on each unit that receives a PJFF system for the purpose of protecting the materials of construction. PAC injection systems are being added to enhance removal of mercury emissions. Emissions of mercury and acid gases are further reduced at all coal-fired units with the existing wet flue gas desulfurization (“WFGD”) systems and with new WFGD systems at Mill Creek Units 1 through 4. Additionally, additives to WFGD systems to keep mercury from being re-entrained are being tested at locations within the Companies’ system. The use of these additives could allow for mercury control with reduced or no use of PAC.

As a result of positive effects from testing the liquid additives are being added to the Title V permits for all of our coal-fired facilities.

National Ambient Air Quality Standards

SO₂

The EPA has set the implementation process and timeline relative to the one-hour standard published as a final rule in June 2010. The 2010 NAAQS for SO₂ is a 1-hour primary (i.e., health based) SO₂ standard of 75 parts per billion (“ppb”), based on the three year average of the fourth highest of the 1-hour maximum concentrations. Kentucky made their initial SO₂ attainment recommendations in January 2013 for areas with adequate monitoring and the initial non-attainment designations approved by EPA were published in the Federal Register in October 2013. The historical 3-hour ambient monitoring SO₂ data (2009 – 2011) at the Watson Lane monitor location in Jefferson County was utilized by the state and local air agencies to designate the area adjacent to the Mill Creek Generating Station in non-attainment of the new standard. Kentucky must submit a SIP that contains enforceable emission limitations or control measures on sources contributing to non-attainment by April 2015 in order to achieve attainment by October 2018. The KDAQ has not completed the SIP revision to date but has indicated that air dispersion modeling performed in support of that effort has shown that compliance with the MATS rule will resolve culpability issues at the Mill Creek Station. In April 2015, KDAQ notified sources that were deemed from a combination of emissions and surrounding to have further need of evaluation of attainment status by either installation of a nearby monitoring system or through an approved modeling effort. The Companies’ sources did not receive the notification of need for additional evaluation.

On August 10, 2015, EPA finalized requirements referred to as the Data Requirements Rule (DRR) for a subsequent phase to assess the attainment status of areas near large sources of SO₂ emissions that did not have adequate ambient monitoring and that were not included in the April 2015 notifications. The DRR required facilities to assess attainment by either modeling or ambient monitoring that had SO₂ emissions in 2014 of 2,000 tons or greater. The Companies received notification from KDAQ dated October 22, 2015, that Trimble County and Ghent would need to provide an attainment assessment under the DRR. A preliminary air dispersion modeling effort has indicated the areas near both facilities are in attainment with the NAAQS. The modeling protocol was submitted accordingly by the Companies and is currently under evaluation by the EPA.

NO₂

The EPA published a final rule that revised the primary NAAQS for NO₂ on February 9, 2010. It became effective on April 12, 2010. EPA adopted a new 1-hour standard of 100 ppb and retained the existing annual average standard of 53 ppb. Based on existing air quality data in Kentucky, all areas are currently well below these standards. Nevertheless, the new rule stipulated the establishment of additional new air quality monitor locations. Emphasis is to be placed on locating these monitors near major roadways in large cities where the highest concentrations are expected; but additional monitors to represent community-wide air quality may also be required in large cities. The additional monitors are to be installed in phases between 2014 and 2017 and will be utilized in development of future revisions to the NO₂ standard.

EPA is also planning to evaluate whether changes to Prevention of Significant Deterioration (“PSD”) air quality increments are needed. If so, this could place further limits on the allowable amount of increased emissions from a new or modified source.

Kentucky must incorporate this new NAAQS into its SIP. Additionally, the SIP must contain a plan to bring any non-attainment areas into attainment with the standard by June 2017.

Ozone

Jefferson County was designated "unclassifiable/attainment" with the 2008 NAAQS for ozone of 0.075 parts per million ("ppm") in May 2012.

On January 7, 2010, EPA proposed an even lower primary ozone standard within a range of 0.060 and 0.070 ppm measured over eight hours. At the same time, EPA proposed a new seasonal secondary ozone standard in the range of 7 to 15 ppm. On September 2, 2011, President Obama announced that EPA was going to withdraw the draft regulation. EPA subsequently withdrew their proposal due to insufficient data and issued a new proposal on November 25, 2014, with plans for the final rule in the fall of 2015. The final regulation establishing the new standard at 0.070 ppm was published in the Federal Register on October 26, 2015. Kentucky will have up to two years from that date to establish attainment status designations. Kentucky will then have one year to submit a SIP incorporating the new NAAQS and plans for bringing all areas into attainment with the new standard. EPA will then have one year to approve Kentucky's SIP submittal and non-attainment areas will have from 2021 to 2037, depending on the severity of non-attainment, to obtain attainment status following EPA's approval.

PM / PM_{2.5}

EPA promulgated in December 2012 a new NAAQS for PM_{2.5} that lowered the 24-hour standard from 15 µg/m³ to 12 µg/m³. An audit conducted by the KDAQ in 2013 found data quality issues with the PM_{2.5} monitors operated by the Louisville Metropolitan Air Pollution Control District ("LMAPCD"). Although Jefferson County is still currently classified as non-attainment for the 1997 24-hr standard, KDAQ recommended a status of attainment/unclassifiable based on

valid 2011 to 2013 data and the general downward trend of ozone. Additionally, KDAQ recommended the use of data from monitors located in Southern Indiana near Jefferson County in support of attainment status.

In March 2015, EPA published designations of unclassifiable for Jefferson County and attainment/unclassifiable for the remainder of Kentucky based on monitoring data in Kentucky and nearby areas from 2012 through 2014. The next 3-year assessment will be conducted following availability of 2016 data to establish a 3-year average consisting of 2014-2016 data. As a result of the shutdown of coal-fired generation at the Cane Run facility in 2014 and the installation of pulse jet fabric filters on the Mill Creek coal-fired units by 2016, concerns with the PM_{2.5} attainment status are expected to be minimized. Additionally in March 2015, EPA proposed an option for resolution of attainment issues between the 1997 and the 2006 standard, by allowing achievement of attainment status with the 2012 standard to satisfy the attainment status of the 1997 standard, considering the 2012 standard is more restrictive.

Greenhouse Gases

On September 22, 2009, EPA issued its mandatory Greenhouse Gas (“GHG”) emissions reporting rule. Facilities with CO₂ emissions of more than 25,000 metric tons or an aggregated maximum rated heat input capacity of more than 30 MMBtu/hour are subject to the GHG emissions reporting rule. Annual reporting to EPA began March 31, 2011. Sources required to report include: power plants, miscellaneous stationary combustion sources, and emissions pertaining to the gas supplied to customers of the Companies. On November 2, 2010, the reporting regulation was expanded to include reporting of Sulfur Hexafluoride (SF₆) emissions from electric transmission and distribution equipment, as well as methane, carbon dioxide, and nitrogen oxide emissions from natural gas processing plants, natural gas transmission compression operations,

natural gas underground storage, and natural gas distribution activities. Reporting for these activities began with the 2010 operating year.

On March 13, 2010, EPA issued the GHG “Tailoring Rule” which became effective on January 2, 2011. This rule sets thresholds for requiring permitting of GHG emissions. Between January 2011 and June 2011, sources subject to any other PSD rule that undergo modification will have to get a permit for any applicable GHG emissions if they total more than 75,000 tpy of CO₂. The threshold was set at 100,000 tpy of CO₂ emissions for new sources and 75,000 tpy CO₂ emissions for modified sources effective by July 2011. With promulgation of the GHG “Tailoring Rule” in March 2010, effective July 2011, any new source with maximum potential emissions of CO₂ greater than 100,000 tpy or a modification to a new source that is evaluated to cause an increase in CO₂ emissions greater than 75,000 tpy will trigger PSD if any other PSD pollutant is triggered. If triggered, the source must include an analysis of best available control technology (“BACT”) during permitting activities.

On June 25, 2013, President Obama announced his “Climate Action Plan” which laid out a timeline and targets for regulatory development to reduce GHG emissions. In response, EPA issued a proposed new source performance standard (“NSPS”) for GHG emissions from new fossil fuel fired electric generation sources. The proposal was published in the Federal Register on January 8, 2014 and establishes the effective date for the specific standards limiting CO₂ emissions from new fossil fuel fired electric generating facilities including coal fired, natural gas fired (if greater than 1/3 of the maximum potential generation is used on the grid), and integrated gas combined cycle units. The currently proposed GHG NSPS would establish partial carbon collection and storage (“PCCS”) as the best system of emission reduction.

The final rule was published by EPA in the Federal Register on October 23, 2015. EPA's final determination of the NSPS for CO₂ relative to these sources is 1,400 lb CO₂/MWh (gross) based on supercritical pulverized coal unit (SCPC) with partial carbon capture and storage (CCS) of approximately 16% with bituminous coal as the best system of emission reduction (BSER) for newly constructed units. As an alternative for BSER, EPA determined a new SCPC unit co-firing natural gas could also meet the standard. The limit in the final rule is less stringent than the proposed rule of 1,100 lb CO₂/MWh (gross) due to an assumed higher level of partial CCS in the proposed rule.

EPA based the final standards for newly constructed or reconstructed stationary combustion turbines on BSER represented by efficient NGCC technology for base load natural gas fired units and clean fuels for non-base load and multi-fuel-fired units. The published final limits are 1,000 lb CO₂/MWh (gross) or 1,030 lb CO₂/MWh (net) for base load natural gas-fired units (base load rating of ≥ 250 MMBtu/h and > 25 MW (net) of electricity to the grid). For multi-fuel-fired units based on the percentage of co-fired natural gas, the standard is 120 lb CO₂/MMBtu for non-base load natural gas-fired units, and 120 to 160 lb CO₂/MMBtu for multi-fuel-fired units based on the percentage of co-fired natural gas.

In June 2014, EPA proposed a GHG NSPS for modified or reconstructed existing sources that would set an emission rate in units of lbs of CO₂ per MWh (net) that is based on a 2% improvement of the best year from a look-back period from 2002 to date of modification or reconstruction. The proposal would set minimums (floors) of 1,900 and 2,100 lb CO₂ per MWh (net) for coal-fired units greater than 2,000 MMBtu/h and 2,100 MMBtu/h respectively. The rule also proposed GHG NSPS for combustions turbines with greater than 33% of the nameplate capacity utilized for electric generation that are modified or reconstructed to meet emission an

emission limit of 1,000 and 1,100 lb CO₂ per MWh (net) for units greater than 850 MMBtu/h and less than 850 MMBtu/h, respectively.

EPA's final requirements for reconstructed combustion turbines were included in their final published rule with newly constructed combustion turbine as described above. The final rule was published by EPA in the Federal Register on October 23, 2015, for modified fossil fuel fired steam generating units and integrated gas combined cycles that perform a modification on or after the date of publication of the proposed standards, June 18, 2014. The NSPS for modified existing sources becomes applicable if a modification occurs that results in an increase in CO₂ hourly emissions of more than 10 percent. BSER for modified sources was determined by EPA to represent the most efficient generation at the affected EGU achievable through a combination of "best operating practices and equipment upgrades". The final standards of performance for CO₂ relative to these sources is a unit-specific emission limit determined by the unit's best historical annual CO₂ emission rate (from 2002 to the date of the modification). The emission limit will be no more stringent than 1,800 lb CO₂/MWh (gross) for sources with heat input > 2,000 MMBtu/hr or 2,000 lb CO₂/MWh (gross) for sources with heat input ≤ 2,000 MMBtu/hr. The final rule places a more stringent maximum limit on modified sources than the proposed rule that included limits of 1,900 and 2,100 lb CO₂/MWh (gross) for units > 2,000 and ≤ 2,000 MMBtu/hr respectively. Additionally, EPA proposed regulations in June 2014 for GHG performance standards applicable to existing fossil fuel fired electric generating units (ESPS) that commenced construction prior to January 8, 2014. The proposed regulation would reduce CO₂ emissions by 30% from 2005 by 2030 with interim reductions beginning in 2020. The regulation was proposed under Section 111(d) of the Clean Air Act as guidelines for development of SIPs to meet "state-specific" emission rate targets in units of lb CO₂ per MWh (net), with an option to convert the

target to units of tons CO₂ per year. The proposed emission-rate targets for Kentucky are 1,763 lb CO₂ per MWh (net) by 2030 with an interim emission rate of 1,844 lb CO₂ per MWh (net) by 2020.

On October 23, 2015 EPA published the final ESPS—the final Clean Power Plan—in the Federal Register. The final rule decreased Kentucky’s and many other states’ emission targets from those of the proposed rule, primarily due to changes in EPA’s analyses of best system of emission reductions (BSER) based on regional considerations instead of state-specific considerations. In shifting from a state-specific BSER to a regional based BSER, the building blocks utilized for Kentucky assume a greater utilization of existing NGCC generation and renewable energy (although not necessarily located in Kentucky). Development and use of demand-side management and energy efficiency was eliminated due to concerns that EPA lacked authority to incorporate it in the emission reduction targets. The emission rate goal in units of lb CO₂/MWh(n) for Kentucky was reduced in the final rule from 1,844 to 1,509 in the interim compliance period and from 1,763 to 1,286 by 2030.

With the final rule, the beginning of the Interim compliance period was shifted from 2020 to 2022. Each state can craft their own emission reduction trajectory, however milestones must be evaluated for 2022-2024, 2025-2027, and 2028-2029 with the requirement that affected EGUs in the state collectively meet the equivalent reductions of the interim limits. State plans must contain procedures to ensure the required CO₂ reductions are being accomplished and no increases in emissions relative to each state’s planned emission reduction trajectory are occurring.

In response to applications for stay by numerous parties, on February 9, 2016, the Supreme Court granted a stay of the Clean Power Plan pending judicial review of the rule. The stay will remain in effect pending Supreme Court review if such review is sought.

Associated with the final rule for existing source performance standards, EPA published a proposed implementation plan on October 23, 2015, that can be adopted by states or utilized by EPA in the event a state does not submit a timely and acceptable compliance plan to implement the ESPS rule. EPA's proposed implementation plan includes allocations of CO₂ emissions for each state reflective of the final ESPS rule and the requirement to limit emissions of CO₂ from any new sources of generation that might be utilized in place of existing generation. The Companies submitted comments to EPA on January 21, 2016.

Coal Combustion Residuals

The EPA issued a new coal combustion residuals ("CCR") regulation on December 19, 2014, with an effective date of October 19, 2015. The new rule makes changes in the permitting and management practices for CCR from coal-ash and flue-gas desulphurization ("FGD") systems whether they are managed in ash treatment basins (ash ponds) or landfills.

EPA chose to regulate CCRs as a non-hazardous solid waste under Resource Conservation and Recovery Act Subtitle D with state oversight of federal minimum standards. All CCR storage units must either close within three years or may remain active by installing groundwater monitoring wells and performing dam integrity testing. If groundwater contamination is found around an unlined storage unit, the unit must stop receiving CCR within six months and properly close within five years. If siting criteria or dam safety factors do not meet the minimum requirements, the unit must close. Data collection has begun and groundwater monitoring plans are being developed.

part 2

1604000000

Exhibit 3

2016 Resource Assessment



PPL companies

May 2016

Table of Contents

1	Executive Summary.....	3
1.1	Capacity and Energy Need	3
1.2	Supply-Side Screening Analysis	4
1.3	Expansion Planning Analysis	6
2	Existing and Planned Generating Resources.....	9
3	Capacity and Energy Need	11
3.1	Economic Outlook.....	11
3.2	Electric Load and Peak Demand Forecast	12
3.3	Resource Summary	15
4	Supply-Side Screening Analysis.....	17
4.1	Introduction	17
4.2	Generation Technology Options	17
4.2.1	Technology Options Summary	17
4.2.2	Technology Option Inputs.....	21
4.2.3	Other Inputs	23
4.3	Supply-Side Screening Key Uncertainties	26
4.3.1	Capital Cost	27
4.3.2	Unit Efficiency (Heat Rate).....	27
4.3.3	Fuel Prices	28
4.3.4	Capacity Factor.....	32
4.4	Supply-Side Screening Methodology	32
4.5	Supply-Side Screening Results	33
5	Expansion Planning Analysis	36
5.1	Key Inputs and Uncertainties.....	36
5.1.1	Load Forecast	36
5.1.2	Natural Gas Prices	37
5.1.3	Summary of Scenarios.....	37
5.1.4	Other Inputs	37
5.2	Expansion Planning Analysis	41
5.2.1	Methodology.....	41
5.2.2	Results.....	41
6	Appendix A – Comparison of Levelized Costs from Supply-Side Screening Analysis at Varying Capacity Factors (“CF”)	43
7	Appendix B – Electric Sales & Demand Forecast Process	45

7.1 Input Data 45

7.2 Forecast Models..... 46

 7.2.1 Residential Forecast..... 46

 7.2.2 Commercial Forecast 47

 7.2.3 Lighting Forecast..... 48

 7.2.4 Industrial Forecast 48

 7.2.5 KU Municipal Forecast 49

 7.2.6 Billed Demand Forecast 49

1 Executive Summary

Louisville Gas and Electric Company (“LG&E”) and Kentucky Utilities Company (“KU”) (collectively, “the Companies”) filed their 2015 Integrated Resource Plan (“IRP”) with the Virginia State Corporation Commission on July 1, 2015. In October 2015 and November 2015, respectively, the U.S. Environmental Protection Agency (“EPA”) published the final versions of the Clean Power Plan (“CPP”) and Effluent Limitation Guidelines (“ELG”). The ELG specifies a compliance deadline of no later than December 2023. The Companies have developed high-level ELG compliance costs, but more detailed estimates will not be available for 12 to 18 months. The future of the CPP is particularly uncertain: on February 9, 2016, the U.S. Supreme Court issued an order staying the CPP pending all appellate review of the CPP, including any review by the Court. If the CPP is ultimately upheld and the staying of the CPP is held to delay the implementation of the rule by two years, compliance with the CPP will not begin until January 2024.

When more information is known regarding the costs and implementation of the CPP and ELG, the Companies will conduct a detailed study to determine the most cost-effective compliance plan. Given the extended compliance deadlines, this resource assessment assumes – in the absence of better information – that CPP and ELG compliance costs will not result in any changes to the Companies’ generating portfolio.

The Companies continually evaluate their resource needs and the need for major capital improvements. This study represents a snapshot of this ongoing resource planning process using current business assumptions and assessment of risks. Because the planning process is constantly evolving, the Companies’ least-cost expansion plan may be revised as conditions change and as new information becomes available. Even though the resource assessment represents the Companies’ analysis of the best options to meet customer needs at this given point in time, this plan is reviewed, re-evaluated, and assessed against other available market alternatives prior to commitment and implementation.

The Companies’ Resource Assessment was completed in three parts. First, the Companies developed a forecast of peak demand and energy requirements to assess the need for additional generating capacity. Next, the Companies performed a screening analysis of more than 50 generation technology options to determine a subset of the most competitive options. Then, this subset of generation technology options was incorporated into a detailed expansion planning analysis to determine the optimal expansion plans.

1.1 Capacity and Energy Need

Table 1 details the Companies’ current capacity supply/demand balance for the 15-year planning period.¹ As discussed in the Companies’ 2014 Reserve Margin Study, the Companies target a minimum 16 percent reserve margin (above peak load after adjusting for demand-side management (“DSM”) programs) for the purpose of developing expansion plans. In Table 1, “Planned/Proposed Resources” reflects the addition of the Brown Solar facility, which is expected to be commissioned in May 2016. The Bluegrass Agreement (165 MW) is included in “Firm Purchases” along with the Companies’ share of Ohio Valley Electric Corporation (“OVEC”) (152 MW). Considering these changes to the Companies’ generation portfolio, along with 480 MW of demand reduction from DSM programs by 2018, and 136 MW of curtailable load from curtailable service rider customers, the Companies will have a long-term need for capacity beginning in 2029.

¹ For purposes of calculating reserve margin, loads subject to the Companies’ curtailable service rider are considered supply-side resources.

Table 1 – Resource Summary (MW, Summer)

	2016	2017	2018	2019	2020	2028	2029	2030
Forecast Peak Load	7,356	7,430	7,485	7,234	7,234	7,457	7,485	7,513
DSM	(408)	(442)	(481)	(490)	(480)	(480)	(480)	(480)
Net Peak Load	6,948	6,988	7,004	6,744	6,754	6,977	7,005	7,033
Existing Resources ²	7,815	7,819	7,819	7,819	7,819	7,819	7,819	7,819
Planned/Proposed Resources ³	8	8	8	8	8	8	8	8
Firm Purchases ⁴	317	317	317	152	152	152	152	152
Curtailed Load	136	136	136	136	136	136	136	136
Total Supply	8,276	8,280	8,280	8,115	8,115	8,115	8,115	8,115
Reserve Margin ("RM")	19.1%	18.5%	18.2%	20.3%	20.1%	16.3%	15.8%	15.4%
RM Shortfall (16% RM) *	216	174	155	292	280	21	(11)	(43)

*Negative values denote reserve margin shortfalls.

While meeting customers' energy demand at the peak hour is critical, it is also vital to reliably serve their energy needs at all hours at the lowest reasonable cost. As seen in Table 2, energy requirements are forecast to grow by 0.13 TWh over the next 15 years even after reductions for DSM and the municipal contract termination.⁵ This translates into a compound annual growth rate of 0.03 percent.

Table 2 – Energy Requirements (TWh, After DSM)

	2016	2017	2018	2019	2020	2028	2029	2030
Energy Requirements	35.4	35.6	35.7	34.8	34.4	35.3	35.4	35.6

1.2 Supply-Side Screening Analysis

Over the past several years, resource costs have been generally stable due to the economic slow-down that began in 2008. An abundance of low cost natural gas supply resulting from advancements in natural gas drilling technologies coupled with relatively low capital and operating costs have greatly improved the economics of NGCC technology. Overall, the costs of renewable generation remain higher than fossil generation technologies. However, with tax incentives and Renewable Energy Credits ("RECs"), both solar PV and wind technologies can be cost competitive.

In the screening analysis, the levelized cost of the technology options was calculated at various levels of utilization. In addition to the level of utilization (i.e., capacity factor), the levelized cost of each technology option is impacted by the uncertainty in capital cost, fuel cost, and unit efficiency. As a result, the technology options were evaluated over 270 cases. Given the uncertainty in REC prices and

² Existing resources include the retirement of Tyrone 3 in February 2013, Cane Run 6 in March 2015, Cane Run 4-5 in June 2015, and Green River 3-4 in September 2015, as well as the addition of Cane Run 7 in June 2015.

³ Planned/Proposed Resources include Brown Solar in May 2016. 80% of the capacity of Brown Solar is assumed to be available at the time of peak.

⁴ Firm Purchases include the Companies' share of OVEC as well as the planned capacity purchase and tolling agreement with Bluegrass for 165 MW through April 2019.

⁵ Energy requirements represent the amount of generated energy needed to serve customers' energy needs, inclusive of transmission and distribution losses.

the availability of investment tax credits (“ITC”) for renewable technologies, two iterations of 270 cases were evaluated:

- No ITC or RECs: This iteration did not include an ITC for renewable technologies or wind and solar RECs.
- 10% ITC and RECs: This iteration incorporated a 10% ITC and REC market prices for solar and wind technologies.

Table 3 lists the technology options that were ranked among the top four least-cost technology options in at least one of the 270 cases. In the “No ITC or RECs” iteration, the “2x1 NGCC G/H-Class” option was least-cost in 212 of the 270 cases and ranked among the top four least-cost options in all 270 cases. The option to install three F-Class Simple-Cycle Combustion Turbines (“SCCTs”) (“SCCT F-Class – Three Units”) was least-cost in 58 cases. The “2x1 NGCC G/H-Class” option was the best option for meeting intermediate and base load energy needs. The “SCCT F-Class – Three Units” option was the best option for meeting peak energy needs. In the “10% ITC and RECs” iteration, the solar PV and wind technology options were ranked among the top four least-cost technology options in multiple cases.

Table 3 – Screening Results (Technology Options Ranked Among Top Four Least-Cost)

Generation Technology Option	No ITC or RECs					10% ITC and RECs				
	# Occurrences					# Occurrences				
	1 st	2 nd	3 rd	4 th	Total	1 st	2 nd	3 rd	4 th	Total
2x1 NGCC G/H-Class	212	5	21	32	270	205	15	22	19	261
2x1 NGCC G/H-Class – DF	0	86	184	0	270	0	65	195	10	270
2x1 NGCC F-Class	0	149	51	17	217	0	156	37	18	211
2x1 NGCC F-Class – DF	0	0	0	155	155	0	0	0	133	133
SCCT F-Class – Three Units	58	2	10	7	77	55	1	8	3	67
SCCT F-Class – One Unit	0	28	4	21	53	0	27	1	21	49
1x1 NGCC G/H-Class	0	0	0	38	38	0	0	2	54	56
Wind	0	0	0	0	0	1	6	4	2	13
Solar Photovoltaic	0	0	0	0	0	9	0	1	1	11
Compressed Air Energy Storage	0	0	0	0	0	0	0	0	9	9

Table 4 lists the generation technology options that were evaluated in the detailed expansion planning analysis. The two F-Class NGCC options, the 2x1 NGCC G/H-Class option with duct firing (“DF”), and the Compressed Air Energy Storage (“CAES”) option in Table 3 were ultimately excluded from the detailed analysis. Potential greenhouse gas (“GHG”) regulations and uncertainty in gas prices make the added efficiency of the G-Class option more cost-effective than the F-Class option. Additionally, the capital and fixed costs for the G-Class option are lower on a per-kilowatt (“kW”) basis. The 2x1 NGCC G/H-Class option with DF was consistently less favorable than the 2x1 NGCC G/H-Class option without duct firing.⁶ The CAES option was eliminated because it ranked among the top four least-cost options in only ten or fewer of 270 cases. In addition, the Companies are not aware of any viable sites for CAES capacity near their service territories.

⁶ In addition, the 2x1 NGCC options with duct firing are not materially different from the 2x1 NGCC options without duct firing. Duct firing serves as a means to adjust the size and flexibility of a NGCC unit.

Table 4 – List of Technology Options Evaluated in Expansion Planning Analysis

2014 IRP Generation Technology Options
2x1 NGCC G/H-Class
1x1 NGCC G/H-Class
SCCT F-Class – Three Units
SCCT F-Class – One Unit
Solar Photovoltaic
Wind

The list of generation technology options in Table 4 is identical to the list of technology options that passed the screening analysis for the 2015 IRP.

1.3 Expansion Planning Analysis

In the expansion planning analysis, the Companies developed optimal expansion plans using the technology options in Table 4 over multiple natural gas price and load scenarios. The cost and unit characteristics for these technology options are summarized in Table 5. The NGCC technology options have higher capital and fixed operating and maintenance (“O&M”) costs, but much better heat rates than SCCTs. The “SCCT F-Class – Three Units” option takes advantage of economies of scale, which results in lower capital costs on a dollar per kilowatt (“\$/kW”) basis. Wind and solar options have much higher capital costs than other options on a \$/kW basis, but no energy costs.

Table 5 – Cost and Unit Characteristics for Generation Technology Options (2013 \$)

Generation Technology Option	2x1 NGCC G/H-Class	1x1 NGCC G/H-Class	SCCT F-Class – One Unit	SCCT F-Class – Three Units	Wind Turbine	Solar PV
Reference Name ⁷	2x1G	1x1G	SCCT	CTx3	Wind	SLPV
Net Capability (MW)						
Summer	737	368	201	602	50	50
Winter	859	429	220	659	50	50
Overnight Installed Cost (\$/kW) ⁸						
Total Non-Fuel Variable O&M (\$/MWh) ⁹						
Total Fixed O&M (\$/kW-yr) ¹⁰						
Full Load Heat Rate (mmBtu/MWh)						
Unavailability (%) ¹¹						

The results of the expansion planning analysis are summarized in Table 6. The Companies have a long-term need for capacity beginning in 2029 in the Base load scenario and 2021 in the High load scenario.¹⁴ In five of six Base and High load scenarios, this need was met with NGCC capacity; in one scenario, this need was met with SCCT capacity. In the Low load scenario, the Companies do not have a long-term need for capacity in the study period. Based on the results in Table 6, a natural gas unit will likely be included in the Companies' least-cost plan to reliably meet load requirements in the future.

⁷ Reference names are abbreviated names for each generation technology option.

⁸ Installed cost is based on annual average capacity.

⁹ Variable O&M for NGCC and SCCT options includes long-term service agreement costs.

¹⁰ Fixed O&M for NGCC and SCCT options includes costs associated with reserving firm gas-line capacity.

¹¹ Unavailability for NGCC and SCCT options is the long-term steady-state outage rate expected after initial operation. For wind and solar options, unavailability reflects the expected capacity factor (Unavailability = 1 – Capacity Factor).

¹² Wind turbine capacity factor modeled at 27% with 11% of the capacity counting toward reserve margin.

¹³ Solar photovoltaic capacity factor modeled at 17.4% with 80% of the capacity counting toward reserve margin.

¹⁴ The analysis assumed additional capacity cannot be added prior to 2021. For this reason, additional capacity is needed in 2021 in the High load scenario.

Table 6 – Optimal Expansion Plans¹⁵

Load	LL	LL	LL	BL	BL	BL	HL	HL	HL
Gas Price	LG	MG	HG	LG	MG	HG	LG	MG	HG
2016	BRS	BRS	BRS	BRS	BRS	BRS	BRS	BRS	BRS
2017									
2018									
2019									
2020									
2021							2x1G(1)	2x1G(1)	2x1G(1)
2022									
2023									
2024									
2025									
2026									
2027									
2028									
2029				2x1G(1)	2x1G(1)	SCCT(1)			
2030									

Load: Low (LL), Base (BL), High (HL) Gas Price: Low (LG), Mid (MG), High (HG)

¹⁵ In Table 6, the value in parentheses following the technology option’s reference name indicates the number of units added in a given year.

2 Existing and Planned Generating Resources

Table 7 contains unit data for existing and planned generating resources.¹⁶ Cane Run 6 was retired in March 2015, Cane Run 4-5 were retired in June 2015 with the commercial operation of Cane Run 7, and Green River 3-4 were retired in September 2015. No additional retirements are assumed during the planning period.

To comply with environmental regulations, the Companies recently installed fabric filter baghouses (“baghouses”) on Brown 3, Ghent 1-4, Mill Creek 1, Mill Creek 2, Mill Creek 4, and Trimble County 1. New flue gas desulfurization systems (“FGDs”) were also installed on Mill Creek 1, Mill Creek 2, and Mill Creek 4. A baghouse and new FGD will be installed on Mill Creek 3 by June 2016. No additional changes to emission controls, operating characteristics, unit ratings, unit availabilities, or fuel supply are assumed for existing units over the planning period.

¹⁶ Note that the net capability ratings for Dix Dam, Ohio Falls, and E.W. Brown Solar reflect the assumed output for these facilities during the summer and winter peak demands.

Table 7 – Existing and Future Generating Resources

Plant Name	Unit No.	Location	Status	Operation Date	Facility Type	Net Capability (MW)		Entitlement		Fuel Type	Unit Type	Scheduled Upgrades and Retirements							
						2015/16 Winter	2015 Summer	KU	LGE										
Cane Run	7	Louisville, KY	Existing	2015	Turbine	673	642	78%	22%	Gas	Base/Intermediate	None							
	11			1968		14	14		100%	Gas / Oil	Peaking								
Dix Dam	1-3	Burgin, KY	Existing	1925	Hydro	31.5	31.5	100%		Water	Hydro	None							
E. W. Brown Coal	1	Burgin, KY	Existing	1957	Steam	107	106	100%		Coal (Rail)	Base/Intermediate	None							
	2			1963		168	166					None							
	3			1971		414	410					None							
E.W. Brown-ABB 11N2	5			Burgin, KY	Existing	2001	Turbine	130	130	47%	53%	Gas	Peaking	None					
E.W. Brown-ABB GT24	6					1999		171	146	62%	38%								
	7					1999		171	146										
E.W. Brown-ABB 11N2	8					1995		128	121	100%									
	9					1994		138	121										
	10					1995		138	121										
	11					1996		128	121										
Ghent	1					Ghent, KY		Existing	1974	Steam	476				474	100%		Coal (Barge)	Baseload
	2	1977	477						495		None								
	3	1981	478						485		None								
	4	1984	487						465		None								
Haeffling	1	Lexington, KY	Existing	1970	Turbine	14	12	100%		Gas / Oil	Peaking	None							
	2			1970		14	12												
Mill Creek	1	Louisville, KY	Existing	1972	Steam	300	300		100%	Coal (Barge & Rail)	Baseload	None							
	2			1974		295	297					None							
	3			1978		394	391					Baghouse, FGD 2016							
	4			1982		486	477					None							
Ohio Falls	1-8	Louisville, KY	Existing	1928	Hydro	Run of River (37/58)			100%	Water	Hydro	10 MW upgrade 2014-2017							
OVEC	N/A	Gallipolis, OH Madison, IN	Existing	1955	Steam	178	172	31%	69%	Coal	Base/Intermediate	None							
Paddy's Run	11	Louisville, KY	Existing	1968	Turbine	13	12		100%	Gas	Peaking	None							
	12			1968		28	23												
	13			2001		175	147						47%	53%					
Trimble County Coal (75%)	1	Bedford, KY	Existing	1990	Steam	511 (383)	511 (383)	0%	75%	Coal (Barge)	Baseload	None							
	2			2011		760 (570)	732 (549)	61%	14%			None							
Trimble County-GE7FA	5			2002	Turbine	179	159	71%	29%	Gas	Peaking	None							
	6			2002		179	159												
	7			2004		179	159												
	8			2004		179	159												
	9			2004		179	159	63%	37%										
	10			2004		179	159												
	Zorn			1		Louisville, KY	Existing	1969	Turbine				16	14		100%	Gas	Peaking	None
	Planned Resources																		
E.W. Brown Solar	1	Burgin, KY	Proposed	2016	Solar	0	8	61%	39%	Solar	Solar PV	None							
Bluegrass Capacity Purchase and Tolling Agreement	1	La Grange, KY	Existing	2015	Turbine	165	165		100%	Gas	Peaking	Agreement terminates on April 30, 2019.							

* The ratings for Dix Dam, Ohio Falls, and E. W. Brown Solar reflect the assumed output for these facilities during the summer and winter peak demands.

3 Capacity and Energy Need

The determination of the Companies' capacity and energy need begins with a robust forecast of peak demand and energy requirements.¹⁷

3.1 Economic Outlook

Economic growth remains on a slow but steady upward trajectory in the LG&E/KU service territory. According to the U.S. Bureau of Economic Analysis, Kentucky's real gross state product increased by only 1.0 percent last year, well below the 2.4 percent growth rate in the U.S. However, IHS Global Insight is forecasting growth of 2.5 percent for 2015-2020 for Kentucky, much closer to the expected U.S. economic growth rate of 2.8 percent.

One major reason for the healthier outlook is the exceptional pace of job growth in the Commonwealth over the past 18 months. Kentucky added an average of 3,158 jobs per month in 2015, the strongest pace of growth since 1999. In 2016, job growth is forecast to slip to 1,550 per month (January-July), but it is still above the long-term trend and Kentucky's unemployment rate has dropped below the national average. But the apparent improvement in Kentucky's unemployment rate is not as impressive as it first appears: Kentucky's labor-force participation rate has materially declined over the same period.

The increase in job growth and subsequent boost to real consumer spending should lead to growth in other sectors as well, such as residential construction and commercial activity. While the state's urban areas, particularly Louisville and Lexington, have seen population growth, the rural regions of Kentucky continue to suffer hardships. Residential population growth of 0.5 percent per year in the LG&E service territory and 0.4 percent per year for the combined KU and Old Dominion Power Company ("ODP") service territory through 2020, are below the previous year's forecast (0.7 percent and 0.6 percent, respectively) due to a slower pace of population growth in Kentucky according to IHS Global Insight.

Commercial business growth is expected to continue in the state's urban centers. However, stagnant to declining growth rates in the rural regions of the state, particularly areas which have been hit hard by the loss of industries and/or population flight, continue to temper the increase in total commercial customers in the Companies' service territory. Overall, the forecast for commercial customer growth is slightly higher than the prior forecast.

Kentucky's manufacturing sector continues to show signs of strength, with foreign exports contributing 14.5 percent of the Commonwealth's GSP, up from 13.6 percent last year. Auto makers are benefiting from a significant period of expansion, with national sales this year on pace to be the strongest since 2000. However, there is a risk to this sector from a potential slowdown in automobile sales in the years ahead as the U.S. market becomes saturated with new vehicles.

Job losses in the coal mining sector remain a net drag on the economies of Kentucky and southwestern Virginia. Unfortunately, the situation is not likely to reverse itself any time soon. Though many emerging market economies are buying up coal in large quantities for power generation, coal from Central Appalachia is not economically competitive with foreign suppliers or Powder River Basin coal. Meanwhile, many U.S. utilities have shifted to burning more natural gas and less coal in recent years as

¹⁷ A detailed summary of the forecast inputs and models is contained in Appendix B - Electric Sales & Demand Forecast Process.

the former has benefited from a boon in supply from shale formations, cutting costs dramatically, while the latter has suffered from a slew of regulatory constraints.

3.2 Electric Load and Peak Demand Forecast

Combined LG&E, KU, and ODP load is expected to grow at a relatively slower rate in the coming years compared to previous forecasts. The slower pace of growth is largely due to lackluster gains in the residential and small commercial classes.

Residential use-per-customer levels are forecast to remain relatively consistent compared to previous years across the service territory, but population growth is now seen as slower than previously forecast. In the small commercial sector, customer growth is forecast to accelerate, but use-per-customer levels continue to fall. As a result, both of these major sectors, which together account for roughly two thirds of total load in the service territory, are contributing to slower load growth across the Companies' service territory.

The industrial sector remains relatively consistent with the previous plan and is forecast to show consistent growth in the years ahead. The closure of mines in eastern and western Kentucky, along with the ODP region of Virginia, remains a persistent downside risk in the forecast; indeed, in Virginia the Companies are forecasting decreasing load over the planning period. However, manufacturers in Kentucky, particularly in the auto sector, are healthy. Planned expansions at some plants (Toyota, for example) are expected to more than offset losses from the mining sector, providing positive trend growth.

From 2016-2020, Combined Company load is expected to decline at a pace of 0.4 percent per year, compared 0.1 percent previously, as a result of the loss of many Municipal customers. Excluding these municipal losses, the compound annual growth rate ("CAGR") for the Companies is 0.5 percent compared to 0.8 percent in the previous plan over the next five years. With the loss of the municipal load, combined LG&E, KU, and ODP load is expected to grow at a CAGR of only 0.03 percent from 2016-2030.

Summer peak demand forecasts have been reduced as a result of the lower energy forecast. Summer 2016 is now expected to peak at 6,948 MW, including the effect of Direct Load Control (DLC), compared to 6,998 MW in the prior forecast. From 2016-2030, including the loss of the municipal customers, peak demand is expected to grow at a CAGR of 0.09 percent.

Table 8 through Table 11 list the most recent three-year history and 15-year forecast of energy sales (kWh) by customer class for KU as a whole and for the ODP service territory. Please see Schedules 1, 5, and 6 for the most recent three-year history and 15-year forecast of peak load, coincident peak load and associated non-coincident peak load for summer and winter seasons of each year, annual energy forecasts, and resultant reserve margins.

Table 8 – KU Calendar Actual Sales by Jurisdiction (GWh)

	2013	2014	2015
Kentucky Retail	18,527	18,889	18,280
Kentucky Wholesale	1,880	1,886	1,855
Virginia Retail	862	836	767
Total System	21,269	21,610	20,902

Table 9 – KU Calendar Forecast Sales by Jurisdiction (GWh)

	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
Kentucky Retail	18,765	18,901	18,966	19,004	19,049	19,078	19,113	19,155	19,216	19,238	19,299	19,367	19,445	19,518	19,596
Kentucky Wholesale	1,886	1,849	1,838	900	446	449	453	457	462	466	470	473	473	473	473
Virginia Retail	784	774	764	760	754	750	749	746	746	741	738	734	732	731	728
Total System	21,434	21,525	21,567	20,664	20,248	20,277	20,315	20,358	20,423	20,445	20,506	20,575	20,650	20,722	20,798

Table 10 – ODP Calendar Actual Sales by Class (GWh)

	2013	2014	2015
Residential	402	406	373
Commercial	188	189	193
Industrial/Mine Power	191	165	126
Lighting	2	1	2
Public Authority/Municipal Pumping	80	75	73
Total System	862	836	767

Table 11 – ODP Calendar Forecast Sales by Class (GWh)

	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
Residential	384	380	373	370	364	360	356	353	352	349	346	344	342	340	338
Schools	19	19	18	17	16	16	16	16	16	16	16	16	16	16	16
General Service	91	90	90	90	90	90	90	90	90	90	90	90	90	91	91
Large Power	283	278	276	275	276	278	279	280	280	280	278	277	277	277	276
Lighting	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7
Municipal Pumping	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
Total System	784	774	764	760	754	750	749	746	746	741	738	734	732	731	728

3.3 Resource Summary

The Companies have retired seven coal units since 2013: Tyrone 3 in February 2013, Cane Run 6 in March 2015, Cane Run 4-5 in June 2015, and Green River 3-4 in September 2015. To offset this loss of energy and capacity, Cane Run 7, a 640 MW NGCC facility, was commissioned at the Companies' Cane Run station on June 19, 2015. Nine KU municipal customers provided notices of termination of their wholesale power agreements in April 2014, resulting in a summer peak demand reduction of approximately 325 MW after April 30, 2019.¹⁸ To supplement the Companies' generating capacity through April 2019, the Companies entered into a capacity purchase and tolling agreement with Bluegrass Generation for 165 MW of capacity from May 2015 through April 2019. The Companies are also constructing a 10 MW photovoltaic ("PV") solar facility at the E. W. Brown station ("Brown Solar") which is expected to be commissioned in May 2016.¹⁹

Table 12 details the Companies' current capacity supply/demand balance for the 15-year planning period.²⁰ As discussed in the Companies' 2014 Reserve Margin Study, the Companies target a minimum 16 percent reserve margin (above peak load after adjusting for DSM programs) for the purpose of developing expansion plans. In Table 12, "Planned/Proposed Resources" reflects the addition of the Brown Solar facility, which is expected to be commissioned in May 2016. The Bluegrass Agreement (165 MW) is included in "Firm Purchases" along with the Companies' share of OVEC (152 MW). With the planned changes to the Companies' generation portfolio and with 480 MW of demand reduction from DSM programs and 136 MW of curtailable load from curtailable service rider customers, the Companies will have a long-term need for capacity beginning in 2029.

¹⁸ The wholesale power contract with the City of Paris provided for a 3-year termination notice so their contract will terminate on April 30, 2017. The summer peak load of the City of Paris is forecasted to be 16 MW.

¹⁹ The KPSC approved the construction of Brown Solar in December 2014.

²⁰ For purposes of calculating reserve margin, loads subject to the Companies' curtailable service rider are considered supply-side resources.

Table 12 – Resource Summary (MW, Summer)

	2016	2017	2018	2019	2020	2028	2029	2030
Forecast Peak Load	7,356	7,430	7,485	7,234	7,234	7,457	7,485	7,513
DSM	(408)	(442)	(481)	(490)	(480)	(480)	(480)	(480)
Net Peak Load	6,948	6,988	7,004	6,744	6,754	6,977	7,005	7,033
Existing Resources ²¹	7,815	7,819	7,819	7,819	7,819	7,819	7,819	7,819
Planned/Proposed Resources ²²	8	8	8	8	8	8	8	8
Firm Purchases ²³	317	317	317	152	152	152	152	152
Curtaillable Load	136	136	136	136	136	136	136	136
Total Supply	8,276	8,280	8,280	8,115	8,115	8,115	8,115	8,115
Reserve Margin (“RM”)	19.1%	18.5%	18.2%	20.3%	20.1%	16.3%	15.8%	15.4%
RM Shortfall (16% RM)*	216	174	155	292	280	21	(11)	(43)

*Negative values reflect reserve margin shortfalls.

While meeting customers’ peak demand is critical, it is also vital to reliably serve their energy needs all year round at the lowest reasonable cost. As seen in Table 12, energy requirements are forecast to grow by 0.1 TWh over the next 15 years after reductions for DSM and the municipal contract termination.²⁴ This translates into a compound annual growth rate of 0.03 percent.

Table 13 – Energy Requirements (TWh, After DSM)

	2016	2017	2018	2019	2020	2028	2029	2030
Energy Requirements	35.4	35.6	35.7	34.8	34.4	35.3	35.4	35.6

The energy requirements in Table 13 were created by adding transmission and distribution losses to the Companies’ sales forecast for LG&E and KU. The methods, models, and assumptions used to develop the load forecast for the service territory served by ODP are described in the most recent Levelized Fuel Factor filing.²⁵ In the proceedings of that case, this forecast was deemed reasonable.²⁶

²¹ Existing resources include the retirement of Tyrone 3 in February 2013, Cane Run 6 in March 2015, Cane Run 4-5 in June 2015, and Green River 3-4 in September 2015, as well as the addition of Cane Run 7 in June 2015.

²² Planned/Proposed Resources include Brown Solar in May 2016. 80% of the capacity of Brown Solar is assumed to be available at the time of peak.

²³ Firm Purchases include the Companies’ share of OVEC as well as the planned capacity purchase and tolling agreement with Bluegrass for 165 MW through April 2019.

²⁴ Energy requirements represent the amount of generated energy needed to serve customers’ energy needs, inclusive of transmission and distribution losses.

²⁵ Please see CASE NO. PUE-2016-00017 - DIRECT TESTIMONY OF CHARLES R. SCHRAM, DIRECTOR - ENERGY PLANNING, ANALYSIS, AND FORECASTING, LG&E AND KU SERVICES COMPANY at pages 3-6 and Exhibit CRS-1 for a complete description of the load forecast methods, models, and assumptions used to prepare the load forecasts.

²⁶ Please see PRE-FILED TESTIMONY OF DIANE W. JENKINS, KENTUCKY UTILITIES COMPANY, D/B/A OLD DOMINION POWER COMPANY, CASE NO. PUE-2016-00017 at pages 6-9.

4 Supply-Side Screening Analysis

4.1 Introduction

The Companies' resource assessment considered 58 generation technology options. A detailed evaluation (using production costing computer models) of all technology options is impractical due to the significant amount of time required for computer simulation. Therefore, the purpose of the supply-side screening analysis is to identify a subset of the most competitive generation technology options that will be modeled in the more detailed expansion planning analysis.

Section 4.2 summarizes the generation technology options considered for meeting future capacity and energy needs. Organized by types, these technology options range from natural gas, coal-fired, waste-to-energy, renewable, energy storage, and nuclear technologies. Section 4.3 presents the key uncertainties that were considered in the analysis. Section 4.3.4 describes the methodology used to evaluate and compare the technology options, and Section 4.5 concludes with determining the least cost generation technology options to be used in the expansion planning analysis.

4.2 Generation Technology Options

4.2.1 Technology Options Summary

The list of generation technology options evaluated in the 2016 IRP was unchanged from the 2015 IRP. With the exception of the advanced battery energy storage technology, the cost and performance characteristics of the generation technology options were estimated in 2013 by Burns & McDonnell, an engineering consulting firm. The Companies compared the Burns & McDonnell cost estimates to more recent cost estimates from [SOURCE] for a subset of the technologies considered and only the cost of the advanced battery energy storage technology was materially different. Table 14 lists all the technology types considered, the generation technology options for each technology type, as well as the representative technology option the study used as a basis for the cost and performance estimates. The list of generation technology types includes natural gas, coal-fired, waste to energy, energy storage, renewable, and nuclear technologies. Each of these technology types is discussed in more detail in the following sections.

Table 14 – Generation Technology Types

Technology Type	Generation Technology Option	Representative Technology Option
Natural Gas	SCCT Aeroderivative – One Unit	Simple-cycle GE LM6000 – One Unit
Natural Gas	SCCT Aeroderivative – Four Units	Simple-cycle GE LM6000 – Four Units
Natural Gas	Intercooled SCCT Aeroderivative – One Unit	Simple-cycle GE LMS100 – One Unit
Natural Gas	Intercooled SCCT Aeroderivative – Two Units	Simple-cycle GE LMS100 – Two Units
Natural Gas	SCCT E-Class – One Unit	Simple-cycle GE 7EA – One Unit
Natural Gas	SCCT E-Class – Three Units	Simple-cycle GE 7EA – Three Units
Natural Gas	SCCT F-Class – One Unit	Simple-cycle GE 7F-5 – One Unit
Natural Gas	SCCT F-Class – Three Units	Simple-cycle GE 7F-5 – Three Units
Natural Gas	Spark Ignition Reciprocating Engine – Six Units	Recip Engine - 100 MW – Six Units
Natural Gas	Spark Ignition Reciprocating Engine – Twelve Units	Recip Engine - 200 MW – Twelve Units
Natural Gas	Simple-cycle Gas Microturbine – Five Units	Microturbine- 1 MW – Five Units
Natural Gas	Simple-cycle Gas Microturbine – Fifteen Units	Microturbine - 3 MW – Fifteen Units
Natural Gas	Molten-Carbonate Fuel Cell – Four Units	Fuel Cell - 10 MW – Four Units
Natural Gas	Molten-Carbonate Fuel Cell – Twelve Units	Fuel Cell - 30 MW – Twelve Units
Natural Gas	1x1 NGCC F-Class	Combined-Cycle 1x1 GE 7F-5

Technology Type	Generation Technology Option	Representative Technology Option
Natural Gas	1x1 NGCC F-Class – DF	Combined-Cycle 1x1 GE 7F-5 - Fired
Natural Gas	1x1 NGCC G/H-Class	Combined-Cycle 1x1 MHI GAC
Natural Gas	1x1 NGCC G/H-Class – DF	Combined-Cycle 1x1 MHI GAC - Fired
Natural Gas	1x1 NGCC J-Class	Combined-Cycle 1x1 MHI JAC
Natural Gas	1x1 NGCC J-Class – DF	Combined-Cycle 1x1 MHI JAC - Fired
Natural Gas	2x1 NGCC F-Class	Combined-Cycle 2x1 GE 7F-5
Natural Gas	2x1 NGCC F-Class – DF	Combined-Cycle 2x1 GE 7F-5 - Fired
Natural Gas	2x1 NGCC G/H-Class	Combined-Cycle 2x1 MHI GAC
Natural Gas	2x1 NGCC G/H-Class – DF	Combined-Cycle 2x1 MHI GAC - Fired
Natural Gas	2x1 NGCC J-Class	Combined-Cycle 2x1 MHI JAC
Natural Gas	2x1 NGCC J-Class – DF	Combined-Cycle 2x1 MHI JAC - Fired
Natural Gas	3x1 NGCC F-Class	Combined-Cycle 3x1 GE 7F-5
Natural Gas	3x1 NGCC F-Class – DF	Combined-Cycle 3x1 GE 7F-5 - Fired
Natural Gas	3x1 NGCC G/H-Class	Combined-Cycle 3x1 MHI GAC
Natural Gas	3x1 NGCC G/H-Class – DF	Combined-Cycle 3x1 MHI GAC - Fired
Natural Gas	3x1 NGCC J-Class	Combined-Cycle 3x1 MHI JAC
Natural Gas	3x1 NGCC J-Class – DF	Combined-Cycle 3x1 MHI JAC - Fired
Coal Fired	Subcritical Pulverized Coal	Subcritical Pulverized Coal
Coal Fired	Subcritical Pulverized Coal with CC	Subcritical Pulverized Coal with CC
Coal Fired	Circulating Fluidized Bed	Circulating Fluidized Bed
Coal Fired	Circulating Fluidized Bed with CC	Circulating Fluidized Bed with CC
Coal Fired	Supercritical Pulverized Coal – 500 MW	Supercritical Pulverized Coal
Coal Fired	Supercritical Pulverized Coal with CC – 425 MW	Supercritical Pulverized Coal with CC
Coal Fired	Supercritical Pulverized Coal – 750 MW	Supercritical Pulverized Coal
Coal Fired	Supercritical Pulverized Coal with CC – 638 MW	Supercritical Pulverized Coal with CC
Coal Fired	2x1 Integrated Gasification	2x1 Integrated Gasification
Coal Fired	2x1 Integrated Gasification with CC	2x1 Integrated Gasification with CC
Waste to Energy	MSW Stoker Fired	MSW Stoker Fired
Waste to Energy	RDF Stoker Fired	RDF Stoker Fired
Waste to Energy	Wood Stoker Fired	Wood Stoker Fired
Waste to Energy	Landfill Gas IC Engine	Landfill Gas IC Engine
Waste to Energy	Anaerobic Digester Gas IC Engine	Anaerobic Digester Gas IC Engine
Waste to Energy	Co-fired Circulating Fluidized Bed	Co-fired Circulating Fluidized Bed
Waste to Energy	Co-fired Circulating Fluidized Bed	Co-fired Circulating Fluidized Bed
Energy Storage	Pumped Hydro Energy Storage	Pumped Hydro Energy Storage
Energy Storage	Adv. Battery Energy Storage	Adv. Battery Energy Storage
Energy Storage	Compressed Air Energy Storage	Compressed Air Energy Storage
Renewable	Wind	Wind
Renewable	Solar Photovoltaic	Solar Photovoltaic
Renewable	Solar Thermal	Solar Thermal
Renewable	Hydro Electric	Hydro Electric
Nuclear	Small Modular Nuclear	Small Modular Nuclear

4.2.1.1 Natural Gas

Because of the EPA’s New Source Performance Standards (“NSPS”) for GHG, natural gas has become the fuel of choice for new fossil generation.

Typically, SCCTs are used for peaking power due to their fast load ramp rates and relatively low capital costs. The SCCT options include traditional frame machines as well as aero-derivative combustion

turbines. Two options from General Electric (“GE”) were evaluated as representative aero-derivative technology options: GE’s LM6000 and LMS100 combustion turbines. Aero-derivative machines are flexible, more efficient than larger frame units, and can be installed with high temperature oxidation catalysts for carbon monoxide control and a selective catalytic reduction (“SCR”) system for nitrogen oxides (“NO_x”) control, which allows them to be located in areas with air emissions concerns. Frame simple-cycle machines, on the other hand, are larger and less expensive on \$/kW basis. This study considered GE models 7EA and 7F-5 as representative technology options for the “E” and “F” turbine classes. The analysis considered building and operating single SCCT and multiple SCCT units to reflect savings from economies of scale.

Other natural gas-fired generation options include internal combustion engines, microturbines, and fuel cells. These options are easily scalable and well-suited for distributed generation and combined heat and power applications. For this reason, the supply-side analysis modeled these options as single units and as multiple units. The Wärtsilä 18V50DF reciprocating engine was evaluated in this study as the representative technology option for the reciprocating engine. Reciprocating engines can accommodate both natural gas and fuel oil, and have high efficiency across the ambient temperature range. Reciprocating engines are becoming popular as a means to follow wind turbine generation with their quick start times and operational flexibility. At present, fuel cells hold less promise for large utility-scale applications due to high capital and maintenance costs, partly attributable to the lack of production capability and limited development.

Multiple NGCC configurations were evaluated: 1x1, 2x1, and 3x1 configurations based on “F-Class,” “G/H-Class,” and “J-Class” combustion turbines. The “F-Class” turbine designs tend to be smaller with faster startup times and higher operational flexibility, including peaking power capabilities and reduced load operation for off-peak turn-down. The “G/H-Class” turbine design is better geared for base load operation. Compared to the “F-Class,” it is larger and more efficient, but with less turndown capability. The “J-Class” combustion turbine, which is an even larger and a more advanced design, is now commercially available in the United States, though no orders have been placed to date. The generation technology options table also includes DF, which is not a stand-alone resource option, but is considered to be an available option for any combined-cycle configuration and represents a low cost option to add peaking capability at relatively high efficiency. DF is also a mechanism to recover lost power generation capability due to high ambient temperatures.

4.2.1.2 Coal Fired

The uncertainty of both proposed and future carbon regulations as well as the difficulty in obtaining environmental permits for coal-based generation have drastically reduced the interest in developing and investing in new pulverized coal technology. Supercritical pulverized coal (“PC”) boilers continue to be the most efficient and cost effective with the smallest overall emission intensity rates among coal-fired technology options. Compared to subcritical PC, supercritical PC have better load following capability, faster ramp rates, and use less water.

The potential requirement for CO₂ capture (“CC”) represents a significant cost for new and, possibly, existing coal resources. Existing federal NSPS for GHG regulations would require CC for new coal units to meet GHG emission limits. CC has been demonstrated in the field, but not at the scale that would be necessary for utility generation. As the technologies mature, they will likely become more technically and financially feasible, especially if markets emerge for the captured gases. In the meantime, however, early adopters may be subject to significant cost and performance risks.

Circulating fluidized bed (“CFB”) boilers are a mature coal technology option that is well suited to burn fuels with a large variability in constituents. Large CFBs require more than one boiler. This increases capital costs but improves unit availability compared to PC technology options. Like PC technology options, CFB are also subject to NSPS for GHG regulations and would require the same CC technology.

The Integrated Gasification Combined-cycle (“IGCC”) is the third coal-based technology option considered in this study. A significant advantage for IGCC when compared to PC technology options is the fact that CO₂ capture with an IGCC is more proven for utility-scale applications. However, IGCC is a technology in continued development and various stages of commercialization. Only a limited number of IGCC plants have been built and operated around the world. These early plants have significantly exceeded their capital budgets.

4.2.1.3 Waste to Energy

Waste to energy (“WTE”) generation can be a practical generation option if there is an existing source of waste that can be used as fuel. Waste fuel is a very diverse category that includes: municipal solid waste (“MSW”), refuse derived fuel (“RDF”), wood chips, landfill gas, sewage, and tire derived fuel (“TDF”). Waste to energy fuels will be discussed in more detail in Section 4.3.3.2. Depending on the waste fuel, most traditional technologies can be employed, including stoker boilers, CFB boilers, and reciprocating engines. The greatest challenge to building large WTE plants or retrofitting a coal unit to a large biomass plant is the cost, availability, reliability, and homogeneity of a long-term fuel supply. The transport and handling logistics of large quantities of WTE fuel poses a significant challenge, depending on the size of the facility.

4.2.1.4 Energy Storage

Energy storage technology options provide short term peaking generation and voltage frequency management. Battery energy storage systems have fast response times, allowing flexibility in load management. CAES and pumped hydro energy storage systems store off-peak power to be released during on-peak demand periods. Energy storage continues to be of interest since the variable nature of some conventional renewable generation alternatives could be enhanced if the energy produced could be stored. However, energy storage technology options are still not cost effective. In addition, land use requirements for pumped hydroelectric facilities make this storage technology option not very suitable in the Companies’ territory.

4.2.1.5 Renewables

The renewable options include solar, wind, and hydro generation. Due to the historically lower capital cost compared to other renewable options, wind turbines have been more common in the utility industry but do not provide a good source of base-load capacity. The viability of wind generation is dependent on wind speeds. Kentucky has average wind speeds that are less than 12.5 mph. Wind speeds of 14.5 mph are needed for suitable wind generation. In this IRP, the peak contribution of the wind resources is assumed to be 11 percent of the total wind capacity. The assumed annual capacity factor of wind is 27 percent. A variable cost of \$5.40/MWh (in 2013 dollars) was added to capture the cost of additional load-following resources needed to integrate wind into the system.²⁷

Solar PV is a proven technology option for daytime peaking power and a viable option to pursue renewable goals and reduce emissions. Solar generation is a function of the amount of sunlight (i.e.

²⁷ The wind integration cost was based on The National Renewable Energy Laboratory’s Eastern Wind Integration and Transmission Study. For the complete report, see: <http://www.nrel.gov/docs/fy11osti/47078.pdf>.

electromagnetic radiation) incident on a surface per day, measured in kWh/m²/day. Kentucky receives between 4 and 5.5 kWh/m²/day. Areas in the western United States with high rates of solar development receive over 7.5 kWh/m²/day. In this IRP, the peak contribution of the solar resource is assumed to be 80 percent of the total solar capacity.

The Companies recently finished upgrading the hydro units on Dix Dam and are in the process of upgrading the Ohio Falls Hydro units. The Companies are not aware of any viable alternatives near their service territories for expanding their portfolio of hydro generation.

The costs of renewable generation remain higher than fossil generation technology options. However, with tax incentives and RECs, both solar PV and wind technology options can be cost competitive.

4.2.1.6 Nuclear

Included in the generation technology option table is a small modular reactor (“SMR”). Currently, SMRs are considered conceptual in design and are developmental in nature. This emerging nuclear technology option offers a smaller footprint and standardized construction compared to traditional nuclear systems, which reduces overall project costs. However, sociopolitical resistance and regulatory obstacles will continue creating permitting challenges for nuclear.

4.2.2 Technology Option Inputs

Table 15 provides the operating characteristics and costs for each of the technology options considered in the screening analysis. The 2013 LGE-KU Generation Technology Assessment, conducted by Burns & McDonnell, served as the basis for these inputs. The 2013 LGE-KU Generation Technology Assessment report is also provided in Volume 3, Technical Appendix. Each of the key input assumptions are discussed in more detail in the following sections.

Table 15 – Generation Technology Options

Representative Technology Option	Operating Characteristics			Costs (2013 \$)		
	Fuel Type	Capacity MW	Heat Rate Btu/kWh	Capital \$/kW	FO&M \$/kW-yr	VO&M \$/MWh
Simple-cycle GE LM6000 – One Unit	Gas	49				
Simple-cycle GE LM6000 – Four Units	Gas	195				
Simple-cycle GE LMS100 – One Unit	Gas	106				
Simple-cycle GE LMS100 – Two Units	Gas	211				
Simple-cycle GE 7EA – One Unit	Gas	87				
Simple-cycle GE 7EA – Three Units	Gas	260				
Simple-cycle GE 7F-5 – One Unit	Gas	211				
Simple-cycle GE 7F-5 – Three Units	Gas	634				
Recip Engine - 100 MW – Six Units	Gas	100				
Recip Engine - 200 MW – Twelve Units	Gas	200				
Microturbine - 1 MW – Five Units	Gas	1				
Microturbine - 3 MW – Fifteen Units	Gas	3				
Fuel Cell - 10 MW – Four Units	Gas	11				
Fuel Cell - 30 MW – Twelve Units	Gas	34				
Combined-cycle 1x1 GE 7F-5	Gas	315				
Combined-cycle 1x1 GE 7F-5 - Fired	Gas	357				
Combined-cycle 1x1 MHI GAC	Gas	397				
Combined-cycle 1x1 MHI GAC - Fired	Gas	452				
Combined-cycle 1x1 MHI JAC	Gas	441				
Combined-cycle 1x1 MHI JAC - Fired	Gas	503				
Combined-cycle 2x1 GE 7F-5	Gas	638				
Combined-cycle 2x1 GE 7F-5 - Fired	Gas	719				

Representative Technology Option	Operating Characteristics			Costs (2013 \$)		
	Fuel Type	Capacity MW	Heat Rate Btu/kWh	Capital \$/kW	FO&M \$/kW-yr	VO&M \$/MWh
Combined-cycle 2x1 MHI GAC	Gas	796				
Combined-cycle 2x1 MHI GAC - Fired	Gas	901				
Combined-cycle 2x1 MHI JAC	Gas	884				
Combined-cycle 2x1 MHI JAC - Fired	Gas	1,003				
Combined-cycle 3x1 GE 7F-5	Gas	960				
Combined-cycle 3x1 GE 7F-5 - Fired	Gas	1,082				
Combined-cycle 3x1 MHI GAC	Gas	1,199				
Combined-cycle 3x1 MHI GAC - Fired	Gas	1,356				
Combined-cycle 3x1 MHI JAC	Gas	1,330				
Combined-cycle 3x1 MHI JAC - Fired	Gas	1,509				
Subcritical Pulverized Coal	Coal	500				
Subcritical Pulverized Coal with CC	Coal	425				
Circulating Fluidized Bed	Coal	500				
Circulating Fluidized Bed with CC	Coal	425				
Supercritical Pulverized Coal	Coal	500				
Supercritical Pulverized Coal with CC	Coal	425				
Supercritical Pulverized Coal	Coal	750				
Supercritical Pulverized Coal with CC	Coal	638				
2x1 Integrated Gasification	Coal	618				
2x1 Integrated Gasification with CC	Coal	482				
MSW Stoker Fired	MSW	50				
RDF Stoker Fired	RDF	50				
Wood Stoker Fired	Biomass	50				
Landfill Gas IC Engine	LFG	5				
Anaerobic Digester Gas IC Engine	Sewage	5				
Co-fired Circulating Fluidized Bed	Coal/Biomass	50				
Co-fired Circulating Fluidized Bed	Coal/TDF	50				
Pumped Hydro Energy Storage	Charging	200				
Adv. Battery Energy Storage	Charging	10				
Compressed Air Energy Storage	Gas/Charging	135				
Wind	No Fuel	50				
Solar Photovoltaic	No Fuel	50				
Solar Thermal	No Fuel	50				
Hydro Electric	No Fuel	50				
Small Modular Nuclear	U235	225				

4.2.2.1 Unit capacity

Unit capacity for each technology option is the net full load output in MW at annual average ambient conditions of 59°F and 60% relative humidity at 600 feet of elevation.

4.2.2.2 Heat rate

The heat rate value provided is the full load net heat rate (HHV Btu/kWh) under new and clean operating conditions. The heat rate is based on annual average performance.

4.2.2.3 Capital Cost

The following assumptions were used by Burns & McDonnell in developing the capital cost estimates for the generation technology options:

- All capital cost estimates are stated in 2013 “overnight” dollars.
- All generation technology options are based on a generic Greenfield site in Kentucky.
- Water, natural gas, and transmission are assumed to be available at the site boundary.

- Capital estimate include air quality control equipment based on expected Best Available Control Technologies (“BACT”) requirements.
- Project indirect costs such as engineering and construction management as well as Engineering, Procurement, and Construction (“EPC”) fees are included. Owner’s costs such as project development and spare parts are also included.
- The following costs were excluded from the capital cost estimates: natural gas supply pipeline, sales and property tax, and transmission upgrades.

4.2.2.4 Fixed and variable O&M:

The following assumptions were used for determining the fixed and variable O&M costs:

- O&M costs are in 2013 dollars.
- O&M costs are based on operating a Greenfield site.
- Fixed O&M cost estimates include labor, office and administration, building and ground maintenance, communication, and laboratory expenses.
- Variable O&M costs include equipment maintenance, water treatment, ammonia, SCR replacements, and other consumables not including fuel.

4.2.2.5 Gas turbine major maintenance

Gas turbine maintenance was assumed to be covered by a long-term service agreement (“LTSA”). LTSA cost is based on \$/operating hour if hours of operation exceed 30 hours per start. Otherwise, the cost is determined per combustion turbine start.

4.2.2.6 Emission Rates for SO₂, NO_x and CO₂

The emission rates provided for each technology option, when applicable, represent full load emission rates, expressed in lbs/mmBtu. The emissions rates are based on expected BACT requirements.

4.2.3 Other Inputs

4.2.3.1 Investment Tax Credit and Renewable Energy Credits

Because of the uncertainty regarding the Investment Tax Credit, renewable technology options were evaluated with and without a 10% ITC.

As long as Kentucky does not have a renewable portfolio standard, the Companies would have the option to sell the RECs that are created when either a wind or solar facility produces electricity.²⁸ The Companies assumed prices of \$26 per solar REC and \$11 per wind REC in the supply-side screening analysis.

4.2.3.2 Financial Inputs

Table 16 provides the escalation rates used in the supply-side screening analysis for capital, fixed O&M, and variable O&M along with the revenue requirements discount rate.

²⁸ One REC is created for every MWh that is produced.

Table 16 – Key Financial Inputs

Input	Value
Capital Escalation Rate	2.0%
Fixed O&M Escalation Rate	2.0%
Variable O&M Escalation Rate	2.0%
Revenue Requirements Discount Rate	6.51%

4.2.3.3 Fixed Charge Rates, Book Life and Tax Life Assumptions

Table 17 lists the fixed charge rate ("FCR"), book life and tax life for the main technology types. FCR is used to calculate a levelized cost of capital.

Table 17 – FCR, Book Life and Tax Life

Technology Types	FCR (%)	Book Life (years)	Tax Life (Years)
Coal	8.16	50	20
SCCT	9.24	30	15
NGCC	9.47	40	20
Wind and Solar	8.06	20	5
Hydro	9.37	55	20

4.2.3.4 SO₂ and NO_x Emission Prices

The emission price forecasts for SO₂ and NO_x in Table 18 are based on market quotes published by Amerex.

Table 18 – SO₂ and NO_x Emission Prices (\$/short ton)

Year	Annual NO _x	Ozone NO _x	SO ₂
2016	125.00	125.00	75.00
2017	125.00	132.81	100.00
2018	109.38	118.06	87.50
2019	93.75	103.30	75.00
2020	78.13	88.54	62.50
2021	150.00	73.78	75.00
2022	70.00	57.18	37.50
2023	46.67	141.67	25.00
2024	35.00	71.67	18.75
2025	28.00	16.67	15.00
2026	10.00	11.67	12.50
2027	5.00	1.67	5.00
2028	0.00	0.00	0.00
2029	0.00	0.00	0.00
2030	0.00	0.00	0.00
2031	0.00	0.00	0.00
2032	0.00	0.00	0.00
2033	0.00	0.00	0.00
2034	0.00	0.00	0.00
2035	0.00	0.00	0.00
2036	0.00	0.00	0.00
2037	0.00	0.00	0.00
2038	0.00	0.00	0.00
2039	0.00	0.00	0.00
2040	0.00	0.00	0.00
2041	0.00	0.00	0.00
2042	0.00	0.00	0.00
2043	0.00	0.00	0.00
2044	0.00	0.00	0.00
2045	0.00	0.00	0.00

4.2.3.5 Firm Gas Transportation

Firm gas transportation costs for SCCT and NGCC technology options are listed in Table 19. Firm gas transportation is based on rates from Texas Gas for winter-no-notice and summer-no-notice service in the LG&E territory. Firm gas is assumed to be available for 16 hours of full load continuous operation for SCCT technology options and 24 hours of full load continuous operation for NGCC technology options.

Table 19 – Firm Gas Transportation Cost

Representative Technology Option	Firm Gas Transportation (2013 \$)
Simple-cycle GE LM6000 – One Unit	\$968,806
Simple-cycle GE LM6000 – Four Units	\$3,875,225
Simple-cycle GE LMS100 – One Unit	\$1,944,884
Simple-cycle GE LMS100 – Two Units	\$3,889,767
Simple-cycle GE 7EA – One Unit	\$2,071,370
Simple-cycle GE 7EA – Three Units	\$6,214,109
Simple-cycle GE 7F-5 – One Unit	\$4,363,915
Simple-cycle GE 7F-5 – Three Units	\$13,091,745
Recip Engine - 100 MW – Six Units	\$1,764,197
Recip Engine - 200 MW – Twelve Units	\$3,528,394
Microturbine- 1 MW – Five Units	\$23,697
Microturbine - 3 MW – Fifteen Units	\$71,092
Fuel Cell - 10 MW – Four Units	\$281,126
Fuel Cell - 30 MW – Twelve Units	\$843,378
Combined-Cycle 1x1 GE 7F-5	\$6,494,371
Combined-Cycle 1x1 GE 7F-5 - Fired	\$7,686,258
Combined-Cycle 1x1 MHI GAC	\$8,079,095
Combined-Cycle 1x1 MHI GAC - Fired	\$9,571,025
Combined-Cycle 1x1 MHI JAC	\$8,527,388
Combined-Cycle 1x1 MHI JAC - Fired	\$10,120,189
Combined-Cycle 2x1 GE 7F-5	\$12,982,213
Combined-Cycle 2x1 GE 7F-5 - Fired	\$15,406,531
Combined-Cycle 2x1 MHI GAC	\$16,159,796
Combined-Cycle 2x1 MHI GAC - Fired	\$19,166,420
Combined-Cycle 2x1 MHI JAC	\$17,054,289
Combined-Cycle 2x1 MHI JAC - Fired	\$20,224,211
Combined-Cycle 3x1 GE 7F-5	\$19,464,926
Combined-Cycle 3x1 GE 7F-5 - Fired	\$23,095,539
Combined-Cycle 3x1 MHI GAC	\$24,221,944
Combined-Cycle 3x1 MHI GAC - Fired	\$28,725,838
Combined-Cycle 3x1 MHI JAC	\$25,594,972
Combined-Cycle 3x1 MHI JAC - Fired	\$30,339,018

4.3 Supply-Side Screening Key Uncertainties

In the screening analysis, the levelized cost for each of the technology options was calculated at various levels of utilization. In addition to the level of utilization (i.e., capacity factor), the levelized cost of each technology option is impacted by the uncertainty in capital cost, fuel cost, and the unit efficiency. As a result, the technology options were evaluated over three capital cost scenarios, three heat rate scenarios, three fuel scenarios, and ten capacity factors for a total of 270 cases. Each of these inputs is discussed in the following sections.

4.3.1 Capital Cost

Table 20 lists the capital cost uncertainty range by technology type. These capital cost ranges were used to develop high and low capital cost scenarios for each technology option. The uncertainty in capital cost for a given technology option is a function of the technology's maturity and the extent to which the cost of building a technology option is site-dependent. Generally, the more conventional or commercially mature technology options have a narrower capital cost range, whereas the more developmental or site-dependent technology options have a wider range.

Table 20– Capital Cost Range by Technology Type

Generation Technology Option	Capital Cost Range (%)	
	Low	High
Simple Cycle Combustion Turbine	-10%	20%
Combined Cycle Combustion Turbine	-10%	20%
Subcritical Pulverized Coal	-10%	25%
Subcritical Pulverized Coal with CC	-5%	35%
Circulating Fluidized Bed	-10%	25%
Circulating Fluidized Bed with CC	-5%	35%
Supercritical Pulverized Coal – 500 MW	-10%	25%
Supercritical Pulverized Coal with CC – 425 MW	-5%	35%
Supercritical Pulverized Coal – 750 MW	-10%	25%
Supercritical Pulverized Coal with CC – 638 MW	-5%	35%
2x1 Integrated Gasification	-10%	30%
2x1 Integrated Gasification with CC	-5%	35%
MSW Stoker Fired	-5%	10%
RDF Stoker Fired	-15%	15%
Wood Stoker Fired	-15%	15%
Landfill Gas IC Engine	-15%	15%
Anaerobic Digester Gas IC Engine	-15%	15%
Co-fired Circulating Fluidized Bed	-10%	20%
Co-fired Circulating Fluidized Bed	-10%	25%
Pumped Hydro Energy Storage	-10%	35%
Adv. Battery Energy Storage	-10%	25%
Compressed Air Energy Storage	-10%	35%
Wind	-10%	20%
Solar Photovoltaic	-20%	20%
Solar Thermal	-20%	20%
Hydro Electric	-15%	35%
Small Modular Nuclear	-5%	35%

4.3.2 Unit Efficiency (Heat Rate)

For non-renewable technology options, a technology option's levelized cost decreases as the assumed heat rate improves. In the screening analysis, each non-renewable technology option was evaluated at its expected heat rate and at heat rates 5% above and below the expected heat rate. A 5% decrease in heat rate represents technological advancement, whereas a 5% increase could represent degraded performance, actual unit efficiency falling short of design specification, or a decreased efficiency due to the addition of future environmental controls.

4.3.3 Fuel Prices

The levelized cost for non-renewable technology options was computed over three fuel price scenarios: Low, Mid, and High. The following sections discuss these scenarios for conventional and non-conventional fuels.

4.3.3.1 Natural Gas and Coal

As mentioned previously, natural gas has become the fuel of choice for new fossil generation. An abundance of natural gas supply resulting from advancements in natural gas drilling technologies has put downward pressure on prices and greatly improved the economics of NGCC technology. On the other hand, the impending nationwide retirement of coal units and the shift to NGCC units will increase the demand for natural gas and put upward pressure on prices. Additional upside price risk is associated with the possibility of regulations limiting the extraction of shale gas. The price of natural gas could have a significant impact on the Companies' optimal expansion plan; lower natural gas prices would favor natural gas technology options, while higher natural gas prices would make renewable generation more competitive. To address this long-term natural gas price uncertainty, the supply-side screening analysis considered three natural gas price scenarios.

The Henry Hub ("HH") natural gas price scenarios considered in this analysis are listed in Table 21. The Mid natural gas price forecast is based on market prices for the short term and the Energy Information Administration's ("EIA") 2015 Annual Energy Outlook ("AEO") for the long term. Prices in 2016-2017 were taken from the Companies' 2016 Business Plan and reflect NYMEX HH monthly forward prices as of 6/18/2015. Prices in 2018-2020 reflect a blend of market prices and a midpoint average curve between the annual HH prices from two EIA AEO 2015 scenarios: "High Oil Price" (a proxy for high gas price) and "High Oil and Gas Resource" (a proxy for low gas price). Blending is 75% market in 2018, 50% market in 2019, and 25% market in 2020. Prices in 2021-2037 reflect the midpoint average curve between the annual HH prices from the "High Oil Price" and "High Oil-Gas Resource" scenarios ("Midpoint"). Prices in 2038-2045 are escalated annually at the 2027-2037 compound annual growth rate of the Midpoint forecast (4.4%) from the 2037 Midpoint forecast prices. Monthly prices after 2017 are calculated using average monthly shape indices derived from the market forwards for 2016-2020. The Low natural gas price forecast is based on EIA's 2015 AEO "High Oil and Gas Resource" scenario. To maintain a consistent spread between the Low and Mid natural gas price scenarios, years 2016-2018 in the Low scenario were adjusted to reflect the 2019 percentage difference between the Low and Mid scenarios. The High natural gas price forecast is based on EIA's 2015 AEO "High Oil Price" scenario.

The forecast mine-mouth coal prices for the Companies' open coal position for Illinois Basin high-sulfur ("ILB-HS") and Powder River basin ("PRB") coal were used to develop the delivered coal prices used in the analysis. The coal prices in Table 21 are based on a 75% blend of ILB-HS coal and 25% PRB coal. Through 2020, these coal prices are based on (i) market bid prices and (ii) a forecast developed by Wood Mackenzie (an energy and mining research and consulting firm) in the spring of 2015.²⁹ In 2020-2040, these prices were escalated at the annual growth rates in the average coal price forecast from EIA's AEO 2015 Reference case. Beyond 2040, coal prices were extrapolated based on the price forecast's 2030-2040 CAGR. An average transportation cost adder is escalated throughout the forecast period.

²⁹ The coal prices in 2016 and 2017 are based fully on the bid price curve. Prices in 2018 are 75% bid prices, 25% Wood Mackenzie. Prices in 2019 and 2020 are blended 50% bid/50% Wood Mackenzie and 25% bid/75% Wood Mackenzie, respectively.

Table 21 – Natural Gas and Coal Prices (Nominal \$/mmBtu)

Year	Delivered Natural Gas Prices			Coal Prices Blended (75% ILB-HS, 25% PRB)
	Low	Mid	High	
2016				
2017				
2018				
2019				
2020				
2021				
2022				
2023				
2024				
2025				
2026				
2027				
2028				
2029				
2030				
2031				
2032				
2033				
2034				
2035				
2036				
2037				
2038				
2039				
2040				
2041				
2042				
2043				
2044				
2045				

The level of natural gas prices determines the favorability of renewable technology options; as natural gas prices increase, the value of renewable technology options potentially increases. Furthermore, the relationship or “spread” between natural gas and coal prices is a key factor in comparing the value of existing or proposed natural gas alternatives to existing coal alternatives. With three natural gas price forecasts and one coal price forecast, this analysis considered three spreads between natural gas and coal prices. As a result, it was not necessary to develop more than one coal price forecast.

4.3.3.2 Non-Conventional Fuels

For the WTE generation technology options, both the fuel costs and fuel cost sensitivities are estimated based on research and data provided by Electric Power Research Institute (“EPRI”) and Burns & McDonnell. Table 22 lists the assumed price for non-conventional fuels in the Low, Mid, and High fuel

price scenarios. These prices were assumed to escalate at 2.0% per year over the 30-year evaluation period. Each of these fuel types are discussed further in the following sections.

Table 22 – Non-Conventional Fuels (2013 Nominal \$/mmBtu)

Fuel Type	Non-Conventional Delivered Fuel Prices Source (EPRI)		
	Low	Mid	High
Municipal Solid Waste			
Refuse Derived Fuel			
Biomass			
Landfill Gas			
Sewage			
Tire Derived Fuel			
Uranium (U235)			

4.3.3.2.1 Municipal Solid Waste

The negative MSW price represents the tipping fee to accept and burn unprocessed solid waste in its as-discarded form with minimal processing. The tipping fee will be dependent on the availability of MSW landfills and their proximities to solid waste sources.

4.3.3.2.2 Refuse Derived Fuel

RDF is MSW that has been sorted to remove non-combustibles and then processed into pellets. The higher end range includes a quality product that has a clean air additive negating the need for more capital intensive equipment.

4.3.3.2.3 Biomass

Biomass refers to using plant-based fuels for energy production. The forecast developed for this analysis is based on wood chips supplied from a 50-mile radius of the plant. The price is highly dependent on the moisture content of the wood, availability in the area, as well as diesel prices.

4.3.3.2.4 Landfill Gas

LFG is a byproduct of the decomposition of waste stored in landfills. LFG is collected from wells at the landfill, filtered, and then compressed. The LFG forecast assumes that the generating unit will be located at the landfill site and the gas has a heating value of 600 Btu/ft³. LFG prices vary greatly with the availability and quality of LFG.

4.3.3.2.5 Sewage

Bio-methane gas is produced from the digestion of sewage sludge or livestock manure. It is similar to LFG with respect to the quality of the fuel and the generation equipment required. The feedstock costs for most currently installed Anaerobic Digesters are zero.

4.3.3.2.6 Tire Derived Fuel

TDF consists of chipped tires with the steel belts removed. The co-firing of up to 10 percent of TDF (by weight) in a fluidized bed boiler can be considered a commercial technology option as there is no significant change in the technology for a dedicated coal unit. However, there is very limited success with mass firing of TDF. While TDF has a low ash and sulfur content as well as a fuel heating value equivalent to or better than coal, the general lack of availability of TDF is a drawback. TDF prices vary significantly with oil prices, the local tire market, and competitive buyers.

4.3.3.2.7 U-235

The small modular nuclear reactor uses uranium enriched in the U-235 isotope for its fuel. Both the price and the range were provided by Burns & McDonnell.

4.3.3.2.8 Charging cost

The energy storage technology options must be charged or recharged by equipment utilizing electricity generated by another source. As such, charging is typically accomplished during periods of low demand by electricity with low generation costs. It is assumed that the energy storage options considered in this analysis are charged using power generated from the Companies' base load units such as coal and NGCC units. The uncertainty around charging costs depends on conventional fuel prices, actual load requirements, and the availability of base load units. Table 23 lists the charging costs used in the analysis.

Table 23 – Charging Cost (\$/MWh)

Year	Charging Cost (\$/MWh)		
	Low	Mid	High
2016			
2017			
2018			
2019			
2020			
2021			
2022			
2023			
2024			
2025			
2026			
2027			
2028			
2029			
2030			
2031			
2032			
2033			
2034			
2035			
2036			
2037			
2038			
2039			
2040			
2041			
2042			
2043			
2044			
2045			

4.3.4 Capacity Factor

Where applicable, the levelized cost of each technology option was calculated over ten capacity factors (1% and 10-90% in 10% increments).

4.4 Supply-Side Screening Methodology

In the screening analysis, the Companies computed the 30-year levelized cost for the technology options developed by Burns & McDonnell over a range of scenarios. The levelized cost includes the costs associated with building and operating the unit. Where applicable, the following costs were considered in the analysis:

1. Fuel Costs
2. Maintenance Cost: Cost per Start, Hourly Operating Cost, or Cost per energy

3. Variable O&M
4. Capital Costs
5. Fixed O&M
6. Firm Gas Transportation Costs
7. Charging Cost
8. Emission Costs
9. Renewable Energy Credits

With some exceptions, the levelized cost of each technology option (in \$/MWh) was calculated over three capital cost scenarios, three heat rate scenarios, three fuel scenarios, and ten capacity factors for a total of 270 cases.³⁰ Technology options that were ranked among the top four least-cost technology options in any case were considered for the more detailed expansion planning analysis.

Several technology options were limited to a maximum capacity factor based on the operating characteristics of the technology option. Capacity factors for wind and solar were limited to 27% and 20%, respectively. The hydroelectric option was limited to a 40% capacity factor based on the Companies' experience with its current hydro assets.

Several technology options were not considered in the screening analysis.

- The 3x1 NGCC options were excluded from the analysis due to their size and impact on system reliability; given the relatively small size of the Companies' generating portfolio, recovering from the loss of such a large unit is difficult. While they were not excluded from the analysis, some larger 2x1 NGCC options create similar concerns.
- The "J-Class" combustion turbine was excluded from the analysis due to its nascent design and limited operating history; although it is now commercially available in the United States, no orders have been placed to date.
- The small modular nuclear reactor was also not included due to significant challenges in siting and permitting the unit especially in Kentucky.³¹
- The MSW stoker fired technology option was excluded from the analysis due to the uncertainty regarding the availability and quality of municipal solid waste fuel.

Given the uncertainty in REC prices and the availability of ITCs for renewable technologies, two iterations of cases each were evaluated:

- No ITC or RECs: This iteration did not include an ITC for renewable technologies or wind and solar RECs.
- 10% ITC and RECs: This iteration incorporated a 10% ITC and REC market prices for solar and wind technologies.

4.5 Supply-Side Screening Results

Table 24 lists the technology options that were ranked among the top four least-cost technology options in the "No ITC or RECs" iteration for at least one of the 270 cases. Table 25 contains the same information for the "10% ITC and RECs" iteration. A comparison of levelized costs for each technology is included in Section 6 – Appendix A.

³⁰ Each of these scenarios are discussed in Section 4.3.

³¹ Since 1984, the Kentucky General Assembly has had a moratorium on any nuclear plant construction without a plan for permanent waste disposal.

Table 24 – Frequency of Occurrence of the Generation Technology Option in the Top Four

Generation Technology Option	# Occurrences				Total
	1 st	2 nd	3 rd	4 th	
2x1 NGCC G/H-Class	212	5	21	32	270
2x1 NGCC G/H-Class – DF	0	86	184	0	270
2x1 NGCC F-Class	0	149	51	17	217
2x1 NGCC F-Class – DF	0	0	0	155	155
SCCT F-Class – Three Units	58	2	10	7	77
SCCT F-Class – One Unit	0	28	4	21	53
1x1 NGCC G/H-Class	0	0	0	38	38

Table 25 – Frequency of Occurrence of the Generation Technology Option in the Top Four with ITC & Wind and Solar RECs

Generation Technology Option	# Occurrences				Total
	1 st	2 nd	3 rd	4 th	
2x1 NGCC G/H-Class - DF	0	65	195	10	270
2x1 NGCC G/H-Class	205	15	22	19	261
2x1 NGCC F-Class	0	156	37	18	211
2x1 NGCC F-Class - DF	0	0	0	133	133
SCCT F-Class – Three Units	55	1	8	3	67
1x1 NGCC G/H-Class	0	0	2	54	56
SCCT F-Class – One Unit	0	27	1	21	49
Wind	1	6	4	2	13
Solar Photovoltaic	9	0	1	1	11
Compressed Air Energy Storage	0	0	0	9	9

The results in both tables are very similar with natural gas technology options dominating as least-cost options. In both iterations, the “2x1 NGCC G/H-Class” option was least cost in more than 200 of the 270 cases. The “SCCT F-Class – Three Units” option was least-cost in over 50 cases in both iterations. In the “10% ITC and RECs” iteration, the solar PV and wind technology options were ranked among the top four least-cost technology options in multiple cases.

In this analysis, changes in non-conventional fuels are positively correlated with changes in natural gas. When changes in non-conventional fuels are assumed to be negatively correlated with natural gas, the results of the analysis are unchanged.

Table 26 lists the generation technology options that were evaluated in the detailed expansion planning analysis. The two F-Class NGCC options, the 2x1 NGCC G/H-Class option with duct firing (“DF”), and the hydroelectric options in Table 24 and Table 25 were ultimately excluded from the detailed analysis. Proposed GHG regulation and uncertainty in gas prices make the added efficiency of the G-Class option more cost-effective than the F-Class option. Additionally, the capital and fixed costs for the G-Class option are lower on a per-kilowatt (“kW”) basis. The 2x1 NGCC G/H-Class option with duct firing was consistently less favorable than the 2x1 NGCC G/H-Class option without duct firing.³² The CAES options were eliminated because they ranked among the top four least-cost options in only ten or fewer of 270 cases. In addition, the Companies are not aware of any viable sites for new CAES capacity near their service territories.

³² In addition, the 2x1 options with duct firing are not materially different from the 2x1 options without duct firing. Duct firing serves as a means to adjust the size and flexibility of a NGCC unit.

Table 26 – List of Generation Technology Options for the Expansion Plan Analysis

Generation Technology Options
2x1 NGCC G/H-Class
1x1 NGCC G/H-Class
SCCT F-Class – Three Units
SCCT F-Class – One Unit
Solar Photovoltaic
Wind

The list of generation technology options in Table 26 is identical to the list of technology options that passed the screening analysis for the 2015 IRP.

5 Expansion Planning Analysis

5.1 Key Inputs and Uncertainties

The Companies evaluate long-term resource decisions under a number of possible futures to ensure that customers' energy needs are reliably met at the lowest reasonable cost. While there are a number of uncertainties that could have some impact on the Companies' resource decisions, the uncertainties in native load (demand and energy) and natural gas prices are the most important to consider when evaluating long-term generating resources. Therefore, the Companies considered these uncertainties in this analysis to understand their impact on the Companies' optimal expansion plan.

5.1.1 Load Forecast

The only reason for the Companies to acquire new supply-side or demand-side resources is to reliably meet customers' future energy needs at the lowest reasonable cost. Therefore, the forecast of future demand and energy has a significant impact on the Companies' optimal expansion plan. The volume of future load (demand and energy) is driven by future economic activity, the adoption rate of new and existing DSM programs, and the development of new electric end-uses (e.g., electric vehicles). The Companies utilized the best information available to develop a reasonable long-term "Base" load forecast. As with any long-term forecast, the uncertainty associated with it tends to grow through time. Therefore, "High" and "Low" load forecasts were also developed, which reflect the statistical uncertainty about the Base load forecast. Table 27 lists the three load forecast scenarios evaluated in this analysis.

Table 27 – Native Load Scenarios

Year	Energy Requirements (GWh)			Peak Demand (MW)		
	Low	Base	High	Low	Base	High
2016	33,729	35,434	37,139	6,619	6,948	7,277
2017	33,852	35,580	37,309	6,655	6,988	7,321
2018	33,916	35,670	37,424	6,667	7,004	7,342
2019	32,989	34,767	36,545	6,408	6,744	7,080
2020	32,638	34,388	36,137	6,419	6,754	7,090
2021	32,719	34,464	36,209	6,450	6,786	7,122
2022	32,818	34,559	36,299	6,484	6,820	7,156
2023	32,928	34,664	36,400	6,516	6,852	7,189
2024	33,068	34,799	36,530	6,538	6,874	7,209
2025	33,139	34,867	36,595	6,555	6,891	7,227
2026	33,265	34,992	36,718	6,581	6,918	7,254
2027	33,393	35,119	36,846	6,609	6,946	7,283
2028	33,548	35,277	37,006	6,638	6,977	7,315
2029	33,682	35,416	37,151	6,665	7,005	7,345
2030	33,820	35,563	37,306	6,690	7,033	7,376

Energy and peak demand grow at similar rates in each of the three load scenarios. The Low load scenario reflects an environment where a significant portion of the Companies' load is lost. Compared to the Base load scenario, peak demand in the Low load scenario is approximately 300 MWs lower in 2016. The High load scenario reflects an environment where a significant amount of load is gained. Compared to the Base load scenario, peak demand in the High load scenario is approximately 300 MWs higher in 2016.

5.1.2 Natural Gas Prices

The price of natural gas could have a significant impact on the Companies' optimal expansion plan; lower natural gas prices would favor natural gas technology options, while higher natural gas prices would make renewable generation more competitive. To address this long-term natural gas price uncertainty, the expansion planning analysis considered three natural gas price scenarios. The "Low," "Mid," and "High" scenarios are listed in Section 4.3.3.1 in Table 21.

5.1.3 Summary of Scenarios

The native load and natural gas price scenarios were combined to produce nine scenarios for the expansion planning analysis, listed in Table 28.

Table 28 – Analysis Scenarios

Scenario	Native Load	Gas Price
1	Low	Low
2	Low	Mid
3	Low	High
4	Base	Low
5	Base	Mid
6	Base	High
7	High	Low
8	High	Mid
9	High	High

5.1.4 Other Inputs

5.1.4.1 GHG Regulations

When more information is known regarding the costs and implementation of the CPP, the Companies will conduct a detailed study to determine the most cost-effective compliance plan. Given the extended compliance deadlines, this resource assessment assumes – in the absence of better information – that CPP compliance costs will not result in any changes to the Companies' generating portfolio.

5.1.4.2 Supply-Side Screening Analysis Results

Table 29 lists the capital costs and unit characteristics for each of the supply-side options that passed the Supply-Side Screening Analysis. Capital costs for these options were developed by Burns & McDonnell. A summary of Burns & McDonnell's Generation Technology Study is included in Section 4.2.2 in Table 15. The complete report is also included in Volume III, Technical Appendix.

Table 29 – Cost and Unit Characteristics for Generation Technology Options (2013 \$)

Unit Type	2x1 NGCC	1x1 NGCC	Simple-Cycle CT	3 Simple-Cycle CTs	Wind Turbines	Solar PV
Reference Name ³³	2x1G	1x1G	SCCT	CTx3	Wind	SLPV
Net Capability (MW)						
Summer	737	368	201	602	50	50
Winter	859	429	220	659	50	50
Overnight Installed Cost (\$/kW) ³⁴						
Total Non-Fuel Variable O&M (\$/MWh) ³⁵						
Total Fixed O&M (\$/kW-yr) ³⁶						
Full Load Heat Rate (mmBtu/MWh)						
Unavailability (%) ³⁷						

NGCC technology has higher capital costs and fixed O&M, but much better heat rates than simple-cycle CTs. The 3 SCCTs option takes advantage of economies of scale, which results in very low capital costs. Wind and Solar options have much higher capital costs than other options, but no energy costs.

5.1.4.3 Reserve Margin

The Companies target a minimum 16 percent reserve margin for the purpose of developing expansion plans. The derivation of this reserve margin target is discussed in detail in the report titled *2014 Reserve Margin Study* located in Volume III, Technical Appendix of the 2014 IRP.

5.1.4.4 Existing Unit Characteristics

Table 30 lists the summer capacity rating, equivalent unplanned outage rate (“EUOR”), and average full load heat rate for each of the Companies’ existing units. EUOR is approximately the sum of each unit’s equivalent forced outage rate and maintenance outage rate.

³³ Reference names are used to more easily compare expansion plans.

³⁴ Installed cost is based on annual average capacity.

³⁵ Variable O&M for NGCC and SCCT options includes long-term service agreement costs.

³⁶ Fixed O&M for NGCC and SCCT options includes costs associated with reserving firm gas-line capacity.

³⁷ Unavailability for NGCC and SCCT options is the long-term steady-state outage rate expected after initial operation. For wind and solar options, unavailability reflects the expected capacity factor (Unavailability = 1 – Capacity Factor).

³⁸ Wind turbine capacity factor modeled at 27% with 11% of the capacity counting toward reserve margin.

³⁹ Solar photovoltaic capacity factor modeled at 17.4% with 80% of the capacity counting toward reserve margin.

Table 30 – Existing Unit Characteristics

Unit	Installed Year	Net Summer Rating (MW) ⁴⁰	EUOR (%)	Average Full Load Heat Rate (mmBtu/MWh)
Brown 1	1957	106	8.8%	10.377
Brown 2	1963	166	8.8%	10.289
Brown 3	1971	410	7.9%	10.845
Brown 5	2001	130	18.5%	12.111
Brown 6	1999	146	6.8%	10.726
Brown 7	1999	146	6.8%	10.726
Brown 8	1995	121	7.8%	12.319
Brown 9	1994	121	7.8%	12.268
Brown 10	1995	121	7.8%	12.268
Brown 11	1996	121	7.8%	12.319
Brown Solar	2016	8	N/A	N/A
Cane Run 7	2015	642	5.0%	6.842
Cane Run 11	1968	14	50.0%	16.117
Dix Dam 1-3	1925	31.5	N/A	N/A
Ghent 1	1974	474	7.9%	10.843
Ghent 2	1977	495	7.9%	10.610
Ghent 3	1981	485	7.9%	11.065
Ghent 4	1984	465	7.9%	10.955
Haefling 1-2	1970	24	50.0%	18.000
Mill Creek 1	1972	300	7.9%	10.430
Mill Creek 2	1974	297	7.9%	10.598
Mill Creek 3	1978	391	7.9%	10.539
Mill Creek 4	1982	477	7.9%	10.726
Ohio Falls 1-8	1928	58	N/A	N/A
Paddy's Run 11	1968	12	50.0%	15.479
Paddy's Run 12	1968	23	50.0%	17.005
Paddy's Run 13	2001	147	12.4%	10.323
Trimble 1 (75%)	1990	383	7.0%	10.602
Trimble 2 (75%)	2011	549	9.0%	9.254
Trimble 5	2002	159	4.6%	10.668
Trimble 6	2002	159	4.6%	10.668
Trimble 7	2004	159	4.6%	10.668
Trimble 8	2004	159	4.6%	10.668
Trimble 9	2004	159	4.6%	10.668
Trimble 10	2004	159	4.6%	10.668
Zorn 1	1969	14	50.0%	18.676

5.1.4.5 Coal Prices

Table 31 lists the delivered coal price forecasts for each of the Companies' existing coal units.

⁴⁰ The ratings for Brown Solar, Dix Dam 1-3, and Ohio Falls 1-8 reflect the assumed output for these facilities during the summer peak demand.

Table 31 – Coal Prices (\$/mmBtu)

Year	Brown	Ghent	Mill Creek	Trimble High SO ₂	Trimble PRB
	6# SO ₂	6# SO ₂	6# SO ₂	6# SO ₂	0.8# SO ₂
2016					
2017					
2018					
2019					
2020					
2021					
2022					
2023					
2024					
2025					
2026					
2027					
2028					
2029					
2030					

5.1.4.6 SO₂ and NO_x Prices

Table 18 in Section 4.2.3.4 lists SO₂ and NO_x price forecasts for the study period.

5.1.4.7 Financial Inputs

Table 32 lists the key financial inputs that were utilized in the expansion planning analysis.

Table 32 – Key Financial Inputs

Input	Value
Return on Equity	10.0%
Cost of Debt	4.21%
Capital Structure	
Debt	47%
Equity	53%
Tax Rate	38.9%
Revenue Requirement Discount Rate	6.51%

5.1.4.8 Transmission System Costs

Due to the time required to estimate transmission interconnection and enhancement costs for specific resources, these costs are not included in the analysis. Prior to committing to a particular resource, the Companies will issue a request for proposals to evaluate the least-cost self-build resource against other market available resources. Transmission interconnection and enhancement costs will be considered in this analysis.

5.2 Expansion Planning Analysis

5.2.1 Methodology

The Strategist computer model was used to develop optimal expansion plans for each of the scenarios listed in Table 28. Strategist uses the Companies’ peak and energy load forecasts and load shapes for multiple years to create typical monthly load shapes for production costing purposes. System dispatch and operation are simulated using a load duration curve production costing technique. Production costs including fuel, incremental O&M, purchase power, and emission costs are calculated based on inputs including generating unit and purchase power characteristics, fuel costs, and unit or fuel specific emissions information. All combinations of potential options are evaluated to produce a list of resource plans, subject to user specified constraints, that satisfy the Companies’ minimum reserve margin criterion. The production cost analysis is combined with an analysis of new construction expenditures to suggest an optimal resource plan and sub-optimal resource plans based on minimizing utility cost.

5.2.2 Results

Table 33 shows optimal expansion plans for the nine scenarios evaluated. The number in parentheses following each Reference Name indicates how many units were commissioned in that year. All units commissioned after 2018 are assumed to be commissioned in the month of June. The location of each commissioned unit has not been determined.

Table 33 – Optimal Expansion Plans

Load	LL	LL	LL	BL	BL	BL	HL	HL	HL
Gas Price	LG	MG	HG	LG	MG	HG	LG	MG	HG
2016	BRS	BRS	BRS	BRS	BRS	BRS	BRS	BRS	BRS
2017									
2018									
2019									
2020									
2021							2x1G(1)	2x1G(1)	2x1G(1)
2022									
2023									
2024									
2025									
2026									
2027									
2028									
2029				2x1G(1)	2x1G(1)	SCCT(1)			
2030									

Load: Low (LL), Base (BL), High (HL) Gas Price: Low (LG), Mid (MG), High (HG)

The Companies have a long-term need for capacity beginning in 2029 in the Base load scenario and 2021 in the High load scenario.⁴¹ In five of six Base and High load scenarios, this need was met with NGCC capacity; in one scenario, this need was met with SCCT capacity. In the Low load scenario, the Companies do not have a long-term need for capacity in the study period.

⁴¹ The analysis assumed additional capacity cannot be added prior to 2021. For this reason, additional capacity is needed in 2021 in the High load scenario.

Based on these results, a natural gas unit will likely be included in the Companies' least cost plan to reliably meet load requirements beyond 2018. In all scenarios but one with a capacity need in the study period, NGCC capacity is the first new unit installed.

6 Appendix A – Comparison of Levelized Costs from Supply-Side Screening Analysis at Varying Capacity Factors (“CF”)⁴²

Table 34 – No ITC or RECs; 0 CO₂ Prices

Generation Technology Option	Capacity MW	Heat Rate Btu/kWh	Installed Cost \$/kW	Fixed O&M \$/kW-yr	Variable O&M \$/MWh	Fixed Charge Rate %	Service Life Yrs	Levelized Cost (\$/MWh)						
								CF 10%	CF 20%	CF 30%	CF 50%	CF 70%	CF 90%	
Simple Cycle GE LM6000	49					9.24%	30							
Simple Cycle GE LM6000 Add-on	195					9.24%	30							
Simple Cycle GE LMS100	106					9.24%	30							
Simple Cycle GE LMS100 Add-on	211					9.24%	30							
Simple Cycle GE 7EA	87					9.24%	30							
Simple Cycle GE 7EA Add-on	260					9.24%	30							
Simple Cycle GE 7F-5	211					9.24%	30							
Simple Cycle GE 7F-5 Add-on	634					9.24%	30							
Recip Engine - 100 MW	100					9.24%	30							
Recip Engine - 100 MW Add-on	200					9.24%	30							
Microturbine - 1 MWM	1					9.24%	30							
Microturbine - 1 MW Add-on	3					9.24%	30							
Fuel Cell - 10 MW	11					9.24%	30							
Fuel Cell - 10 MW Add-on	34					9.24%	30							
Combined Cycle 1x1 GE 7F-5	315					9.47%	40							
Combined Cycle 1x1 GE 7F-5 - Fired	357					9.47%	40							
Combined Cycle 1x1 MHI GAC	397					9.47%	40							
Combined Cycle 1x1 MHI GAC - Fired	452					9.47%	40							
Combined Cycle 2x1 GE 7F-5	638					9.47%	40							
Combined Cycle 2x1 GE 7F-5 - Fired	719					9.47%	40							
Combined Cycle 2x1 MHI GAC	796					9.47%	40							
Combined Cycle 2x1 MHI GAC - Fired	901					9.47%	40							
Subcritical Pulverized Coal - w/Carbon Capture	425					9.29%	50							
Circulating Fluidized Bed - w/Carbon Capture	425					9.29%	50							
Supercritical Pulverized Coal - 500 MW - w/Carbon Capture	425					9.29%	50							
Supercritical Pulverized Coal - 750 MW - w/Carbon Capture	638					9.29%	50							
2x1 Integrated Gasification CC - w/Carbon Capture	482					9.29%	50							
RDF Stoker Fired	50					9.29%	50							
Wood Stoker Fired	50					9.29%	50							
Landfill Gas IC Engine	5					9.24%	30							
Anaerobic Digester Gas IC Engine	5					9.24%	30							
Co-fired Circulating Fluidized Bed Coal/Biomass (50/50)	50					9.29%	50							
Co-fired Circulating Fluidized Bed Coal/TDF (90/10)	50					9.29%	50							
Pumped Hydro Energy Storage	200					8.06%	20							
Adv. Battery Energy Storage	10					8.06%	20							
CAES	135					8.06%	20							
Wind Energy Conversion	50					8.06%	20							
Solar Photovoltaic	50					8.06%	20							
Solar Thermal	50					8.06%	20							
Hydro Electric	50					9.37%	55							

Table 35 – 10% ITC and RECs; 0 CO₂ Prices

Generation Technology Option	Capacity MW	Heat Rate Btu/kWh	Installed Cost \$/kW	Fixed O&M \$/kW-yr	Variable O&M \$/MWh	Fixed Charge Rate %	Service Life Yrs	Levelized Cost (\$/MWh)						
								CF 10%	CF 20%	CF 30%	CF 50%	CF 70%	CF 90%	
Simple Cycle GE LM6000	49					9.24%	30							
Simple Cycle GE LM6000_Add-on	195					9.24%	30							
Simple Cycle GE LMS100	106					9.24%	30							
Simple Cycle GE LMS100_Add-on	211					9.24%	30							
Simple Cycle GE 7EA	87					9.24%	30							
Simple Cycle GE 7EA_Add-on	260					9.24%	30							
Simple Cycle GE 7F-5	211					9.24%	30							
Simple Cycle GE 7F-5_Add-on	634					9.24%	30							
Recip Engine - 100 MW	100					9.24%	30							
Recip Engine - 100 MW_Add-on	200					9.24%	30							
Microturbine - 1 MWM	1					9.24%	30							
Microturbine - 1 MW_Add-on	3					9.24%	30							
Fuel Cell - 10 MW	11					9.24%	30							
Fuel Cell - 10 MW_Add-on	34					9.24%	30							
Combined Cycle 1x1 GE 7F-5	315					9.47%	40							
Combined Cycle 1x1 GE 7F-5 - Fired	357					9.47%	40							
Combined Cycle 1x1 MHI GAC	397					9.47%	40							
Combined Cycle 1x1 MHI GAC - Fired	452					9.47%	40							
Combined Cycle 2x1 GE 7F-5	638					9.47%	40							
Combined Cycle 2x1 GE 7F-5 - Fired	719					9.47%	40							
Combined Cycle 2x1 MHI GAC	796					9.47%	40							
Combined Cycle 2x1 MHI GAC - Fired	901					9.47%	40							
Subcritical Pulverized Coal - w/Carbon Capture	425					9.29%	50							
Circulating Fluidized Bed - w/Carbon Capture	425					9.29%	50							
Supercritical Pulverized Coal - 500 MW - w/Carbon Capture	425					9.29%	50							
Supercritical Pulverized Coal - 750 MW - w/Carbon Capture	638					9.29%	50							
2x1 Integrated Gasification CC - w/Carbon Capture	482					9.29%	50							
RDF Stoker Fired	50					9.29%	50							
Wood Stoker Fired	50					9.29%	50							
Landfill Gas IC Engine	5					9.24%	30							
Anaerobic Digester Gas IC Engine	5					9.24%	30							
Co-fired Circulating Fluidized Bed_Coal/Biomass (50/50)	50					9.29%	50							
Co-fired Circulating Fluidized Bed_Coal/TDF (90/10)	50					9.29%	50							
Pumped Hydro Energy Storage	200					8.06%	20							
Adv. Battery Energy Storage	10					8.06%	20							
CAES	135					8.06%	20							
Wind Energy Conversion	50					8.06%	20							
Solar Photovoltaic	50					8.06%	20							
Solar Thermal	50					8.06%	20							
Hydro Electric	50					9.37%	55							

⁴² Levelized costs are shown assuming Base capital costs, Base heat rates, and Mid natural gas prices.

7 Appendix B – Electric Sales & Demand Forecast Process

The Sales Analysis & Forecasting group develops the LG&E and KU sales and demand forecasts. These forecasts serve as foundational inputs for the Companies' generation forecast and business plan. This document summarizes the inputs to these forecasts as well as the forecast models.

7.1 Input Data


Table 36 provides a summary of data inputs.

Table 36 – Summary of Forecast Data Inputs

<i>Data</i>	<i>Source</i>	<i>Format</i>
State Macroeconomic and Demographic Drivers (e.g., Employment, Wages, Households, Population)	IHS Global Insight, Kentucky Data Center	Annual or Quarterly by County – History and Forecast
National Macroeconomic Drivers	IHS Global Insight	Annual or Quarterly – History and Forecast
Personal Income	IHS Global Insight	Annual by County
Weather	NOAA	Daily HDD/CDD Data by Weather Station – History
Bill Cycle Schedule	Revenue Accounting	Monthly Collection Dates – History and Forecast
Appliance Saturations/Efficiencies	EIA, 2010 LG&E/KU Residential Customer Survey	Annual – History and Forecast
Structural Variables (e.g., dwelling size, age, and type)	EIA, 2010 LG&E/KU Residential Customer Survey	Annual – History and Forecast
Elasticities of Demand	EIA / Historical Trend	Annual – History
Billed Sales History	CCS Billing System	LG&E, KU and ODP – Monthly by Rate Group
Number of Customers History	CCS Billing System	LG&E, KU and ODP – Monthly by Rate Group

IHS Global Insight produces forecasts of macroeconomic drivers by county. With an understanding of the counties that make up each service territory, this data can be used to create service territory-specific forecasts of macroeconomic drivers. Figure 1 contains a map of the LG&E, KU, and ODP electric service territories.

Figure 1 – LG&E, KU, and ODP Service Territory Map



Two counties make up the majority of the LG&E service territory, while KU serves customers in parts of over 70 counties; ODP’s service territory includes parts of five counties in southwestern Virginia. Service territory-specific macroeconomic forecasts are created by aggregating the applicable county-specific forecasts for the counties in LG&E, KU, and ODP service territories.

7.2 Forecast Models

The Companies’ energy forecast comprises twenty-nine forecast models. All models forecast sales and the number of customers on a monthly basis. These forecasts are discussed in detail in the following sections.

7.2.1 Residential Forecast

The Residential forecast comprises three classes: KU Residential, LG&E Residential, and ODP Residential. The Residential forecast includes all customers on the Residential Service (RS) and Volunteer Fire Department (VFD) rate schedules. Residential sales are forecast for each company as the product of a customer forecast and a use-per-customer forecast.

7.2.1.1 Residential Customer Forecast

The number of residential customers is forecasted by company as a function of the number of forecasted households or forecast population in the service territory. Household and population data by county and Metropolitan Statistical Area (MSA) is available from IHS Global Insight and the Kentucky Data Center.

7.2.1.2 Residential Use-per-Customer Forecast

Average use-per-customer is forecast using a Statistically-Adjusted End-Use (SAE) Model. Such a model combines an econometric model – that relates monthly sales to various explanatory variables such as weather and economic conditions – with traditional end-use modeling. The SAE approach defines energy use as a function of energy used by heating equipment, cooling equipment, and other equipment.

$$\text{Use-per-Customer} = a1 \cdot X_{\text{Heat}} + a2 \cdot X_{\text{Cool}} + a3 \cdot X_{\text{Other}}$$

The heating, cooling and other components (the X variables) are based on various input variables including weather (heating and cooling degree days), appliance saturations, efficiencies, and economic and

demographic variables such as income, population, members per household and electricity prices. Once the historical profile of these explanatory variables has been established, a regression model is specified to identify the statistical relationship between changes in these variables and changes in the dependent variable, use-per-customer.

7.2.2 Commercial Forecast

The Commercial forecast comprises ten rate class models: KU General Service, KU Large Commercial, KU All-Electric Schools, LG&E General Service, LG&E Primary Commercial, LG&E Secondary Commercial, ODP Large Commercial, ODP General Service, ODP Schools and ODP Municipal Pumping. Each of these rate classes is forecast separately on a monthly basis over the forecast period. The period of historical data used in the models varies based on each rate class's history.

7.2.2.1 KU, LG&E, and ODP General Service

The general service forecasts include all customers on the General Service (GS) rate and are comprised of two separate forecasts: a sales forecast and a customer forecast. The former employs a Statistically-Adjusted End-Use model (SAE), which defines energy use as a function of energy used by heating equipment, cooling equipment, and other equipment (see description under Residential, 3.1.2).

The customer forecasts are a function of the Residential customer forecasts which incorporate Household and Population growth since, historically, household growth, population growth, and residential customer growth are highly correlated.

7.2.2.2 KU Large Commercial

The KU Large Commercial forecast includes all customers on the PS Secondary and TOD Secondary rates. Sales to PS Secondary customers are modeled as a function of heating and cooling degree days, Retail and Wholesale Employment indices, and binary variables which account for anomalies in the historical data.

7.2.2.3 KU All-Electric Schools (AES)

The KU All-Electric Schools forecast includes all customers on the All-Electric School rate schedule. KU AES sales are modeled as a function of the number of KU households, weather, and binary variables to account for anomalies in the historical data.

7.2.2.4 LG&E Commercial

The LG&E Commercial forecast includes all customers on the CPS Primary, CPS Secondary, CTOD-Primary, and CTOD-Secondary rate schedules. The Primary and Secondary rates are forecast separately to capture similar energy usage patterns and levels. LG&E Commercial sales are forecast in total as a function of weather, specific economic drivers, the number of customers, and other binary variables to account for anomalies in the historical data.

7.2.2.5 LG&E Special Contracts

The LG&E Special Contracts forecast includes Louisville Water Company and Fort Knox. These customers are forecast individually, based on information and feedback from the customers and major account representatives.

7.2.2.6 ODP Schools

The ODP Schools forecast includes all customers on the School Service (SS) rate schedule. Sales to the ODP schools are modeled as a function of the number of households, weather, and binary variables.

7.2.2.7 ODP Municipal Pumping

The ODP municipal pumping forecast consists of customers on the Water Pumping Service rate schedule. ODP municipal pumping sales are forecast using a trend model based on recent sales.

7.2.3 Lighting Forecast

The Lighting forecast comprises seven rate classes: LG&E LES and TES, KU LES and TES, and unmetered Street Lighting for each company. All Lighting-related energy is forecast using a trend model based on recent sales.

7.2.4 Industrial Forecast

A relatively small number of customers in an industrial rate can make up a significant portion of the total sales for that rate. Furthermore, any expansion or reduction in operations by the larger industrial customers can significantly impact the Companies' load forecast. Therefore, the Companies work directly with the largest industrial customers (Major Accounts) to develop their forecasts. The large individually forecast customers are removed from the historical energy sales data by rate, while the remaining customers are forecast using econometric models described below. The total rate forecast is the combination of the individually forecast customers and the customers forecast using econometric models.

7.2.4.1 KU Industrial Forecast

The KU industrial forecast comprises three forecast models. The forecast models are aggregated by rate codes by voltage level.

7.2.4.1.1 Primary

The PS Primary, TOD Primary, and LTOD Primary rates are forecast together, then allocated into individual rate forecasts using historical sales ratios. The Primary forecast includes all customers that take service at the primary distribution voltage. Sales to Primary customers are modeled as a function of an industry-weighted Industrial Production Index and weather.

7.2.4.1.2 Retail Transmission Service

The RTS forecast includes all retail customers previously on a Transmission-level rate. Since a large component is sales to Mine Power customers, the Wood-Mackenzie forecast of Eastern and Western Kentucky coal production is used as a driver. In recent years, the demand for lower sulfur eastern Kentucky coal has declined while the demand for higher sulfur western Kentucky coal has increased. Therefore, two mining forecasts are developed to more accurately reflect this trend. The two forecasts are combined to form the final KU RTS forecast.

7.2.4.1.3 Fluctuating Load Service

The FLS forecast includes one customer, the North American Stainless Arc Furnace. The FLS forecast is developed based on discussions with the customer.

7.2.4.2 LG&E Industrial Forecast

The LG&E industrial forecast consists of three forecast models: Industrial Primary (Power Service and Time of Day), Industrial Secondary (Power Service and Time of Day), and Retail Transmission Service. Each of these rate classes is forecast separately with specific economic drivers and weather.

7.2.4.2.1 Industrial Primary (Power Service and Time of Day)

The Industrial Primary forecast includes all customers on Industrial Primary rates. Monthly sales are modeled as a function of an industry-weighted Industrial Production Index, number of customers, and weather.

7.2.4.2.2 Industrial Secondary (Power Service and Time of Day)

The Industrial Secondary forecast includes all customers on Industrial secondary rates. Monthly sales are modeled as a function of an industry-weighted Industrial Production Index, number of customers, and weather.

7.2.4.2.3 Retail Transmission Service

The RTS rate consists of both individually forecast major accounts and smaller customers. The major accounts customer forecasts are developed with input from the major account managers and customer input. The remaining smaller customer forecasts are developed using a trend model based on recent sales.

7.2.4.3 ODP Industrial Forecast

The ODP industrial forecast is a combined forecast of PS Primary, TOD Primary, and RTS rates. Industrial sales are forecast as a function of the Eastern Kentucky Wood-Mackenzie index, number of customers, and weather.

7.2.5 KU Municipal Forecast

KU municipal forecasts are provided by various consultants for different cities. These forecasts are reviewed for consistency and compared to historical sales and trends. Questions or concerns regarding the forecasts are sent to the municipal customers and their consultants, if applicable. Any subsequent revisions received from the municipal customers are incorporated into the forecasts.

7.2.6 Billed Demand Forecast

The Billed Demand forecasts are based on historical demand factors, where the demand factor is the billed demand volume divided by the billed sales volume. The historical demand factor is then multiplied by the sales forecast for rates that have billed demand components.

160440034

Exhibit 4

Kentucky Utilities Company and Louisville Gas and Electric Company
PEAK LOAD AND ENERGY FORECAST

Sch1

	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
PJM Load Obligation (if appropriate)																			
1. Utility Peak Load (MW)																			
A. Summer																			
1. Base Forecast				7,356	7,430	7,485	7,234	7,234	7,266	7,300	7,332	7,354	7,370	7,398	7,426	7,457	7,485	7,513	
2. Conservation, Efficiency				201	221	244	246	235	235	235	235	235	235	235	235	235	235	235	
3. Demand-side and Response				207	221	236	244	244	244	244	244	244	244	244	244	244	244	244	
4. Adjusted Load (1)	6,434	6,313	6,392	6,948	6,988	7,004	6,744	6,754	6,786	6,820	6,852	6,874	6,891	6,918	6,946	6,977	7,005	7,033	
5. % Increase in Adjusted Load (from previous year)		-1.9%	1.2%	8.7%	0.6%	0.2%	-3.7%	0.2%	0.5%	0.5%	0.5%	0.3%	0.2%	0.4%	0.4%	0.4%	0.4%	0.4%	
B. Winter (2)																			
1. Base Forecast				6,291	6,348	6,379	6,399	6,133	6,144	6,161	6,180	6,206	6,218	6,238	6,261	6,289	6,318	6,345	
2. Conservation, Efficiency				201	221	244	246	235	235	235	235	235	235	235	235	235	235	235	
3. Demand-side and Response				0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
4. Adjusted Load	5,907	7,114	7,079	6,090	6,127	6,135	6,153	5,897	5,908	5,925	5,944	5,971	5,983	6,003	6,025	6,054	6,082	6,110	
5. % Increase in Adjusted Load (from previous year)		20.4%	-0.5%	-14.0%	0.6%	0.1%	0.3%	-4.2%	0.2%	0.3%	0.3%	0.4%	0.2%	0.3%	0.4%	0.5%	0.5%	0.4%	
2. Energy (GWH)																			
A. Base Forecast				36,361	36,598	36,779	35,769	35,496	35,573	35,667	35,772	35,907	35,975	36,100	36,228	36,385	36,525	36,671	
B. Conservation, Efficiency				927	1,017	1,108	1,002	1,108	1,108	1,108	1,108	1,108	1,108	1,108	1,108	1,108	1,108	1,108	
C. Demand-side and Response				0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
D. Adjusted Load	35,042	35,554	34,846	35,434	35,580	35,670	34,767	34,388	34,464	34,559	34,664	34,799	34,867	34,992	35,119	35,277	35,416	35,563	
E. % Increase in Adjusted Load (from previous year)		1.5%	-2.0%	1.7%	0.4%	0.3%	-2.5%	-1.1%	0.2%	0.3%	0.3%	0.4%	0.2%	0.4%	0.4%	0.4%	0.4%	0.4%	

1944006607

Kentucky Utilities Company and Louisville Gas and Electric Company
PEAK LOAD AND ENERGY FORECAST

Sch1

	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
PJM Load Obligation (if appropriate)																			
1. Utility Peak Load (MW)																			
A. Summer																			
1. High Forecast				7,685	7,763	7,822	7,570	7,570	7,602	7,636	7,668	7,689	7,706	7,734	7,763	7,795	7,825	7,856	
2. Conservation, Efficiency				201	221	244	246	235	235	235	235	235	235	235	235	235	235	235	
3. Demand-side and Response				207	221	236	244	244	244	244	244	244	244	244	244	244	244	244	
4. Adjusted Load (1)	6,434	6,313	6,392	7,277	7,321	7,342	7,080	7,090	7,122	7,156	7,189	7,209	7,227	7,254	7,283	7,315	7,345	7,376	
5. % Increase in Adjusted Load (from previous year)		-1.9%	1.2%	13.8%	0.6%	0.3%	-3.6%	0.1%	0.4%	0.5%	0.5%	0.3%	0.2%	0.4%	0.4%	0.4%	0.4%	0.4%	
B. Winter (2)																			
1. High Forecast				6,593	6,655	6,691	6,727	6,445	6,454	6,470	6,487	6,512	6,523	6,542	6,563	6,591	6,620	6,647	
2. Conservation, Efficiency				201	221	244	246	235	235	235	235	235	235	235	235	235	235	235	
3. Demand-side and Response				0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
4. Adjusted Load	5,907	7,114	7,079	6,392	6,434	6,446	6,482	6,209	6,219	6,235	6,252	6,277	6,288	6,307	6,328	6,356	6,384	6,412	
5. % Increase in Adjusted Load (from previous year)		20.4%	-0.5%	-9.7%	0.7%	0.2%	0.5%	-4.2%	0.2%	0.3%	0.3%	0.4%	0.2%	0.3%	0.3%	0.4%	0.4%	0.4%	
2. Energy (GWH)																			
A. High Forecast				38,067	38,326	38,533	37,547	37,246	37,318	37,408	37,508	37,638	37,703	37,827	37,954	38,115	38,259	38,414	
B. Conservation, Efficiency				927	1,017	1,108	1,002	1,108	1,108	1,108	1,108	1,108	1,108	1,108	1,108	1,108	1,108	1,108	
C. Demand-side and Response				0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
D. Adjusted Load	35,042	35,554	34,846	37,139	37,309	37,424	36,545	36,137	36,209	36,299	36,400	36,530	36,595	36,718	36,846	37,006	37,151	37,306	
E. % Increase in Adjusted Load (from previous year)		1.5%	-2.0%	6.6%	0.5%	0.3%	-2.3%	-1.1%	0.2%	0.2%	0.3%	0.4%	0.2%	0.3%	0.3%	0.4%	0.4%	0.4%	

16007091

Kentucky Utilities Company and Louisville Gas and Electric Company
PEAK LOAD AND ENERGY FORECAST

Sch1

	(ACTUAL)			(PROJECTED)														
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
PJM Load Obligation (if appropriate)																		
1. Utility Peak Load (MW)																		
A. Summer																		
1. Low Forecast				7,027	7,097	7,147	6,898	6,898	6,930	6,963	6,996	7,018	7,035	7,061	7,088	7,118	7,145	7,170
2. Conservation, Efficiency				201	221	244	246	235	235	235	235	235	235	235	235	235	235	235
3. Demand-side and Response				207	221	236	244	244	244	244	244	244	244	244	244	244	244	244
4. Adjusted Load (1)	6,434	6,313	6,392	6,619	6,655	6,667	6,408	6,419	6,450	6,484	6,516	6,538	6,555	6,581	6,609	6,638	6,665	6,690
5. % Increase in Adjusted Load (from previous year)		-1.9%	1.2%	3.6%	0.5%	0.2%	-3.9%	0.2%	0.5%	0.5%	0.5%	0.3%	0.3%	0.4%	0.4%	0.5%	0.4%	0.4%
B. Winter (2)																		
1. Low Forecast				5,989	6,040	6,067	6,070	5,821	5,833	5,852	5,872	5,900	5,913	5,935	5,958	5,987	6,016	6,043
2. Conservation, Efficiency				201	221	244	246	235	235	235	235	235	235	235	235	235	235	235
3. Demand-side and Response				0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
4. Adjusted Load	5,907	7,114	7,079	5,788	5,819	5,823	5,825	5,585	5,597	5,616	5,636	5,664	5,678	5,699	5,723	5,752	5,780	5,807
5. % Increase in Adjusted Load (from previous year)		20.4%	-0.5%	-18.2%	0.5%	0.1%	0.0%	-4.1%	0.2%	0.3%	0.4%	0.5%	0.2%	0.4%	0.4%	0.5%	0.5%	0.5%
2. Energy (GWH)																		
A. Low Forecast				34,656	34,870	35,025	33,991	33,747	33,827	33,926	34,037	34,176	34,247	34,374	34,501	34,656	34,790	34,928
B. Conservation, Efficiency				927	1,017	1,108	1,002	1,108	1,108	1,108	1,108	1,108	1,108	1,108	1,108	1,108	1,108	1,108
C. Demand-side and Response				0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
D. Adjusted Load	35,042	35,554	34,846	33,729	33,852	33,916	32,989	32,638	32,719	32,818	32,928	33,068	33,139	33,265	33,393	33,548	33,682	33,820
E. % Increase in Adjusted Load (from previous year)		1.5%	-2.0%	-3.2%	0.4%	0.2%	-2.7%	-1.1%	0.2%	0.3%	0.3%	0.4%	0.2%	0.4%	0.4%	0.5%	0.4%	0.4%

760077097

Scenario: Mid Gas - Base Load	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
I. System Output (GWh)																			
a. Nuclear	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
b. Coal	33,560	33,002	28,938	28,015	28,490	28,459	28,871	29,984	30,746	30,737	31,863	32,055	32,211	32,061	32,609	32,503	32,628	32,812	
c. Heavy Fuel Oil	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
d. Light Fuel Oil	0	5	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
e. Natural Gas	503	1,201	2,598	6,657	6,297	6,393	5,081	3,588	2,903	3,008	1,988	1,927	1,840	2,114	1,693	1,955	1,974	1,937	
f. Hydro-Conventional	300	344	372	306	334	359	359	359	359	359	359	359	359	359	359	359	359	359	359
g. Hydro-Pumped Storage	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
h. Renewable Resources	0	0	0	11	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15
i. Total Generation (sum of a through h)	34,363	34,552	31,910	34,989	35,136	35,226	34,326	33,946	34,023	34,118	34,223	34,356	34,425	34,549	34,676	34,832	34,977	35,123	
j. Purchased Power																			
1. Firm	854	896	837	443	442	442	439	441	439	439	440	441	440	440	440	441	439	439	
2. Other	2,637	3,453	2,258	1	1	1	1	1	1	1	1	2	2	2	2	2	0	0	
k. Less Pumping Energy	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
l. Less Other Sales (1)	503	481	386	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
m. Total System Firm Energy Requirements	37,352	38,420	34,619	35,434	35,580	35,670	34,767	34,388	34,464	34,559	34,664	34,798	34,868	34,991	35,118	35,276	35,416	35,563	
II. Energy Supplied by Competitive Service Providers	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

Scenario: Mid Gas - High Load	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
I. System Output (GWh)																			
a. Nuclear	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
b. Coal	33,560	33,002	28,938	29,154	29,735	29,638	29,999	30,907	31,329	31,294	32,840	33,080	33,200	33,004	33,639	33,489	33,598	33,794	
c. Heavy Fuel Oil	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
d. Light Fuel Oil	0	5	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
e. Natural Gas	503	1,201	2,598	7,216	6,774	6,960	5,727	4,411	4,066	4,191	2,746	2,634	2,581	2,900	2,392	2,701	2,738	2,697	
f. Hydro-Conventional	300	344	372	306	334	359	359	359	359	359	359	359	359	359	359	359	359	359	359
g. Hydro-Pumped Storage	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
h. Renewable Resources	0	0	0	11	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15
i. Total Generation (sum of a through h)	34,363	34,552	31,910	36,687	36,858	36,972	36,101	35,692	35,769	35,859	35,960	36,089	36,155	36,278	36,406	36,564	36,710	36,865	
j. Purchased Power																			
1. Firm	854	896	837	447	447	447	440	441	439	439	439	440	439	439	439	441	439	439	
2. Other	2,637	3,453	2,258	3	3	3	3	3	1	1	1	1	1	1	1	1	1	1	1
k. Less Pumping Energy	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
l. Less Other Sales (1)	503	481	386	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
m. Total System Firm Energy Requirements	37,352	38,420	34,619	37,137	37,307	37,422	36,544	36,136	36,209	36,299	36,400	36,530	36,595	36,718	36,846	37,006	37,151	37,306	

II. Energy Supplied by Competitive Service Providers NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA

Scenario: Mid Gas - Low Load

	(ACTUAL)			(PROJECTED)																
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030		
I. System Output (GWh)																				
a. Nuclear	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
b. Coal	33,560	33,002	28,938	26,755	27,121	27,176	27,634	28,985	29,732	29,739	30,716	30,912	31,084	30,984	31,439	31,384	31,513	24,778		
c. Heavy Fuel Oil	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
d. Light Fuel Oil	0	5	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
e. Natural Gas	503	1,201	2,598	6,215	5,942	5,925	4,541	2,838	2,173	2,265	1,398	1,341	1,241	1,467	1,140	1,348	1,355	1,326		
f. Hydro-Conventional	300	344	372	306	334	359	359	359	359	359	359	359	359	359	359	359	359	359	338	
g. Hydro-Pumped Storage	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
h. Renewable Resources	0	0	0	11	15	15	15	15	15	15	15	15	15	15	15	15	15	15	2,499	
i. Total Generation (sum of a through h)	34,363	34,552	31,910	33,287	33,411	33,475	32,550	32,197	32,279	32,378	32,488	32,627	32,699	32,825	32,953	33,106	33,242	28,940		
j. Purchased Power																				
1. Firm	854	896	837	441	440	440	439	440	439	439	439	440	439	439	439	440	439	439		
2. Other	2,637	3,453	2,258	1	1	1	0	0	0	1	1	1	1	1	1	1	1	1	1	
k. Less Pumping Energy	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
l. Less Other Sales (1)	503	481	386	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
m. Total System Firm Energy Requirements	37,352	38,420	34,619	33,729	33,852	33,916	32,889	32,638	32,719	32,818	32,928	33,068	33,139	33,265	33,393	33,548	33,682	29,381		

II. Energy Supplied by Competitive Service Providers NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA

Scenario: High Gas - Base Load

	(ACTUAL)			(PROJECTED)																
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030		
I. System Output (GWh)																				
a. Nuclear	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
b. Coal	33,560	33,002	28,938	29,060	30,024	30,878	30,929	31,641	32,098	31,996	32,434	32,324	32,402	32,203	32,698	32,601	32,684	32,822		
c. Heavy Fuel Oil	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
d. Light Fuel Oil	0	5	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
e. Natural Gas	503	1,201	2,598	5,612	4,763	3,974	3,023	1,931	1,551	1,748	1,415	1,658	1,649	1,972	1,604	1,857	1,917	1,925		
f. Hydro-Conventional	300	344	372	306	334	359	359	359	359	359	359	359	359	359	359	359	359	359	359	
g. Hydro-Pumped Storage	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
h. Renewable Resources	0	0	0	11	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	
i. Total Generation (sum of a through h)	34,363	34,552	31,910	34,989	35,136	35,226	34,326	33,946	34,023	34,118	34,223	34,356	34,425	34,549	34,676	34,832	34,975	35,121		
j. Purchased Power																				
1. Firm	854	896	837	443	442	442	439	441	439	439	440	441	440	440	440	441	440	440		
2. Other	2,637	3,453	2,258	1	1	1	1	1	1	1	1	2	2	2	2	2	2	1	2	
k. Less Pumping Energy	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
l. Less Other Sales (1)	503	481	386	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
m. Total System Firm Energy Requirements	37,352	38,420	34,619	35,434	35,580	35,670	34,767	34,388	34,464	34,559	34,664	34,798	34,886	34,991	35,118	35,276	35,418	35,562		

II. Energy Supplied by Competitive Service Providers NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA

Scenario: High Gas - High Load

	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
I. System Output (GWh)																			
a. Nuclear	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
b. Coal	33,560	33,002	28,938	30,157	31,006	31,675	31,830	32,644	33,160	32,893	33,528	33,370	33,417	33,159	33,735	33,589	33,660	33,808	
c. Heavy Fuel Oil	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
d. Light Fuel Oil	0	5	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
e. Natural Gas	503	1,201	2,598	6,213	5,502	4,923	3,898	2,673	2,235	2,493	2,058	2,345	2,384	2,745	2,288	2,601	2,678	2,685	
f. Hydro-Conventional	300	344	372	306	334	359	359	359	359	359	359	359	359	359	359	359	359	359	
g. Hydro-Pumped Storage	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
h. Renewable Resources	0	0	0	11	15	15	15	15	15	15	15	15	15	15	15	15	15	15	
i. Total Generation (sum of a through h)	34,363	34,552	31,910	36,887	36,858	36,972	38,101	35,692	35,769	35,859	35,980	36,089	36,155	36,278	36,408	36,584	36,710	36,865	
j. Purchased Power																			
1. Firm	854	896	837	447	447	447	440	441	439	439	439	440	439	439	439	441	439	439	
2. Other	2,637	3,453	2,258	3	3	3	3	3	1	1	1	1	1	1	1	1	1	1	
k. Less Pumping Energy	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
l. Less Other Sales (1)	503	481	386	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
m. Total System Firm Energy Requirements	37,352	38,420	34,619	37,137	37,307	37,422	36,544	36,136	36,209	36,299	36,400	36,530	36,595	36,718	36,848	37,008	37,151	37,306	
II. Energy Supplied by Competitive Service Providers	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

Scenario: High Gas - Low Load

	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
I. System Output (GWh)																			
a. Nuclear	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
b. Coal	33,560	33,002	28,938	27,859	28,969	29,998	29,922	30,497	30,886	30,837	31,186	31,128	31,227	31,096	31,506	31,460	31,556	31,687	
c. Heavy Fuel Oil	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
d. Light Fuel Oil	0	5	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
e. Natural Gas	503	1,201	2,598	5,111	4,094	3,104	2,253	1,326	1,019	1,167	928	1,125	1,098	1,355	1,072	1,272	1,311	1,319	
f. Hydro-Conventional	300	344	372	306	334	359	359	359	359	359	359	359	359	359	359	359	359	359	
g. Hydro-Pumped Storage	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
h. Renewable Resources	0	0	0	11	15	15	15	15	15	15	15	15	15	15	15	15	15	15	
i. Total Generation (sum of a through h)	34,363	34,552	31,910	33,287	33,411	33,475	32,550	32,197	32,279	32,378	32,488	32,627	32,699	32,825	32,953	33,106	33,242	33,379	
j. Purchased Power																			
1. Firm	854	896	837	441	440	440	439	440	439	439	439	440	439	439	439	440	439	439	
2. Other	2,637	3,453	2,258	1	1	1	0	0	0	1	1	1	1	1	1	1	1	1	
k. Less Pumping Energy	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
l. Less Other Sales (1)	503	481	386	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
m. Total System Firm Energy Requirements	37,352	38,420	34,619	33,729	33,852	33,916	32,989	32,638	32,719	32,818	32,928	33,068	33,139	33,265	33,393	33,548	33,682	33,820	
II. Energy Supplied by Competitive Service Providers	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

Scenario: Low Gas - Base Load

	(ACTUAL)			(PROJECTED)														
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
I. System Output (GWh)																		
a. Nuclear	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
b. Coal	33,560	33,002	28,938	27,194	27,603	28,185	28,079	27,764	27,694	27,633	27,892	28,202	27,993	27,773	28,259	28,854	25,890	23,481
c. Heavy Fuel Oil	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
d. Light Fuel Oil	0	5	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
e. Natural Gas	503	1,201	2,598	7,477	7,183	6,667	5,874	5,808	5,955	6,111	5,956	5,780	6,058	6,402	6,043	5,604	8,713	11,269
f. Hydro-Conventional	300	344	372	306	334	359	359	359	359	359	359	359	359	359	359	359	359	359
g. Hydro-Pumped Storage	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
h. Renewable Resources	0	0	0	11	15	15	15	15	15	15	15	15	15	15	15	15	15	15
i. Total Generation (sum of a through h)	34,363	34,562	31,910	34,988	35,135	35,228	34,326	33,946	34,023	34,118	34,223	34,356	34,425	34,549	34,676	34,832	34,977	35,123
j. Purchased Power																		
1. Firm	854	896	837	444	443	442	439	441	439	439	440	441	440	440	440	441	439	439
2. Other	2,637	3,453	2,258	1	1	1	1	1	1	1	1	2	2	2	2	2	0	0
k. Less Pumping Energy	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
l. Less Other Sales (1)	503	481	388	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
m. Total System Firm Energy Requirements	37,352	38,420	34,619	35,434	35,580	35,670	34,767	34,388	34,464	34,559	34,664	34,798	34,866	34,991	35,118	35,276	35,416	35,563
II. Energy Supplied by Competitive Service Providers	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

Scenario: Low Gas - High Load

	(ACTUAL)			(PROJECTED)														
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
I. System Output (GWh)																		
a. Nuclear	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
b. Coal	33,560	33,002	28,938	28,121	28,646	29,369	29,402	29,119	26,982	25,257	25,708	25,312	24,982	24,769	25,090	26,773	25,292	24,758
c. Heavy Fuel Oil	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
d. Light Fuel Oil	0	5	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
e. Natural Gas	503	1,201	2,598	8,247	7,861	7,229	6,324	6,199	8,413	10,228	9,878	10,403	10,799	11,135	10,942	9,417	11,044	11,733
f. Hydro-Conventional	300	344	372	306	334	359	359	359	359	359	359	359	359	359	359	359	359	359
g. Hydro-Pumped Storage	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
h. Renewable Resources	0	0	0	11	15	15	15	15	15	15	15	15	15	15	15	15	15	15
i. Total Generation (sum of a through h)	34,363	34,562	31,910	36,685	36,857	36,972	36,101	35,692	35,769	35,859	35,960	36,089	36,155	36,278	36,406	36,564	36,710	36,865
j. Purchased Power																		
1. Firm	854	896	837	449	447	447	440	441	439	439	439	440	439	439	439	441	439	439
2. Other	2,637	3,453	2,258	3	3	3	3	3	1	1	1	1	1	1	1	1	1	1
k. Less Pumping Energy	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
l. Less Other Sales (1)	503	481	388	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
m. Total System Firm Energy Requirements	37,352	38,420	34,619	37,137	37,307	37,422	36,544	36,136	36,209	36,299	36,400	36,530	36,595	36,718	36,846	37,006	37,151	37,306
II. Energy Supplied by Competitive Service Providers	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

Scenario: Low Gas - Low Load

	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
I. System Output (GWh)																			
a. Nuclear	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
b. Coal	33,560	33,002	28,938	26,135	26,436	26,873	26,825	26,293	26,205	26,204	26,407	26,770	26,550	26,365	26,808	27,485	27,020	26,897	
c. Heavy Fuel Oil	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
d. Light Fuel Oil	0	5	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
e. Natural Gas	503	1,201	2,598	6,834	6,626	6,228	5,551	5,530	5,701	5,801	5,707	5,482	5,775	6,088	5,770	5,247	5,848	6,108	
f. Hydro-Conventional	300	344	372	306	334	359	359	359	359	359	359	359	359	359	359	359	359	359	359
g. Hydro-Pumped Storage	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
h. Renewable Resources	0	0	0	11	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15
i. Total Generation (sum of a through h)	34,363	34,552	31,910	33,287	33,411	33,475	32,550	32,197	32,279	32,378	32,488	32,627	32,699	32,825	32,953	33,106	33,242	33,379	
j. Purchased Power																			
1. Firm	854	896	837	442	440	440	439	440	439	439	439	440	439	439	439	440	439	439	
2. Other	2,637	3,453	2,258	1	1	1	0	0	0	1	1	1	1	1	1	1	1	1	
k. Less Pumping Energy	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
l. Less Other Sales (1)	503	481	386	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
m. Total System Firm Energy Requirements	37,352	38,420	34,619	33,729	33,852	33,916	32,989	32,638	32,719	32,818	32,928	33,068	33,139	33,265	33,393	33,548	33,682	33,820	
II. Energy Supplied by Competitive Service Providers	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

*In the event that a unit uses multiple fuels for generation (alternate fuel) allocate generation accordingly; ignition and flame stabilization fuels are not considered fuel for generation.
 (1) To include all sales or delivery transactions with other electric utilities. (i.e., firm sales, diversity exchange, etc.)

Kentucky Utilities Company and Louisville Gas and Electric Company
GENERATION

Sch3

Scenario: Mid Gas - Base Load	(ACTUAL)			(PROJECTED)														
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
III. System Output Mix (%)																		
a. Nuclear	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
b. Coal	98%	96%	91%	80%	81%	81%	84%	88%	90%	90%	93%	93%	94%	93%	94%	93%	93%	93%
c. Heavy Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
d. Light Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
e. Natural Gas	1%	3%	8%	19%	18%	18%	15%	11%	9%	9%	6%	6%	5%	6%	5%	6%	6%	6%
f. Hydro-Conventional	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%
g. Hydro-Pumped Storage	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
h. Renewable Resources	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
i. Total Generation (sum of a through h)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
j. Purchased Power																		
1. Firm	2%	2%	2%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%
2. Other	7%	9%	7%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
k. Less Pumping Energy.	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
l. Less Other Sales (1)	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
IV. SYSTEM LOAD FACTOR	62%	64%	62%	58%	58%	58%	59%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%

Scenario: Mid Gas - High Load	(ACTUAL)			(PROJECTED)														
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
III. System Output Mix (%)																		
a. Nuclear	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
b. Coal	98%	96%	91%	79%	81%	80%	83%	87%	88%	87%	91%	92%	92%	91%	92%	92%	92%	92%
c. Heavy Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
d. Light Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
e. Natural Gas	1%	3%	8%	20%	18%	19%	16%	12%	11%	12%	8%	7%	7%	8%	7%	7%	7%	7%
f. Hydro-Conventional	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%
g. Hydro-Pumped Storage	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
h. Renewable Resources	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
i. Total Generation (sum of a through h)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
j. Purchased Power																		
1. Firm	2%	2%	2%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%
2. Other	7%	9%	7%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
k. Less Pumping Energy.	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
l. Less Other Sales (1)	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
IV. SYSTEM LOAD FACTOR	62%	64%	62%	58%	58%	58%	59%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%

Scenario: Mid Gas - Low Load

	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
III. System Output Mix (%)																			
a. Nuclear	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
b. Coal	98%	96%	91%	80%	81%	81%	85%	90%	92%	92%	95%	95%	95%	94%	95%	95%	95%	86%	
c. Heavy Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
d. Light Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
e. Natural Gas	1%	3%	8%	19%	18%	18%	14%	9%	7%	7%	4%	4%	4%	4%	3%	4%	4%	5%	
f. Hydro-Conventional	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	
g. Hydro-Pumped Storage	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
h. Renewable Resources	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	9%	
i. Total Generation (sum of a through h)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
j. Purchased Power																			
1. Firm	2%	2%	2%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	
2. Other	7%	9%	7%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
k. Less Pumping Energy.	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
l. Less Other Sales (1)	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
IV. SYSTEM LOAD FACTOR	62%	64%	62%	58%	58%	58%	59%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	

Scenario: High Gas - Base Load

	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
III. System Output Mix (%)																			
a. Nuclear	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
b. Coal	98%	96%	91%	83%	85%	88%	90%	93%	94%	94%	95%	94%	94%	93%	94%	94%	93%	93%	
c. Heavy Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
d. Light Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
e. Natural Gas	1%	3%	8%	16%	14%	11%	9%	6%	5%	5%	4%	5%	5%	6%	5%	5%	5%	5%	
f. Hydro-Conventional	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	
g. Hydro-Pumped Storage	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
h. Renewable Resources	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
i. Total Generation (sum of a through h)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
j. Purchased Power																			
1. Firm	2%	2%	2%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	
2. Other	7%	9%	7%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
k. Less Pumping Energy.	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
l. Less Other Sales (1)	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
IV. SYSTEM LOAD FACTOR	62%	64%	62%	58%	58%	58%	59%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	

Scenario: High Gas - High Load

	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
III. System Output Mix (%)																			
a. Nuclear	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
b. Coal	98%	96%	91%	82%	84%	86%	88%	91%	93%	92%	93%	92%	92%	91%	93%	92%	92%	92%	92%
c. Heavy Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
d. Light Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
e. Natural Gas	1%	3%	8%	17%	15%	13%	11%	7%	6%	7%	6%	6%	7%	8%	6%	7%	7%	7%	7%
f. Hydro-Conventional	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%
g. Hydro-Pumped Storage	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
h. Renewable Resources	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
i. Total Generation (sum of a through h)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
j. Purchased Power																			
1. Firm	2%	2%	2%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%
2. Other	7%	9%	7%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
k. Less Pumping Energy.	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
l. Less Other Sales (1)	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
IV. SYSTEM LOAD FACTOR	62%	64%	62%	58%	58%	58%	59%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%

Scenario: High Gas - Low Load

	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
III. System Output Mix (%)																			
a. Nuclear	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
b. Coal	98%	96%	91%	84%	87%	90%	92%	95%	96%	95%	96%	95%	95%	95%	96%	95%	95%	95%	95%
c. Heavy Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
d. Light Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
e. Natural Gas	1%	3%	8%	15%	12%	9%	7%	4%	3%	4%	3%	3%	3%	4%	3%	4%	4%	4%	4%
f. Hydro-Conventional	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%
g. Hydro-Pumped Storage	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
h. Renewable Resources	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
i. Total Generation (sum of a through h)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
j. Purchased Power																			
1. Firm	2%	2%	2%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%
2. Other	7%	9%	7%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
k. Less Pumping Energy.	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
l. Less Other Sales (1)	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
IV. SYSTEM LOAD FACTOR	62%	64%	62%	58%	58%	58%	59%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%

Scenario: Low Gas - Base Load

	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
III. System Output Mix (%)																			
a. Nuclear	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
b. Coal	98%	96%	91%	78%	79%	80%	82%	82%	81%	81%	82%	82%	81%	80%	81%	83%	74%	67%	
c. Heavy Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
d. Light Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
e. Natural Gas	1%	3%	8%	21%	20%	19%	17%	17%	18%	18%	17%	17%	18%	19%	17%	16%	25%	32%	
f. Hydro-Conventional	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	
g. Hydro-Pumped Storage	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
h. Renewable Resources	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
i. Total Generation (sum of a through h)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
j. Purchased Power																			
1. Firm	2%	2%	2%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	
2. Other	7%	9%	7%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
k. Less Pumping Energy.	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
l. Less Other Sales (1)	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
IV. SYSTEM LOAD FACTOR	62%	64%	62%	58%	58%	58%	59%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	

Scenario: Low Gas - High Load

	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
III. System Output Mix (%)																			
a. Nuclear	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
b. Coal	98%	96%	91%	77%	78%	79%	81%	82%	75%	70%	71%	70%	69%	68%	69%	73%	69%	67%	
c. Heavy Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
d. Light Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
e. Natural Gas	1%	3%	8%	22%	21%	20%	18%	17%	24%	29%	27%	29%	30%	31%	30%	26%	30%	32%	
f. Hydro-Conventional	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	
g. Hydro-Pumped Storage	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
h. Renewable Resources	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
i. Total Generation (sum of a through h)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
j. Purchased Power																			
1. Firm	2%	2%	2%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	
2. Other	7%	9%	7%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
k. Less Pumping Energy.	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
l. Less Other Sales (1)	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
IV. SYSTEM LOAD FACTOR	62%	64%	62%	58%	58%	58%	59%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	

Scenario: Low Gas - Low Load

	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
III. System Output Mix (%)																			
a. Nuclear	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
b. Coal	98%	96%	91%	79%	79%	80%	82%	82%	81%	81%	81%	82%	81%	80%	81%	83%	81%	81%	
c. Heavy Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
d. Light Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
e. Natural Gas	1%	3%	8%	21%	20%	19%	17%	17%	18%	18%	18%	17%	18%	19%	18%	16%	18%	18%	
f. Hydro-Conventional	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	
g. Hydro-Pumped Storage	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
h. Renewable Resources	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
i. Total Generation (sum of a through h)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
j. Purchased Power																			
1. Firm	2%	2%	2%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	
2. Other	7%	9%	7%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
k. Less Pumping Energy.	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
l. Less Other Sales (1)	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
IV. SYSTEM LOAD FACTOR	62%	64%	62%	58%	58%	58%	59%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	

*In the event that a unit uses multiple fuels for generation (alternate fuel) allocate generation accordingly; ignition and flame stabilization fuels are not considered fuel for generation.

(1) To include all sales or delivery transactions with other electric utilities. (i.e., firm sales, diversity exchange, etc.)

(a-i) percentage of total generation

(j-l) percentage of energy requirements

Kentucky Utilities Company and Louisville Gas and Electric Company
POWER SUPPLY DATA

Sch4

	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
I. Capability (MW)																			
1. Summer																			
a. Installed Net Dependable Capability (1)	7,905	7,911	7,852	7,847	7,851	7,851	7,851	7,851	7,851	7,851	7,851	7,851	7,851	7,851	7,851	7,851	7,851	7,851	
b. Total Positive Interchange commitments (2)	179	179	337	337	337	337	172	172	172	172	172	172	172	172	172	172	172	172	
c. Capability in Cold Reserve/ Reserve Shutdown Status (1)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
d. Demand-side and Response (4)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
e. Total Net Summer Capability (a+b+c+d)	8,084	8,090	8,189	8,184	8,188	8,188	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	
2. Winter (3)																			
a. Installed Net Dependable Capability (1)	8,180	8,187	8,146	8,085	8,080	8,084	8,084	8,084	8,084	8,084	8,084	8,084	8,084	8,084	8,084	8,084	8,084	8,084	
b. Total Positive Interchange commitments (2)	179	179	178	343	343	343	343	178	178	178	178	178	178	178	178	178	178	178	
c. Capability in Cold Reserve/ Reserve Shutdown Status (1)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
d. Demand-side and Response (4)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
e. Total Net Winter Capability (a+b+c+d)	8,359	8,366	8,324	8,428	8,423	8,427	8,427	8,262	8,262	8,262	8,262	8,262	8,262	8,262	8,262	8,262	8,262	8,262	

(1) Provide Net Seasonal Capability
(2) To include firm commitments for the receipt of specified blocks of power (i.e. unit power, limited term, diversity exchange, cogeneration, small power production, etc.)
(3) 2013 data refers to winter of 2012/2013, 2014 data refers to winter of 2013/2014, etc.
(4) all DSM demand response and energy efficiency included in Adjusted Load - see Sch 1

Kentucky Utilities Company and Louisville Gas and Electric Company
 POWER SUPPLY DATA (cont.)

Sch5

	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
II. Load (MW)																			
1. Summer																			
a. Adjusted Summer Peak (1)	6,434	6,313	6,392	6,948	6,988	7,004	6,744	6,754	6,786	6,820	6,852	6,874	6,891	6,918	6,946	6,977	7,005	7,033	
b. Total Negative Power Commitments (2)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
c. Total Summer Peak	6,434	6,313	6,392	6,948	6,988	7,004	6,744	6,754	6,786	6,820	6,852	6,874	6,891	6,918	6,946	6,977	7,005	7,033	
d. Percent Increase in Total Summer Peak		-1.9%	1.2%	8.7%	0.6%	0.2%	-3.7%	0.2%	0.5%	0.5%	0.5%	0.3%	0.2%	0.4%	0.4%	0.4%	0.4%	0.4%	
2. Winter (3)																			
a. Adjusted Winter Peak (1)	5,907	7,114	7,079	6,090	6,127	6,135	6,153	5,897	5,908	5,925	5,944	5,971	5,983	6,003	6,025	6,054	6,082	6,110	
b. Total Negative Power Commitments (2)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
c. Total Winter Peak (4)	5,907	7,114	7,079	6,090	6,127	6,135	6,153	5,897	5,908	5,925	5,944	5,971	5,983	6,003	6,025	6,054	6,082	6,110	
d. Percent Increase in Total Winter Peak		20.4%	-0.5%	-14.0%	0.6%	0.1%	0.3%	-4.2%	0.2%	0.3%	0.3%	0.4%	0.2%	0.3%	0.4%	0.5%	0.5%	0.4%	

(1) Peak after energy efficiency and demand-side programs, see page 1.

(2) To include firm commitments for the delivery of specified blocks of power (i.e. unit power, limited term, diversity exchange. etc.)

Kentucky Utilities Company and Louisville Gas and Electric Company
POWER SUPPLY DATA (continued)

Sch6

Scenario: Base Load	(ACTUAL)			(PROJECTED)														
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
I. Reserve Margin																		
(Including Cold Reserve Capability) (1)																		
1. Summer Reserve Margin																		
a. MW	1,471	1,777	1,797	1,236	1,200	1,183	1,279	1,268	1,236	1,203	1,170	1,149	1,132	1,105	1,077	1,046	1,017	989
b. Percent of Load	23%	28%	28%	18%	17%	17%	19%	19%	18%	18%	17%	17%	16%	16%	16%	15%	15%	14%
2. Winter Reserve Margin (2)																		
a. MW	2,273	1,252	1,245	2,338	2,296	2,292	2,273	2,364	2,353	2,336	2,317	2,291	2,279	2,259	2,236	2,208	2,179	2,152
b. Percent of Load	38%	18%	18%	38%	37%	37%	37%	40%	40%	39%	39%	38%	38%	38%	37%	36%	36%	35%
II. Reserve Margin																		
(Excluding Cold Reserve Capability) (3)																		
1. Summer Reserve Margin																		
a. MW	1,471	1,777	1,797	1,236	1,200	1,183	1,279	1,268	1,236	1,203	1,170	1,149	1,132	1,105	1,077	1,046	1,017	989
b. Percent of Load	23%	28%	28%	18%	17%	17%	19%	19%	18%	18%	17%	17%	16%	16%	16%	15%	15%	14%
2. Winter Reserve Margin (2)																		
a. MW	2,273	1,252	1,245	2,338	2,296	2,292	2,273	2,364	2,353	2,336	2,317	2,291	2,279	2,259	2,236	2,208	2,179	2,152
b. Percent of Load	38%	18%	18%	38%	37%	37%	37%	40%	40%	39%	39%	38%	38%	38%	37%	36%	36%	35%
Scenario: High Load																		
(Including Cold Reserve Capability) (1)																		
1. Summer Reserve Margin																		
a. MW	1,471	1,777	1,797	907	867	846	943	932	900	867	834	813	796	768	739	707	677	647
b. Percent of Load	23%	28%	28%	12%	12%	12%	13%	13%	13%	12%	12%	11%	11%	11%	10%	10%	9%	9%
2. Winter Reserve Margin (2)																		
a. MW	2,273	1,252	1,245	2,036	1,989	1,980	1,945	2,052	2,043	2,027	2,009	1,984	1,974	1,955	1,934	1,906	1,877	1,850
b. Percent of Load	38%	18%	18%	32%	31%	31%	30%	33%	33%	33%	32%	32%	31%	31%	31%	30%	29%	29%
II. Reserve Margin																		
(Excluding Cold Reserve Capability) (3)																		
1. Summer Reserve Margin																		
a. MW	1,471	1,777	1,797	907	867	846	943	932	900	867	834	813	796	768	739	707	677	647

b. Percent of Load	23%	28%	28%	12%	12%	12%	13%	13%	13%	12%	12%	11%	11%	11%	10%	10%	9%	9%
2. Winter Reserve Margin (2)																		
a. MW	2,273	1,252	1,245	2,036	1,989	1,980	1,945	2,052	2,043	2,027	2,009	1,984	1,974	1,955	1,934	1,906	1,877	1,850
b. Percent of Load	38%	18%	18%	32%	31%	31%	30%	33%	33%	33%	32%	32%	31%	31%	31%	30%	29%	29%

Scenario: Low Load	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	

I. Reserve Margin																		
(Including Cold Reserve Capability) (1)																		
1. Summer Reserve Margin																		
a. MW	1,471	1,777	1,797	1,564	1,533	1,521	1,614	1,604	1,572	1,539	1,506	1,484	1,468	1,441	1,414	1,384	1,358	1,332
b. Percent of Load	23%	28%	28%	24%	23%	23%	25%	25%	24%	24%	23%	23%	22%	22%	21%	21%	20%	20%
2. Winter Reserve Margin (2)																		
a. MW	2,273	1,252	1,245	2,639	2,603	2,604	2,602	2,676	2,664	2,645	2,625	2,597	2,584	2,562	2,539	2,510	2,481	2,454
b. Percent of Load	38%	18%	18%	46%	45%	45%	45%	48%	48%	47%	47%	46%	46%	45%	44%	44%	43%	42%

II. Reserve Margin																		
(Excluding Cold Reserve Capability) (3)																		
1. Summer Reserve Margin																		
a. MW	1,471	1,777	1,797	1,564	1,533	1,521	1,614	1,604	1,572	1,539	1,506	1,484	1,468	1,441	1,414	1,384	1,358	1,332
b. Percent of Load	23%	28%	28%	24%	23%	23%	25%	25%	24%	24%	23%	23%	22%	22%	21%	21%	20%	20%
2. Winter Reserve Margin (2)																		
a. MW	2,273	1,252	1,245	2,639	2,603	2,604	2,602	2,676	2,664	2,645	2,625	2,597	2,584	2,562	2,539	2,510	2,481	2,454
b. Percent of Load	38%	18%	18%	46%	45%	45%	45%	48%	48%	47%	47%	46%	46%	45%	44%	44%	43%	42%

Scenario:	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
Mid Gas - Base Load	Not Applicable			2	2	2	2	1	2	2	2	3	3	3	4	5	0	0	
Mid Gas - High Load	Not Applicable			7	7	7	6	5	1	1	1	1	1	1	1	1	1	2	
Mid Gas - Low Load	Not Applicable			0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	
High Gas - Base Load	Not Applicable			2	2	2	2	1	2	2	2	3	3	3	4	5	2	3	
High Gas - High Load	Not Applicable			7	7	7	6	5	1	1	1	1	1	1	1	1	1	2	
High Gas - Low Load	Not Applicable			0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	
Low Gas - Base Load	Not Applicable			2	2	2	2	1	2	2	2	3	3	3	4	5	0	0	
Low Gas - High Load	Not Applicable			7	7	7	6	5	1	1	1	1	1	1	1	1	1	2	
Low Gas - Low Load	Not Applicable			0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	

(1) To be calculated based on Total Net Capability for summer and winter.
(2) 2013 data refers to winter of 2012/2013, 2014 data refers to winter of 2013/2014 etc.
(3) Same as footnote 1 above less capability in cold reserve.

Kentucky Utilities Company and Louisville Gas and Electric Company
Capacity Data

Sch7

	(ACTUAL)			(PROJECTED)														
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
I. Installed Capacity (MW) (1)																		
a. Nuclear	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
b. Coal	5,742	5,736	5,170	5,157	5,157	5,157	5,157	5,157	5,157	5,157	5,157	5,157	5,157	5,157	5,157	5,157	5,157	5,157
c. Heavy Fuel Oil	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
d. Light Fuel Oil	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
e. Natural Gas	2,085	2,085	2,927	2,927	2,927	2,927	2,762	2,762	2,762	2,762	2,762	2,762	2,762	2,762	2,762	2,762	2,762	2,762
f. Hydro-Conventional	86	88	92	92	96	96	96	96	96	96	96	96	96	96	96	96	96	96
g. Pumped Storage	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
h. Renewable	0	0	0	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8
i. Total (sum of a through h)	7,913	7,909	8,189	8,184	8,188	8,188	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023
II. Installed Capacity Mix (%) (2)																		
a. Nuclear	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
b. Coal	73%	73%	63%	63%	63%	63%	64%	64%	64%	64%	64%	64%	64%	64%	64%	64%	64%	64%
c. Heavy Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
d. Light Fuel Oil	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
e. Natural Gas	26%	26%	36%	36%	36%	36%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%
f. Hydro-Conventional	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%
g. Pumped Storage	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
h. Renewable	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
i. Total (sum of a through h)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%

(1) Not dependable installed capability during peak season; unit capabilities to be classified by primary fuel type; for winter peaking utilities-2013 refers to the winter of 2013/2014 etc.

(2) Each item in Section I as a percent of line i (total)

Equivalent Availability Factor (%)

Unit Name	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
Brown 1	91.0	91.1	72.5	85.9	89.4	85.9	89.4	85.9	89.4	77.2	89.4	85.9	89.4	85.9	89.4	85.9	77.2	85.9	
Brown 2	88.8	84.3	95.4	85.9	87.7	77.2	89.4	87.7	89.4	87.7	89.4	77.2	89.4	85.9	89.4	85.9	89.4	85.9	
Brown 3	78.5	80.2	76.3	86.8	90.3	86.8	86.8	77.9	90.3	86.8	90.3	86.8	90.3	77.9	90.3	86.8	90.3	86.8	
Brown 5	98.1	96.8	88.3	79.9	69.0	81.5	81.5	81.5	81.5	81.5	81.5	81.5	81.5	81.5	81.5	81.5	81.5	81.5	
Brown 6	97.3	94.6	97.7	91.4	91.4	78.8	91.4	91.4	91.4	93.2	93.2	93.2	93.2	93.2	93.2	93.2	93.2	93.2	
Brown 7	97.4	95.0	98.2	91.4	91.4	91.4	78.8	91.4	91.4	93.2	93.2	93.2	93.2	93.2	93.2	93.2	93.2	93.2	
Brown 8	95.8	96.3	91.4	92.2	88.6	92.2	92.2	92.2	78.0	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	
Brown 9	81.9	93.9	91.5	92.2	88.6	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	
Brown 10	99.1	94.7	80.1	92.2	88.6	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	
Brown 11	82.1	95.8	91.4	92.2	88.6	92.2	78.0	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	92.2	
Cane Run 4	72.9	86.1	77.7	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
Cane Run 5	86.6	87.7	79.4	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
Cane Run 6	81.9	71.3	57.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
Cane Run 7	NA	NA	85.8	90.4	91.3	91.3	87.7	87.7	91.3	91.3	91.3	85.9	91.3	95.0	91.3	80.4	91.3	95.0	
Cane Run 11	98.9	99.6	93.3	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	
Ghent 1	90.1	89.6	74.6	86.8	86.8	83.2	86.8	86.8	86.8	70.8	86.8	86.8	88.6	86.8	88.6	86.8	77.9	88.6	
Ghent 2	94.4	92.9	78.4	86.8	85.0	86.8	76.2	86.8	86.8	86.8	86.8	86.8	86.8	77.9	88.6	86.8	88.6	86.8	
Ghent 3	86.6	80.5	84.7	85.0	86.8	77.9	83.2	86.8	86.8	86.8	86.8	85.0	77.9	86.8	88.6	86.8	88.6	86.8	
Ghent 4	84.7	78.1	94.6	85.0	86.8	85.0	86.8	86.8	77.9	86.8	86.8	85.0	86.8	88.6	86.8	77.9	88.6	86.8	
G. River 3	96.6	91.2	88.1	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
G. River 4	86.5	88.3	84.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
Haefling 1-2 (2)	97.6	98.2	99.8	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	
Mill Creek 1	70.4	90.1	77.3	90.3	85.0	90.3	85.0	90.3	77.9	90.3	85.0	90.3	85.0	90.3	85.0	90.3	77.9	90.3	
Mill Creek 2	88.5	80.7	76.7	83.2	90.3	85.0	90.3	77.9	90.3	85.0	90.3	85.0	90.3	85.0	90.3	77.9	90.3	85.0	
Mill Creek 3	75.4	91.8	85.4	76.2	83.2	90.3	77.9	90.3	85.0	90.3	85.0	90.3	85.0	90.3	77.9	90.3	85.0	90.3	
Mill Creek 4	80.5	66.3	89.4	83.2	90.3	85.0	90.3	85.0	90.3	77.9	90.3	85.0	90.3	85.0	90.3	85.0	90.3	77.9	
Paddy's Run 11&12 (3)	94.7	96.6	76.8	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	
Paddy's Run 13	83.3	90.6	84.7	85.9	85.9	85.9	85.9	57.3	52.2	85.9	85.9	85.9	85.9	87.6	87.6	87.6	87.6	87.6	
Trimble 1 75%	85.6	93.2	77.3	89.4	76.9	89.4	84.1	89.4	84.1	89.4	84.1	89.4	76.9	89.4	84.1	89.4	84.1	89.4	
Trimble 2 75%	66.4	60.1	85.4	82.3	85.8	75.3	82.3	82.3	85.8	82.3	85.8	82.3	82.3	75.3	82.3	82.3	82.3	82.3	
Trimble 5	97.3	98.6	92.9	95.5	80.8	95.5	95.5	95.5	77.1	95.5	95.5	95.5	95.5	95.5	95.5	95.5	95.5	95.5	
Trimble 6	98.1	97.5	93.3	80.8	95.5	95.5	95.5	77.1	95.5	95.5	95.5	95.5	95.5	95.5	95.5	95.5	95.5	95.5	
Trimble 7	98.0	97.2	94.2	95.5	80.8	95.5	95.5	95.5	77.1	95.5	95.5	95.5	95.5	95.5	95.5	95.5	95.5	95.5	
Trimble 8	93.0	96.6	96.4	95.5	95.5	95.5	95.5	95.5	80.8	95.5	95.5	95.5	77.1	95.5	95.5	95.5	95.5	95.5	
Trimble 9	97.8	95.7	95.8	95.5	95.5	80.8	95.5	95.5	95.5	77.1	95.5	95.5	95.5	95.5	95.5	95.5	95.5	95.5	
Trimble 10	82.4	97.8	97.3	95.5	95.5	95.5	95.5	95.5	95.5	95.5	95.5	80.8	95.5	95.5	95.5	95.5	95.5	95.5	
Zorn 1	99.7	85.0	81.3	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	
Brown Solar	NA	NA	NA	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	

(1) Combustion turbines to be reported as a composite facility.

(2) Haefling 1-2 actuals include Haefling 3

(3) Paddy's Run 11 & 12 each have a 50% Projected EAF.

UNIT PERFORMANCE DATA (1)

Net Capacity Factor (%)

Unit Name	(ACTUAL)			(PROJECTED)														
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
Scenario: Mid Gas - Base Load																		
E.W. Brown 1	40.8	40.0	22.3	15.4	20.9	21.5	21.6	16.8	21.1	21.6	32.9	37.7	45.9	42.3	42.8	42.9	37.5	43.2
E.W. Brown 2	60.2	51.8	42.7	15.3	18.3	17.5	19.9	16.3	21.3	26.4	31.9	32.0	41.4	40.6	40.5	40.5	44.3	41.8
E.W. Brown 3	44.5	42.1	33.5	6.5	10.5	12.2	11.2	8.1	12.0	14.4	17.3	22.1	27.8	24.2	29.0	29.3	32.7	31.7
E.W. Brown 5	0.3	3.5	10.8	0.8	0.7	1.0	0.5	0.4	0.5	0.5	0.5	0.5	0.5	0.6	0.6	0.7	0.2	0.2
E.W. Brown 6	3.9	13.7	16.2	26.9	1.7	2.0	1.1	1.0	1.0	1.1	1.0	1.1	1.1	1.3	1.2	1.5	0.4	0.3
E.W. Brown 7	3.4	16.3	12.5	30.5	2.3	2.7	1.4	1.4	1.4	1.6	1.3	1.7	1.8	1.8	1.7	2.4	0.6	0.5
E.W. Brown 8	0.3	2.2	7.3	0.5	0.5	0.8	0.4	0.4	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.6	0.1	0.1
E.W. Brown 9	0.5	1.6	8.4	0.9	0.8	0.7	0.3	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.4	0.5	0.1	0.1
E.W. Brown 10	0.1	1.8	7.8	0.7	0.6	0.5	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.3	0.3	0.4	0.1	0.1
E.W. Brown 11	0.1	2.2	5.4	0.4	0.4	0.7	0.3	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.5	0.5	0.1	0.1
Cane Run 4	51.3	56.7	40.1	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 5	58.7	66.1	45.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 6	47.3	36.2	25.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 7	NA	NA	19.7	94.1	95.1	93.4	77.3	52.6	42.6	42.6	26.9	24.0	23.1	26.6	20.6	22.5	24.0	23.0
Cane Run 11	0.1	-0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.0
Ghent 1	79.5	77.5	60.9	85.0	72.5	70.7	78.3	80.7	82.3	67.8	82.3	82.6	84.7	83.6	84.9	83.5	74.8	85.5
Ghent 2	81.0	77.7	58.8	79.8	71.1	75.4	64.0	74.3	76.3	78.0	77.8	78.8	79.6	71.1	80.9	80.1	81.5	79.8
Ghent 3	76.9	71.7	71.1	51.1	47.1	46.5	52.0	56.0	65.6	67.8	66.0	64.6	62.3	70.5	70.4	70.6	72.4	70.7
Ghent 4	73.3	70.9	80.3	68.0	61.4	63.0	68.2	72.7	69.8	80.3	78.3	77.1	79.5	81.9	79.6	72.3	82.5	80.8
Green River 3	52.2	59.3	49.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Green River 4	80.1	82.8	71.3	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Haefling 1-2 (2)	0.2	0.4	1.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.0	0.0
Mill Creek 1	55.3	74.0	56.3	81.1	79.0	82.3	79.2	89.2	77.1	89.4	84.0	89.7	84.2	89.6	84.1	89.6	77.0	89.7
Mill Creek 2	72.0	66.6	55.6	73.5	86.1	78.3	87.8	77.1	89.1	84.2	89.3	84.1	89.3	84.2	89.2	77.1	89.1	84.2
Mill Creek 3	64.6	78.0	63.6	62.6	78.2	79.9	72.2	88.0	83.7	88.3	83.2	87.9	82.9	88.2	76.3	88.3	83.1	88.0
Mill Creek 4	64.8	55.6	67.8	68.3	88.1	81.6	89.7	85.3	90.7	78.1	90.7	85.3	90.7	85.3	90.7	85.4	90.7	78.2
Paddy's Run 11&12	-0.1	0.2	-0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.0
Paddy's Run 13	2.3	8.1	14.1	7.0	18.7	19.0	14.2	8.6	4.9	8.3	6.5	7.9	7.6	8.6	7.1	9.1	4.9	2.6
Trimble County 1 (75%)	77.6	80.0	64.4	73.0	68.6	87.0	73.5	73.8	71.0	76.4	72.8	77.7	67.6	78.8	73.9	78.9	74.8	78.9
Trimble County 2 (75%)	65	59	84.2	82.9	86.4	75.7	82.8	82.9	86.4	82.8	86.4	82.9	82.8	75.7	82.8	82.9	82.8	82.8
Trimble County 5	4.8	9.5	14.5	10.7	10.8	17.1	11.7	10.8	7.2	10.3	7.6	8.9	8.1	9.3	7.8	10.1	5.4	3.0
Trimble County 6	6.5	10.4	13.8	7.8	11.7	13.2	8.5	6.7	7.3	7.6	5.6	6.8	6.3	7.2	6.0	7.8	3.8	2.2
Trimble County 7	5.2	7.7	16.4	6.2	8.0	10.1	6.2	6.1	5.0	5.6	4.2	5.2	4.8	5.5	4.7	6.0	2.8	1.7
Trimble County 8	2.0	2.9	5.0	4.6	6.5	7.5	4.4	4.3	4.1	3.4	3.2	3.8	3.6	4.2	3.7	4.7	2.0	1.3
Trimble County 9	6.2	9.0	17.5	3.4	4.7	5.3	3.1	3.1	2.8	2.9	2.4	2.8	2.8	3.1	2.8	3.5	1.3	0.9
Trimble County 10	1.9	3.7	4.6	2.5	3.4	4.0	2.2	2.1	2.0	2.3	1.7	2.0	2.1	2.3	2.1	2.7	0.9	0.6
Zorn 1	0.2	0.1	0.9	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.0
Dix Dam 1-3	50.7	27.5	35.5	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7
Ohio Falls 1-8	40.9	57.5	52.1	44.6	46.9	51.3	51.3	51.2	51.3	51.3	51.3	51.2	51.3	51.3	51.3	51.2	51.3	51.3
Brown Solar	NA	NA	NA	18.8	17.4	17.4	17.4	17.3	17.4	17.4	17.4	17.3	17.4	17.4	17.4	17.3	17.4	17.4
2x1 NGCC	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	4.9	7.1

Scenario Mid Gas - High Load

E.W. Brown 1	40.8	40.0	22.3	20.7	27.5	28.0	29.0	23.2	23.8	26.8	41.3	46.0	54.9	50.7	51.7	51.3	44.9	51.5
E.W. Brown 2	60.2	51.8	42.7	19.7	23.5	22.6	26.0	21.8	24.1	30.5	38.3	38.6	49.0	48.0	48.3	48.0	52.1	49.3
E.W. Brown 3	44.5	42.1	33.5	9.1	14.0	15.9	15.4	11.5	10.6	12.0	22.6	29.0	35.3	30.6	36.8	36.9	40.4	39.2
E.W. Brown 5	0.3	3.5	10.8	1.5	1.3	1.9	1.1	0.9	0.3	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.3
E.W. Brown 6	3.9	13.7	16.2	35.5	3.1	3.5	2.1	2.0	0.7	0.5	0.4	0.5	0.5	0.6	0.6	0.7	0.6	0.7
E.W. Brown 7	3.4	16.3	12.5	38.9	4.0	4.7	2.5	2.5	0.9	0.6	0.6	0.7	0.7	0.7	0.7	1.0	0.8	0.9
E.W. Brown 8	0.3	2.2	7.3	1.0	0.9	1.5	0.8	0.7	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.3
E.W. Brown 9	0.5	1.6	8.4	1.7	1.4	1.4	0.7	0.6	0.2	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2
E.W. Brown 10	0.1	1.8	7.8	1.3	1.1	1.1	0.5	0.5	0.2	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2
E.W. Brown 11	0.1	2.2	5.4	0.8	0.8	1.3	0.7	0.6	0.2	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3
Cane Run 4	51.3	56.7	40.1	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 5	58.7	66.1	45.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 6	47.3	36.2	25.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 7	NA	NA	19.7	94.1	95.1	94.1	81.0	60.8	51.9	51.3	34.7	30.8	30.8	34.2	27.5	29.1	31.3	30.3
Cane Run 11	0.1	-0.1	0.2	0.2	0.2	0.2	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1
Ghent 1	79.5	77.5	60.9	85.5	75.9	74.2	80.7	82.3	83.6	68.7	83.7	83.9	85.9	84.7	86.0	84.7	75.8	86.5
Ghent 2	81.0	77.7	58.8	80.8	72.9	76.9	65.9	75.9	78.0	79.5	79.6	80.4	81.2	72.5	82.5	81.5	83.0	81.2
Ghent 3	76.9	71.7	71.1	58.5	55.2	53.5	59.0	62.1	71.3	73.3	72.1	70.7	67.2	75.7	76.0	76.1	77.6	75.9
Ghent 4	73.3	70.9	80.3	72.9	68.5	68.8	73.2	77.2	72.6	82.8	81.5	80.1	82.3	84.6	82.4	74.4	85.0	83.4
Green River 3	52.2	59.3	49.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Green River 4	80.1	82.8	71.3	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Haefling 1-2 (2)	0.2	0.4	1.1	0.3	0.3	0.3	0.2	0.2	0.1	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Mill Creek 1	55.3	74.0	56.3	82.1	79.9	83.5	80.2	89.4	77.3	89.6	84.2	89.8	84.4	89.7	84.3	89.7	77.1	89.8
Mill Creek 2	72.0	66.6	55.6	74.9	86.9	79.3	88.3	77.1	89.3	84.2	89.4	84.2	89.4	84.2	89.3	77.2	89.3	84.2
Mill Creek 3	64.6	78.0	63.6	65.1	78.9	81.4	73.2	88.6	84.1	88.9	83.8	88.6	83.5	88.8	76.8	88.9	83.7	88.7
Mill Creek 4	64.8	55.6	67.8	71.9	88.9	82.7	90.0	85.3	90.7	78.1	90.7	85.3	90.7	85.3	90.7	85.4	90.7	78.2
Paddy's Run 11&12	-0.1	0.2	-0.1	0.2	0.2	0.2	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1
Paddy's Run 13	2.3	8.1	14.1	11.1	25.7	25.3	20.8	12.1	2.5	3.6	3.2	3.6	3.5	4.0	3.4	4.4	4.0	4.0
Trimble County 1 (75%)	77.6	80.0	64.4	74.7	69.6	87.4	75.1	75.6	72.9	78.5	74.9	79.9	69.5	80.9	75.9	81.0	76.7	81.0
Trimble County 2 (75%)	65.3	58.8	84.2	82.9	86.4	75.7	82.8	82.9	86.4	82.8	86.4	82.9	82.8	75.7	82.8	82.9	82.8	82.8
Trimble County 5	4.8	9.5	14.5	15.5	15.5	23.3	17.7	16.1	4.8	4.4	3.6	4.4	4.1	4.6	4.2	5.1	4.7	4.8
Trimble County 6	6.5	10.4	13.8	11.4	16.9	18.7	13.3	10.3	6.6	3.2	2.7	3.0	2.9	3.3	3.0	3.7	3.5	3.6
Trimble County 7	5.2	7.7	16.4	9.5	11.9	14.7	10.0	9.8	4.7	2.3	1.9	2.3	2.3	2.6	2.4	2.9	2.7	2.8
Trimble County 8	2.0	2.9	5.0	7.3	10.2	11.4	7.4	7.2	3.5	1.6	1.5	1.8	1.8	2.0	1.9	2.3	2.2	2.3
Trimble County 9	6.2	9.0	17.5	5.4	7.6	8.4	5.4	5.3	2.3	1.2	1.1	1.2	1.2	1.3	1.3	1.6	1.5	1.6
Trimble County 10	1.9	3.7	4.6	4.1	5.6	6.6	3.9	3.8	1.6	0.9	0.8	0.9	0.9	1.0	1.0	1.2	1.1	1.2
Zorn 1	0.2	0.1	0.9	0.2	0.2	0.2	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1
Dix Dam 1-3	50.7	27.5	35.5	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7
Ohio Falls 1-8	40.9	57.5	52.1	44.6	46.9	51.3	51.3	51.2	51.3	51.3	51.3	51.2	51.3	51.3	51.3	51.2	51.3	51.3
Brown Solar	NA	NA	NA	18.8	17.4	17.4	17.4	17.3	17.4	17.4	17.4	17.3	17.4	17.4	17.4	17.3	17.4	17.4
2x1 NGCC	NA	NA	NA	NA	NA	NA	NA	NA	11.7	16.2	8.8	9.8	9.2	10.7	9.0	11.4	10.5	10.5

Scenario Mid Gas - Low Load

E.W. Brown 1	40.8	40.0	22.3	11.0	15.1	15.7	15.8	11.5	14.8	15.6	24.7	29.6	36.5	33.6	33.7	34.3	29.9	34.6
E.W. Brown 2	60.2	51.8	42.7	11.4	13.6	13.0	14.4	11.4	15.7	20.1	25.1	25.5	33.6	33.1	32.6	33.0	36.3	34.1
E.W. Brown 3	44.5	42.1	33.5	4.4	7.5	8.9	7.7	5.5	8.0	9.9	12.1	16.5	21.2	18.5	22.0	22.5	25.3	24.5
E.W. Brown 5	0.3	3.5	10.8	0.4	0.4	0.5	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.4	0.3	0.4
E.W. Brown 6	3.9	13.7	16.2	19.2	0.9	1.0	0.5	0.5	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.8	0.7	0.8
E.W. Brown 7	3.4	16.3	12.5	22.7	1.2	1.5	0.7	0.7	0.7	0.8	0.6	0.9	1.0	0.9	0.9	1.3	1.0	1.1
E.W. Brown 8	0.3	2.2	7.3	0.2	0.2	0.4	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.3
E.W. Brown 9	0.5	1.6	8.4	0.4	0.4	0.3	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2
E.W. Brown 10	0.1	1.8	7.8	0.3	0.3	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2
E.W. Brown 11	0.1	2.2	5.4	0.2	0.2	0.3	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3
Cane Run 4	51.3	56.7	40.1	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 5	58.7	66.1	45.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 6	47.3	36.2	25.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 7	NA	NA	19.7	94.1	95.1	92.2	73.1	43.8	33.4	33.9	19.9	17.7	16.3	19.5	14.6	16.5	17.4	16.7
Cane Run 11	0.1	-0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1
Ghent 1	79.5	77.5	60.9	84.3	67.9	66.1	75.1	78.6	80.3	66.4	80.3	80.6	82.9	82.0	83.3	81.8	73.5	84.0
Ghent 2	81.0	77.7	58.8	78.6	69.0	73.7	62.0	72.7	74.4	76.4	75.8	76.9	77.6	69.6	79.0	78.5	79.8	78.1
Ghent 3	76.9	71.7	71.1	43.3	38.8	39.2	44.0	49.1	58.5	60.7	58.4	57.3	56.0	63.9	63.2	63.7	65.8	64.0
Ghent 4	73.3	70.9	80.3	61.7	52.8	55.9	61.8	66.8	65.8	76.5	73.8	72.7	75.5	77.9	75.6	68.9	78.9	76.9
Green River 3	52.2	59.3	49.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Green River 4	80.1	82.8	71.3	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Haefling 1-2 (2)	0.2	0.4	1.1	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Mill Creek 1	55.3	74.0	56.3	80.0	78.1	81.1	78.2	88.9	77.0	89.2	83.8	89.6	84.0	89.4	83.9	89.5	76.8	89.6
Mill Creek 2	72.0	66.6	55.6	72.0	85.2	77.2	87.2	77.0	88.9	84.0	89.2	84.1	89.2	84.1	89.1	77.0	89.0	84.1
Mill Creek 3	64.6	78.0	63.6	59.8	77.4	78.5	71.3	87.4	83.0	87.5	82.5	87.0	82.1	87.4	75.7	87.5	82.4	87.2
Mill Creek 4	64.8	55.6	67.8	63.6	87.0	80.1	89.3	85.3	90.7	78.1	90.7	85.3	90.7	85.3	90.7	85.4	90.6	78.2
Paddy's Run 11&12	-0.1	0.2	-0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1
Paddy's Run 13	2.3	8.1	14.1	4.1	12.9	13.6	9.1	5.8	3.2	5.4	4.2	5.2	4.9	5.7	4.6	6.1	5.5	5.6
Trimble County 1 (75%)	77.6	80.0	64.4	71.3	67.5	86.5	71.8	72.1	68.9	74.2	70.6	75.4	65.5	76.5	71.6	76.5	72.6	76.5
Trimble County 2 (75%)	65.3	58.8	84.2	82.9	86.4	75.7	82.8	82.9	86.4	82.8	86.4	82.9	82.8	75.7	82.8	82.9	82.8	82.8
Trimble County 5	4.8	9.5	14.5	7.0	7.1	11.8	7.2	6.7	4.5	6.5	4.7	5.7	5.1	5.9	5.0	6.5	6.0	5.9
Trimble County 6	6.5	10.4	13.8	4.9	7.5	8.8	5.1	4.1	4.3	4.6	3.4	4.2	3.8	4.4	3.7	4.9	4.4	4.4
Trimble County 7	5.2	7.7	16.4	3.8	5.0	6.4	3.5	3.5	2.9	3.3	2.4	3.1	2.8	3.2	2.8	3.7	3.4	3.6
Trimble County 8	2.0	2.9	5.0	2.7	3.9	4.6	2.4	2.4	2.3	1.9	1.8	2.2	2.1	2.4	2.1	2.7	2.5	2.6
Trimble County 9	6.2	9.0	17.5	1.9	2.7	3.1	1.6	1.6	1.5	1.6	1.3	1.6	1.5	1.7	1.6	2.0	1.8	1.9
Trimble County 10	1.9	3.7	4.6	1.4	1.8	2.2	1.1	1.1	1.0	1.2	0.9	1.1	1.1	1.3	1.2	1.5	1.4	1.5
Zorn 1	0.2	0.1	0.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1
Dix Dam 1-3	50.7	27.5	35.5	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7
Ohio Falls 1-8	40.9	57.5	52.1	44.6	46.9	51.3	51.3	51.2	51.3	51.3	51.3	51.2	51.3	51.3	51.3	51.2	51.3	51.3
Brown Solar	NA	NA	NA	18.8	17.4	17.4	17.4	17.3	17.4	17.4	17.4	17.3	17.4	17.4	17.4	17.3	17.4	17.4

Scenario High Gas - Base Load

E.W. Brown 1	40.8	40.0	22.3	22.7	23.0	23.5	26.0	33.8	42.3	38.0	39.8	39.4	45.9	42.3	42.8	42.9	37.5	43.2
E.W. Brown 2	60.2	51.8	42.7	19.6	20.0	18.2	26.0	32.5	38.4	42.3	38.3	33.8	43.4	42.7	41.5	41.8	44.8	42.0
E.W. Brown 3	44.5	42.1	33.5	12.8	13.5	14.6	14.4	17.1	28.3	32.4	28.0	28.0	32.3	27.3	31.1	31.5	34.0	31.9
E.W. Brown 5	0.3	3.5	10.8	0.7	0.6	0.8	0.5	0.4	0.5	0.5	0.5	0.5	0.5	0.6	0.6	0.7	0.5	0.5
E.W. Brown 6	3.9	13.7	16.2	13.9	1.6	1.8	1.0	0.9	1.0	1.1	1.0	1.1	1.1	1.3	1.2	1.5	1.4	1.5
E.W. Brown 7	3.4	16.3	12.5	15.6	2.0	2.5	1.3	1.3	1.3	1.6	1.3	1.7	1.8	1.7	1.7	2.4	1.9	1.9
E.W. Brown 8	0.3	2.2	7.3	0.5	0.4	0.6	0.4	0.4	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.6	0.4	0.5
E.W. Brown 9	0.5	1.6	8.4	0.7	0.6	0.6	0.3	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.4	0.5	0.4	0.4
E.W. Brown 10	0.1	1.8	7.8	0.6	0.5	0.5	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.3	0.3	0.4	0.3	0.3
E.W. Brown 11	0.1	2.2	5.4	0.4	0.4	0.5	0.3	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.5	0.5	0.4	0.4
Cane Run 4	51.3	56.7	40.1	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 5	58.7	66.1	45.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 6	47.3	36.2	25.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 7	NA	NA	19.7	84.1	71.1	52.8	43.1	25.1	19.3	21.0	17.0	19.4	19.7	24.1	19.0	20.8	22.9	22.9
Cane Run 11	0.1	-0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Ghent 1	79.5	77.5	60.9	85.1	77.5	80.2	83.9	81.8	82.6	67.9	82.3	82.6	84.7	83.6	84.9	83.5	74.8	85.5
Ghent 2	81.0	77.7	58.8	80.6	74.1	78.4	67.6	77.5	78.3	79.6	78.1	78.9	79.6	71.1	80.9	80.1	81.5	79.8
Ghent 3	76.9	71.7	71.1	57.3	59.3	65.4	67.1	66.3	68.8	69.5	66.1	64.9	62.4	70.6	70.4	70.7	72.5	70.7
Ghent 4	73.3	70.9	80.3	70.2	70.5	79.1	80.1	76.9	69.8	80.3	78.3	77.1	79.5	81.9	79.6	72.3	82.5	80.8
Green River 3	52.2	59.3	49.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Green River 4	80.1	82.8	71.3	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Haefling 1-2 (2)	0.2	0.4	1.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.1
Mill Creek 1	55.3	74.0	56.3	81.6	80.1	83.9	81.7	89.6	77.1	89.6	84.0	89.7	84.2	89.6	84.1	89.6	77.0	89.7
Mill Creek 2	72.0	66.6	55.6	74.1	87.2	79.6	88.9	77.1	89.1	84.2	89.3	84.1	89.3	84.2	89.2	77.1	89.1	84.2
Mill Creek 3	64.6	78.0	63.6	63.3	79.0	82.9	74.4	88.5	83.7	88.4	83.2	87.9	82.9	88.2	76.3	88.2	83.1	88.0
Mill Creek 4	64.8	55.6	67.8	72.6	89.5	84.4	90.6	85.3	90.7	78.1	90.7	85.3	90.7	85.3	90.7	85.4	90.7	78.2
Paddy's Run 11&12	-0.1	0.2	-0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Paddy's Run 13	2.3	8.1	14.1	5.4	14.1	14.0	8.3	6.2	4.8	8.3	6.6	7.9	7.8	8.7	7.2	9.4	8.5	8.3
Trimble County 1 (75%)	77.6	80.0	64.4	75.0	69.2	87.9	76.5	77.4	73.7	78.9	73.2	77.9	67.5	78.7	73.8	78.8	74.7	78.9
Trimble County 2 (75%)	65.3	58.8	84.2	82.9	86.4	75.7	82.8	82.9	86.4	82.8	86.4	82.9	82.8	75.7	82.8	82.9	82.8	82.8
Trimble County 5	4.8	9.5	14.5	8.7	9.5	15.7	10.4	8.9	6.1	9.0	6.9	8.4	7.9	9.3	7.7	9.9	9.1	9.0
Trimble County 6	6.5	10.4	13.8	6.2	9.1	12.2	7.4	5.8	6.4	6.9	5.3	6.6	6.1	7.1	6.0	7.7	7.1	7.0
Trimble County 7	5.2	7.7	16.4	5.0	6.2	9.4	5.5	5.0	4.6	5.1	4.0	5.2	4.8	5.7	4.9	6.2	5.7	5.8
Trimble County 8	2.0	2.9	5.0	3.6	5.3	7.0	4.0	3.7	3.7	3.1	3.1	3.8	3.5	4.2	3.7	4.6	4.2	4.3
Trimble County 9	6.2	9.0	17.5	2.6	3.8	4.9	2.8	2.6	2.7	2.8	2.3	2.8	2.8	3.1	2.8	3.5	3.2	3.3
Trimble County 10	1.9	3.7	4.6	1.9	2.7	3.7	2.0	1.9	1.9	2.3	1.7	2.0	2.1	2.3	2.1	2.7	2.5	2.6
Zorn 1	0.2	0.1	0.9	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Dix Dam 1-3	50.7	27.5	35.5	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7
Ohio Falls 1-8	40.9	57.5	52.1	44.6	46.9	51.3	51.3	51.2	51.3	51.3	51.3	51.2	51.3	51.3	51.3	51.2	51.3	51.3
Brown Solar	NA	NA	NA	18.8	17.4	17.4	17.4	17.3	17.4	17.4	17.4	17.3	17.4	17.4	17.4	17.3	17.4	17.4
SCCT	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0.7	0.8

Scenario High Gas - Low Load

E.W. Brown 1	40.8	40.0	22.3	16.5	16.5	17.2	18.0	26.0	32.9	30.2	30.7	31.0	36.5	33.6	33.7	34.3	29.9	34.6
E.W. Brown 2	60.2	51.8	42.7	14.7	14.7	13.3	19.6	25.7	30.5	34.2	30.3	26.8	35.1	34.8	33.4	34.0	36.7	34.2
E.W. Brown 3	44.5	42.1	33.5	9.2	9.5	10.4	9.7	12.4	21.2	24.9	20.8	21.1	24.6	21.0	23.6	24.2	26.4	24.7
E.W. Brown 5	0.3	3.5	10.8	0.4	0.3	0.4	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.4	0.3	0.4
E.W. Brown 6	3.9	13.7	16.2	9.1	0.8	0.9	0.5	0.4	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.8	0.7	0.8
E.W. Brown 7	3.4	16.3	12.5	10.6	1.1	1.3	0.6	0.6	0.7	0.8	0.7	0.9	1.0	0.9	0.9	1.3	1.0	1.1
E.W. Brown 8	0.3	2.2	7.3	0.2	0.2	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.3
E.W. Brown 9	0.5	1.6	8.4	0.3	0.3	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2
E.W. Brown 10	0.1	1.8	7.8	0.3	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2
E.W. Brown 11	0.1	2.2	5.4	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3
Cane Run 4	51.3	56.7	40.1	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 5	58.7	66.1	45.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 6	47.3	36.2	25.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 7	NA	NA	19.7	81.1	64.4	43.7	33.9	18.2	13.4	14.8	11.7	14.0	13.8	17.5	13.3	15.1	16.6	16.6
Cane Run 11	0.1	-0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1
Ghent 1	79.5	77.5	60.9	84.3	75.2	78.8	82.6	79.6	80.6	66.5	80.3	80.6	82.9	82.0	83.3	81.8	73.5	84.0
Ghent 2	81.0	77.7	58.8	79.6	72.7	77.1	66.1	75.5	76.2	77.8	76.1	76.9	77.6	69.6	79.0	78.5	79.8	78.1
Ghent 3	76.9	71.7	71.1	49.9	52.2	60.1	60.7	58.9	61.5	62.4	58.5	57.5	56.1	64.0	63.3	63.8	65.8	64.0
Ghent 4	73.3	70.9	80.3	65.1	65.1	75.8	76.2	71.8	65.8	76.5	73.8	72.7	75.5	77.9	75.6	68.9	78.9	76.9
Green River 3	52.2	59.3	49.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Green River 4	80.1	82.8	71.3	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Haefling 1-2 (2)	0.2	0.4	1.1	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Mill Creek 1	55.3	74.0	56.3	80.5	79.3	82.7	80.7	89.4	77.0	89.4	83.8	89.6	84.0	89.4	83.9	89.5	76.8	89.6
Mill Creek 2	72.0	66.6	55.6	72.4	86.6	78.7	88.6	77.0	88.9	84.0	89.2	84.1	89.2	84.1	89.1	77.0	89.0	84.1
Mill Creek 3	64.6	78.0	63.6	60.7	78.4	81.4	73.4	87.8	83.0	87.6	82.5	87.0	82.1	87.4	75.7	87.4	82.4	87.2
Mill Creek 4	64.8	55.6	67.8	69.5	89.1	84.0	90.5	85.3	90.7	78.1	90.7	85.3	90.7	85.3	90.7	85.4	90.6	78.2
Paddy's Run 11&12	-0.1	0.2	-0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1
Paddy's Run 13	2.3	8.1	14.1	3.0	9.4	10.0	5.3	4.0	3.1	5.4	4.2	5.2	5.1	5.8	4.7	6.3	5.6	5.5
Trimble County 1 (75%)	77.6	80.0	64.4	73.4	68.4	87.7	74.9	75.1	71.4	76.5	71.0	75.6	65.5	76.4	71.6	76.5	72.6	76.5
Trimble County 2 (75%)	65.3	58.8	84.2	82.9	86.4	75.7	82.8	82.9	86.4	82.8	86.4	82.9	82.8	75.7	82.8	82.9	82.8	82.8
Trimble County 5	4.8	9.5	14.5	5.5	6.2	10.8	6.4	5.5	3.8	5.6	4.3	5.3	5.0	5.9	4.9	6.4	5.8	5.8
Trimble County 6	6.5	10.4	13.8	3.8	5.7	8.1	4.4	3.5	3.8	4.1	3.2	4.0	3.7	4.4	3.7	4.8	4.4	4.4
Trimble County 7	5.2	7.7	16.4	3.0	3.8	6.0	3.1	2.9	2.6	2.9	2.3	3.1	2.9	3.4	3.0	3.8	3.5	3.6
Trimble County 8	2.0	2.9	5.0	2.1	3.1	4.2	2.2	2.0	2.0	1.8	1.8	2.2	2.1	2.4	2.1	2.7	2.5	2.6
Trimble County 9	6.2	9.0	17.5	1.5	2.1	2.8	1.4	1.4	1.4	1.5	1.3	1.5	1.5	1.7	1.6	2.0	1.8	1.9
Trimble County 10	1.9	3.7	4.6	1.0	1.5	2.0	1.0	0.9	1.0	1.2	0.9	1.1	1.1	1.3	1.2	1.5	1.4	1.5
Zorn 1	0.2	0.1	0.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1
Dix Dam 1-3	50.7	27.5	35.5	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7
Ohio Falls 1-8	40.9	57.5	52.1	44.6	46.9	51.3	51.3	51.2	51.3	51.3	51.3	51.2	51.3	51.3	51.3	51.2	51.3	51.3
Brown Solar	NA	NA	NA	18.8	17.4	17.4	17.4	17.3	17.4	17.4	17.4	17.3	17.4	17.4	17.4	17.3	17.4	17.4

Scenario Low Gas - Base Load

E.W. Brown 1	40.8	40.0	22.3	3.5	5.8	20.3	21.1	16.0	18.2	17.2	17.1	19.0	21.2	18.3	19.6	23.2	9.4	6.9
E.W. Brown 2	60.2	51.8	42.7	4.6	8.4	16.9	19.7	15.6	16.8	19.2	16.3	16.2	19.5	17.9	18.3	20.1	12.5	6.6
E.W. Brown 3	44.5	42.1	33.5	0.7	1.7	10.0	11.1	7.7	9.5	11.1	8.9	9.6	10.5	9.0	10.3	11.7	6.8	3.6
E.W. Brown 5	0.3	3.5	10.8	1.8	0.8	1.1	0.6	0.6	0.6	0.6	0.6	0.7	0.7	0.8	0.7	0.8	0.2	0.2
E.W. Brown 6	3.9	13.7	16.2	33.9	3.6	2.4	1.1	1.0	1.1	1.3	1.1	1.3	1.3	1.4	1.4	1.7	0.5	0.4
E.W. Brown 7	3.4	16.3	12.5	37.0	5.1	3.3	1.4	1.4	1.5	1.8	1.4	1.7	2.2	2.0	1.9	2.8	0.7	0.5
E.W. Brown 8	0.3	2.2	7.3	0.9	0.5	0.9	0.5	0.5	0.5	0.5	0.5	0.6	0.6	0.7	0.7	0.7	0.2	0.2
E.W. Brown 9	0.5	1.6	8.4	1.5	0.9	0.7	0.4	0.3	0.3	0.4	0.3	0.4	0.4	0.5	0.5	0.6	0.1	0.1
E.W. Brown 10	0.1	1.8	7.8	1.1	0.7	0.6	0.3	0.2	0.3	0.3	0.3	0.3	0.3	0.4	0.4	0.5	0.1	0.1
E.W. Brown 11	0.1	2.2	5.4	0.7	0.4	0.7	0.4	0.4	0.4	0.4	0.4	0.4	0.5	0.5	0.5	0.6	0.1	0.1
Cane Run 4	51.3	56.7	40.1	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 5	58.7	66.1	45.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 6	47.3	36.2	25.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 7	NA	NA	19.7	94.1	95.1	95.1	91.0	91.2	95.1	95.1	95.1	89.2	95.1	99.5	95.1	83.2	95.1	99.5
Cane Run 11	0.1	-0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.0
Ghent 1	79.5	77.5	60.9	84.1	71.0	70.1	76.2	70.4	69.4	58.5	69.2	72.1	73.3	71.7	74.4	75.7	52.5	52.0
Ghent 2	81.0	77.7	58.8	78.5	69.6	75.0	63.8	70.3	70.0	71.9	70.0	71.9	71.8	64.6	73.6	74.8	67.7	61.6
Ghent 3	76.9	71.7	71.1	51.4	45.5	45.2	44.8	41.1	42.2	43.7	40.2	40.1	38.3	44.2	44.2	49.0	34.1	20.0
Ghent 4	73.3	70.9	80.3	68.0	61.4	61.4	61.4	55.4	51.6	60.3	56.0	56.5	59.2	60.7	57.9	54.7	50.2	25.4
Green River 3	52.2	59.3	49.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Green River 4	80.1	82.8	71.3	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Haefling 1-2 (2)	0.2	0.4	1.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.0	0.0
Mill Creek 1	55.3	74.0	56.3	79.1	78.6	81.9	78.8	88.2	75.7	88.0	82.4	88.7	83.0	88.0	83.0	89.0	75.0	85.9
Mill Creek 2	72.0	66.6	55.6	71.6	85.7	78.2	87.2	76.4	87.8	83.1	88.3	83.5	88.4	83.5	88.2	76.7	87.5	82.0
Mill Creek 3	64.6	78.0	63.6	61.6	77.6	79.8	71.6	85.7	81.1	85.2	80.3	85.0	79.7	84.9	73.6	85.5	78.6	81.3
Mill Creek 4	64.8	55.6	67.8	66.8	87.9	81.5	89.2	84.9	90.2	77.8	90.2	85.1	90.3	85.1	90.3	85.2	89.5	76.6
Paddy's Run 11&12	-0.1	0.2	-0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.0
Paddy's Run 13	2.3	8.1	14.1	11.5	32.2	23.6	14.7	10.3	8.1	14.6	11.1	13.5	13.1	14.4	12.2	16.1	8.5	4.1
Trimble County 1 (75%)	77.6	80.0	64.4	71.1	67.3	87.0	72.6	70.6	66.4	71.2	66.3	70.8	60.8	71.1	66.8	72.4	65.0	65.3
Trimble County 2 (75%)	65.3	58.8	84.2	82.9	86.4	75.7	82.8	82.9	86.4	82.8	86.4	82.9	82.8	75.7	82.8	82.9	82.8	82.8
Trimble County 5	4.8	9.5	14.5	21.4	21.3	18.6	12.0	11.3	8.1	12.0	9.3	11.3	10.4	11.9	10.1	13.2	6.6	3.4
Trimble County 6	6.5	10.4	13.8	15.1	22.1	14.8	8.7	7.2	8.5	8.8	6.9	8.5	7.8	9.1	7.7	10.0	4.8	2.6
Trimble County 7	5.2	7.7	16.4	13.7	15.0	11.5	6.2	6.2	5.8	6.4	5.1	6.3	5.8	6.8	5.8	7.6	3.3	1.9
Trimble County 8	2.0	2.9	5.0	10.5	14.1	8.7	4.4	4.4	4.5	3.7	3.7	4.6	3.9	5.0	4.4	5.7	2.3	1.4
Trimble County 9	6.2	9.0	17.5	8.1	10.9	6.3	3.1	3.1	3.2	3.3	2.7	3.3	3.4	3.7	3.3	4.2	1.6	1.0
Trimble County 10	1.9	3.7	4.6	6.2	8.1	4.8	2.2	2.1	2.2	2.7	2.0	2.3	2.5	2.7	2.4	3.1	1.0	0.7
Zorn 1	0.2	0.1	0.9	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.0
Dix Dam 1-3	50.7	27.5	35.5	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7
Ohio Falls 1-8	40.9	57.5	52.1	44.6	46.9	51.3	51.3	51.2	51.3	51.3	51.3	51.2	51.3	51.3	51.3	51.2	51.3	51.3
Brown Solar	NA	NA	NA	18.8	17.4	17.4	17.4	17.3	17.4	17.4	17.4	17.3	17.4	17.4	17.4	17.3	17.4	17.4
2x1 NGCC	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	45.8	84.2

Scenario - Low Gas - High Load

E.W. Brown 1	40.8	40.0	22.3	5.4	8.8	26.4	29.1	22.0	14.9	8.3	8.1	9.0	9.7	9.1	9.4	11.2	9.2	10.0
E.W. Brown 2	60.2	51.8	42.7	6.7	11.5	21.7	25.7	20.7	13.5	9.3	7.8	8.0	9.3	8.9	8.9	9.9	9.9	9.4
E.W. Brown 3	44.5	42.1	33.5	1.3	2.9	13.3	15.1	10.7	7.7	5.2	4.2	4.6	4.9	4.5	4.9	5.6	5.5	5.3
E.W. Brown 5	0.3	3.5	10.8	2.9	1.4	2.0	1.2	1.1	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.4	0.4	0.4
E.W. Brown 6	3.9	13.7	16.2	43.4	6.0	4.2	2.2	2.0	0.8	0.5	0.5	0.5	0.6	0.6	0.6	0.7	0.7	0.8
E.W. Brown 7	3.4	16.3	12.5	46.1	8.0	5.5	2.5	2.7	1.1	0.7	0.7	0.7	0.9	0.8	0.9	1.1	1.0	1.0
E.W. Brown 8	0.3	2.2	7.3	1.7	1.0	1.7	1.0	0.9	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.3	0.3	0.4
E.W. Brown 9	0.5	1.6	8.4	2.7	1.7	1.5	0.8	0.7	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3
E.W. Brown 10	0.1	1.8	7.8	2.1	1.3	1.2	0.6	0.6	0.2	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2
E.W. Brown 11	0.1	2.2	5.4	1.4	0.8	1.4	0.8	0.8	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.3
Cane Run 4	51.3	56.7	40.1	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 5	58.7	66.1	45.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 6	47.3	36.2	25.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 7	NA	NA	19.7	94.1	95.1	95.1	91.1	91.2	95.1	95.1	95.1	89.2	95.1	99.5	95.1	83.3	95.1	99.5
Cane Run 11	0.1	-0.1	0.2	0.2	0.2	0.2	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1
Ghent 1	79.5	77.5	60.9	84.5	74.1	73.9	79.4	74.9	64.4	52.5	60.2	60.8	60.9	58.8	61.1	68.4	54.6	58.8
Ghent 2	81.0	77.7	58.8	79.3	71.0	76.5	65.8	72.8	67.3	64.6	64.0	65.3	64.9	58.3	66.3	70.7	67.5	64.9
Ghent 3	76.9	71.7	71.1	58.7	53.2	52.1	52.9	49.3	39.3	29.7	29.1	22.4	21.6	25.1	24.8	34.6	26.5	25.7
Ghent 4	73.3	70.9	80.3	72.9	68.5	67.8	68.7	63.5	49.1	47.0	42.4	39.3	41.1	43.3	40.2	46.8	45.7	33.7
Green River 3	52.2	59.3	49.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Green River 4	80.1	82.8	71.3	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Haefling 1-2 (2)	0.2	0.4	1.1	0.3	0.3	0.3	0.2	0.2	0.1	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Mill Creek 1	55.3	74.0	56.3	79.7	79.5	83.1	79.9	88.7	75.4	86.7	81.5	87.3	81.3	86.5	81.6	88.3	75.3	86.7
Mill Creek 2	72.0	66.6	55.6	72.6	86.4	79.3	87.9	76.7	87.5	82.0	87.1	82.6	87.2	82.5	87.0	76.1	87.4	82.6
Mill Creek 3	64.6	78.0	63.6	63.7	78.3	81.3	72.7	86.7	81.0	83.4	79.3	82.8	77.5	82.3	71.5	83.8	77.7	82.2
Mill Creek 4	64.8	55.6	67.8	70.2	88.8	82.7	89.7	85.1	90.5	77.7	90.3	84.8	89.8	84.6	89.3	85.1	89.3	77.0
Paddy's Run 11&12	-0.1	0.2	-0.1	0.2	0.2	0.2	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1
Paddy's Run 13	2.3	8.1	14.1	16.6	40.8	30.7	21.4	14.7	4.1	6.1	4.9	5.8	5.7	6.2	5.5	7.0	6.4	6.5
Trimble County 1 (75%)	77.6	80.0	64.4	72.2	68.0	87.4	74.2	72.9	66.0	67.9	64.1	66.7	57.2	67.1	62.4	69.5	63.5	67.1
Trimble County 2 (75%)	65.3	58.8	84.2	82.9	86.4	75.7	82.8	82.9	86.4	82.8	86.4	82.9	82.8	75.7	82.8	82.9	82.8	82.8
Trimble County 5	4.8	9.5	14.5	28.6	27.6	25.0	18.1	16.9	5.5	5.0	4.2	4.8	4.5	5.2	4.6	5.8	5.3	5.5
Trimble County 6	6.5	10.4	13.8	20.6	29.4	20.3	13.6	11.1	7.9	3.6	3.1	3.5	3.4	3.9	3.5	4.4	4.1	4.2
Trimble County 7	5.2	7.7	16.4	19.2	20.4	16.3	10.1	10.0	5.5	2.6	2.3	2.6	2.6	2.9	2.7	3.3	3.1	3.2
Trimble County 8	2.0	2.9	5.0	15.1	19.7	12.9	7.5	7.4	3.9	1.7	1.7	1.9	1.8	2.2	2.0	2.5	2.3	2.4
Trimble County 9	6.2	9.0	17.5	11.8	15.8	9.6	5.4	5.4	2.6	1.4	1.3	1.4	1.5	1.6	1.5	1.8	1.7	1.8
Trimble County 10	1.9	3.7	4.6	9.2	12.1	7.7	3.9	3.8	1.7	1.0	0.9	1.0	1.1	1.2	1.1	1.3	1.3	1.4
Zorn 1	0.2	0.1	0.9	0.2	0.2	0.2	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1
Dix Dam 1-3	50.7	27.5	35.5	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7
Ohio Falls 1-8	40.9	57.5	52.1	44.6	46.9	51.3	51.3	51.2	51.3	51.3	51.3	51.2	51.3	51.3	51.3	51.2	51.3	51.3
Brown Solar	NA	NA	NA	18.8	17.4	17.4	17.4	17.3	17.4	17.4	17.4	17.3	17.4	17.4	17.4	17.3	17.4	17.4
2x1 NGCC	NA	NA	NA	NA	NA	NA	NA	NA	40.2	70.5	65.8	77.9	79.5	80.2	81.6	66.6	82.4	88.9

Scenario: Low Gas - Low Load

E.W. Brown 1	40.8	40.0	22.3	2.1	3.5	15.0	15.0	11.0	12.4	12.1	11.8	13.5	15.0	13.0	13.8	16.9	12.9	14.2
E.W. Brown 2	60.2	51.8	42.7	2.9	5.7	12.6	14.3	11.1	11.9	14.1	11.6	11.9	14.3	13.2	13.3	14.9	14.6	13.5
E.W. Brown 3	44.5	42.1	33.5	0.4	0.9	7.2	7.6	5.3	6.4	7.9	6.1	6.8	7.4	6.4	7.2	8.4	8.1	7.5
E.W. Brown 5	0.3	3.5	10.8	1.0	0.4	0.5	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.5
E.W. Brown 6	3.9	13.7	16.2	25.1	2.0	1.2	0.5	0.5	0.5	0.6	0.5	0.6	0.6	0.6	0.7	0.7	0.9	0.9
E.W. Brown 7	3.4	16.3	12.5	28.3	3.0	1.8	0.7	0.7	0.7	0.9	0.7	0.9	1.1	1.0	1.0	1.5	1.2	1.2
E.W. Brown 8	0.3	2.2	7.3	0.4	0.2	0.4	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.3	0.4	0.4
E.W. Brown 9	0.5	1.6	8.4	0.8	0.4	0.3	0.1	0.1	0.1	0.2	0.1	0.2	0.2	0.2	0.2	0.3	0.2	0.3
E.W. Brown 10	0.1	1.8	7.8	0.6	0.3	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2
E.W. Brown 11	0.1	2.2	5.4	0.3	0.2	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.3
Cane Run 4	51.3	56.7	40.1	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 5	58.7	66.1	45.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 6	47.3	36.2	25.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 7	NA	NA	19.7	94.1	95.1	95.1	90.9	91.1	95.0	95.0	95.0	89.2	95.0	99.5	95.1	83.0	95.1	99.5
Cane Run 11	0.1	-0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1
Ghent 1	79.5	77.5	60.9	83.4	66.8	65.1	71.6	64.4	63.1	53.7	63.0	66.4	67.7	66.2	69.1	71.0	61.3	69.5
Ghent 2	81.0	77.7	58.8	77.7	67.8	73.2	61.6	67.2	66.7	68.7	66.8	69.0	68.8	61.8	70.9	72.4	71.9	69.8
Ghent 3	76.9	71.7	71.1	43.5	37.5	38.0	36.3	32.8	33.6	35.6	32.1	32.2	30.8	36.0	35.8	40.4	38.4	36.3
Ghent 4	73.3	70.9	80.3	61.7	52.8	53.6	52.3	45.9	43.5	51.6	46.7	47.5	50.2	52.0	48.8	46.7	55.3	49.6
Green River 3	52.2	59.3	49.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Green River 4	80.1	82.8	71.3	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Haefling 1-2 (2)	0.2	0.4	1.1	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.1
Mill Creek 1	55.3	74.0	56.3	78.4	77.8	80.8	77.7	87.5	75.1	87.2	81.6	88.0	82.3	87.3	82.4	88.6	75.7	87.8
Mill Creek 2	72.0	66.6	55.6	70.4	84.8	77.1	86.3	75.9	87.1	82.6	87.6	83.0	87.9	83.0	87.7	76.4	88.0	83.2
Mill Creek 3	64.6	78.0	63.6	59.2	77.0	78.4	70.7	84.7	80.2	84.2	79.3	84.0	78.7	83.8	72.7	84.4	79.1	83.7
Mill Creek 4	64.8	55.6	67.8	62.4	86.8	79.9	88.4	84.7	89.9	77.6	89.8	84.9	90.0	84.9	90.0	85.1	90.0	77.9
Paddy's Run 11&12	-0.1	0.2	-0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1
Paddy's Run 13	2.3	8.1	14.1	7.5	24.3	17.4	9.3	6.8	5.4	9.5	7.1	8.8	8.6	9.5	8.0	10.8	9.5	9.4
Trimble County 1 (75%)	77.6	80.0	64.4	69.9	66.5	86.5	71.0	68.4	64.1	68.8	64.1	68.6	58.9	68.9	64.6	70.2	65.4	69.3
Trimble County 2 (75%)	65.3	58.8	84.2	82.9	86.4	75.7	82.8	82.9	86.4	82.8	86.4	82.9	82.8	75.7	82.8	82.9	82.8	82.8
Trimble County 5	4.8	9.5	14.5	15.3	15.7	13.3	7.4	7.0	5.1	7.5	5.8	7.2	6.6	7.7	6.5	8.6	7.7	7.7
Trimble County 6	6.5	10.4	13.8	10.6	15.8	10.2	5.1	4.4	5.1	5.3	4.2	5.2	4.8	5.6	4.8	6.4	5.7	5.8
Trimble County 7	5.2	7.7	16.4	9.3	10.4	7.6	3.5	3.6	3.3	3.7	3.0	3.7	3.5	4.1	3.5	4.7	4.2	4.3
Trimble County 8	2.0	2.9	5.0	7.0	9.4	5.5	2.4	2.4	2.5	2.1	2.1	2.6	2.3	2.9	2.6	3.4	3.0	3.1
Trimble County 9	6.2	9.0	17.5	5.2	7.1	3.8	1.6	1.6	1.7	1.8	1.5	1.8	1.9	2.1	1.9	2.4	2.2	2.3
Trimble County 10	1.9	3.7	4.6	3.8	5.1	2.7	1.1	1.1	1.1	1.4	1.1	1.3	1.3	1.4	1.3	1.7	1.6	1.7
Zorn 1	0.2	0.1	0.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1
Dix Dam 1-3	50.7	27.5	35.5	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7	25.7
Ohio Falls 1-8	40.9	57.5	52.1	44.6	46.9	51.3	51.3	51.2	51.3	51.3	51.3	51.2	51.3	51.3	51.3	51.2	51.3	51.3
Brown Solar	NA	NA	NA	18.8	17.4	17.4	17.4	17.3	17.4	17.4	17.4	17.3	17.4	17.4	17.4	17.3	17.4	17.4

(1) Combustion turbines to be reported as a composite facility.

(2) Haefling 1-2 actuals include Haefling 3

2016 IRP

Kentucky Utilities Company and Louisville Gas and Electric Company
UNIT PERFORMANCE DATA (1)

Sch10

Average Heat Rate (Btu/kWh)

Unit Name	(ACTUAL)			(PROJECTED)														
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
Scenario: Mid Gas - Base Load																		
E.W. Brown 1	12,033	12,407	12,983	10,981	10,763	10,746	10,700	10,681	10,827	10,804	10,787	10,628	10,562	10,579	10,576	10,566	10,558	10,568
E.W. Brown 2	10,729	10,675	11,142	10,622	10,534	10,469	10,511	10,504	10,553	10,528	10,531	10,417	10,408	10,410	10,411	10,406	10,396	10,403
E.W. Brown 3	11,311	11,397	11,646	11,599	11,593	11,774	11,746	11,659	11,390	11,352	11,469	11,450	11,460	11,362	11,339	11,312	11,264	11,243
E.W. Brown 5	24,417	16,513	13,490	12,494	12,744	13,092	13,476	13,995	14,070	14,089	13,974	13,998	13,952	13,926	13,871	13,883	14,168	14,042
E.W. Brown 6	12,536	12,092	10,609	10,877	11,045	11,230	11,270	11,383	11,582	11,572	11,562	11,559	11,547	11,543	11,538	11,518	11,600	11,591
E.W. Brown 7	12,127	11,182	10,605	10,843	10,996	11,171	11,194	11,363	11,541	11,506	11,537	11,626	11,632	11,573	11,599	11,620	11,595	11,627
E.W. Brown 8	20,979	15,416	12,874	12,716	12,975	13,386	14,310	14,704	14,653	14,652	14,630	14,578	14,559	14,509	14,481	14,397	14,765	14,708
E.W. Brown 9	17,924	16,309	13,215	12,693	13,185	13,558	13,906	14,228	14,156	14,310	13,930	14,140	14,057	14,092	13,943	14,088	14,508	14,039
E.W. Brown 10	40,990	15,629	13,004	12,691	13,087	13,328	13,585	13,684	13,647	13,781	13,475	13,621	13,544	13,590	13,463	13,594	13,928	13,505
E.W. Brown 11	30,238	15,911	13,569	12,708	12,861	13,322	13,917	14,325	14,213	14,188	14,187	14,129	14,113	14,133	14,118	14,037	14,339	14,304
Cane Run 4	11,557	11,161	12,588	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 5	10,858	10,845	11,461	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 6	10,868	10,841	11,043	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 7	NA	NA	6,980	6,831	6,831	6,848	6,884	6,963	7,084	7,090	7,113	7,132	7,131	7,175	7,214	7,188	7,241	7,301
Cane Run 11	42,874	(5,919)	56,474	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117
Ghent 1	10,784	10,823	10,698	10,759	10,788	10,824	10,799	10,794	10,788	10,785	10,788	10,788	10,785	10,784	10,783	10,787	10,783	10,781
Ghent 2	10,696	10,688	10,629	10,516	10,504	10,499	10,503	10,498	10,508	10,509	10,517	10,518	10,522	10,519	10,520	10,522	10,523	10,521
Ghent 3	11,080	10,912	11,003	11,124	11,149	11,127	11,144	11,152	11,130	11,113	11,116	11,113	11,101	11,101	11,105	11,103	11,100	11,098
Ghent 4	11,051	10,912	10,930	10,942	10,983	10,973	10,941	10,943	10,932	10,916	10,927	10,927	10,922	10,918	10,917	10,921	10,915	10,912
Green River 3	12,992	12,961	13,074	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Green River 4	11,155	11,397	10,712	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Haefling 1-2 (2)	29,444	21,195	21,995	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000
Mill Creek 1	10,658	10,464	10,470	10,310	10,335	10,319	10,335	10,379	10,381	10,381	10,380	10,383	10,382	10,383	10,381	10,382	10,380	10,383
Mill Creek 2	10,671	10,693	10,629	10,530	10,551	10,538	10,561	10,568	10,567	10,569	10,568	10,568	10,568	10,569	10,568	10,568	10,567	10,569
Mill Creek 3	10,500	10,674	10,858	10,472	10,499	10,466	10,481	10,512	10,519	10,514	10,515	10,511	10,513	10,514	10,515	10,514	10,515	10,512
Mill Creek 4	10,827	10,836	10,388	10,642	10,642	10,656	10,651	10,651	10,651	10,655	10,652	10,653	10,652	10,652	10,651	10,650	10,652	10,653
Paddy's Run 11&12	(29,554)	28,983	(13,051)	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242
Paddy's Run 13	11,327	11,145	10,809	10,685	10,704	10,872	10,876	11,517	13,035	13,179	13,164	13,165	13,146	13,147	13,107	13,115	13,254	13,218
Trimble County 1 (75%)	10,762	10,746	8,085	10,430	10,480	10,556	10,473	10,432	10,451	10,457	10,474	10,476	10,487	10,485	10,485	10,485	10,493	10,487
Trimble County 2 (75%)	9,369	9,300	6,919	9,177	9,178	9,186	9,185	9,185	9,187	9,185	9,185	9,185	9,185	9,187	9,187	9,187	9,187	9,187
Trimble County 5	13,020	12,985	11,056	10,976	10,910	11,072	11,160	11,342	11,618	11,768	12,046	12,153	12,235	12,345	12,371	12,379	12,373	12,094
Trimble County 6	12,796	11,958	10,791	10,987	10,950	11,109	11,192	11,366	11,685	11,709	11,972	12,054	12,113	12,252	12,245	12,251	12,267	12,035
Trimble County 7	12,849	12,342	11,043	11,008	10,966	11,144	11,222	11,326	11,690	11,688	11,929	11,976	11,958	12,108	12,105	12,114	12,164	12,029
Trimble County 8	12,590	12,854	11,149	11,022	10,992	11,179	11,250	11,337	11,665	11,610	11,868	11,885	11,842	11,879	11,881	11,904	12,017	11,980
Trimble County 9	12,752	12,491	10,664	11,034	11,009	11,208	11,276	11,346	11,647	11,655	11,824	11,851	11,832	11,814	11,797	11,794	11,920	11,895
Trimble County 10	12,513	12,634	11,331	11,032	11,025	11,241	11,299	11,353	11,627	11,651	11,727	11,733	11,727	11,691	11,680	11,669	11,790	11,769
Zorn 1	25,887	40,436	20,388	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676
2x1 NGCC	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	7,089	7,173

Scenario: Mid Gas - High Load

E.W. Brown 1	12,033	12,407	12,983	10,916	10,724	10,695	10,657	10,646	10,860	10,791	10,712	10,580	10,519	10,538	10,535	10,529	10,524	10,529
E.W. Brown 2	10,729	10,675	11,142	10,592	10,508	10,446	10,482	10,478	10,575	10,523	10,487	10,390	10,376	10,380	10,382	10,378	10,369	10,375
E.W. Brown 3	11,311	11,397	11,646	11,581	11,580	11,736	11,700	11,606	11,458	11,357	11,440	11,360	11,365	11,285	11,263	11,237	11,196	11,183
E.W. Brown 5	24,417	16,513	13,490	12,465	12,690	13,036	13,381	13,859	14,246	14,083	14,021	14,001	13,978	13,952	13,915	13,908	13,911	13,883
E.W. Brown 6	12,536	12,092	10,609	10,842	11,015	11,186	11,230	11,345	11,604	11,593	11,581	11,574	11,567	11,569	11,562	11,546	11,555	11,540
E.W. Brown 7	12,127	11,182	10,605	10,816	10,974	11,135	11,166	11,322	11,561	11,539	11,563	11,613	11,623	11,603	11,616	11,630	11,601	11,575
E.W. Brown 8	20,979	15,416	12,874	12,692	12,919	13,299	14,113	14,473	14,708	14,730	14,711	14,658	14,639	14,594	14,563	14,498	14,544	14,487
E.W. Brown 9	17,924	16,309	13,215	12,669	13,120	13,492	13,831	14,155	14,705	14,084	13,898	13,992	13,950	13,977	13,888	13,979	13,926	13,922
E.W. Brown 10	40,990	15,629	13,004	12,667	13,025	13,279	13,529	13,655	14,125	13,583	13,449	13,482	13,448	13,477	13,403	13,482	13,437	13,439
E.W. Brown 11	30,238	15,911	13,569	12,686	12,819	13,235	13,764	14,127	14,246	14,257	14,248	14,190	14,176	14,208	14,186	14,125	14,170	14,121
Cane Run 4	11,557	11,161	12,588	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 5	10,858	10,845	11,461	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 6	10,868	10,841	11,043	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 7	NA	NA	6980.3	6,831	6,831	6,845	6,877	6,939	7,042	7,048	7,078	7,096	7,107	7,143	7,189	7,155	7,197	7,250
Cane Run 11	42,874	(5,919)	56,474	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117
Ghent 1	10,784	10,823	10,698	10,758	10,777	10,808	10,790	10,787	10,782	10,780	10,783	10,782	10,781	10,779	10,781	10,780	10,781	10,780
Ghent 2	10,696	10,688	10,629	10,523	10,507	10,506	10,508	10,503	10,513	10,515	10,522	10,524	10,528	10,525	10,526	10,528	10,529	10,527
Ghent 3	11,080	10,912	11,003	11,110	11,129	11,113	11,121	11,133	11,110	11,097	11,097	11,097	11,086	11,086	11,089	11,088	11,087	11,085
Ghent 4	11,051	10,912	10,930	10,924	10,953	10,952	10,925	10,925	10,921	10,906	10,913	10,914	10,910	10,907	10,905	10,911	10,905	10,901
Green River 3	12,992	12,961	13,074	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Green River 4	11,155	11,397	10,712	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Haefling 1-2 (2)	29,444	21,195	21,995	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000
Mill Creek 1	10,658	10,464	10,470	10,319	10,344	10,330	10,345	10,381	10,383	10,383	10,382	10,384	10,383	10,384	10,383	10,383	10,381	10,384
Mill Creek 2	10,671	10,693	10,629	10,534	10,555	10,543	10,563	10,568	10,568	10,569	10,569	10,569	10,568	10,569	10,568	10,569	10,568	10,569
Mill Creek 3	10,500	10,674	10,858	10,476	10,504	10,474	10,490	10,517	10,522	10,519	10,520	10,517	10,518	10,518	10,519	10,519	10,519	10,517
Mill Creek 4	10,827	10,836	10,388	10,641	10,644	10,654	10,651	10,651	10,651	10,655	10,652	10,653	10,652	10,652	10,651	10,650	10,652	10,653
Paddy's Run 11&12	(29,554)	28,983	(13,051)	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242
Paddy's Run 13	11,327	11,145	10,809	10,649	10,663	10,804	10,822	11,505	13,094	13,222	13,211	13,202	13,192	13,192	13,157	13,168	13,159	13,131
Trimble County 1 (75%)	10,762	10,746	8,085	10,443	10,494	10,560	10,490	10,449	10,471	10,476	10,494	10,496	10,507	10,504	10,504	10,505	10,512	10,506
Trimble County 2 (75%)	9,369	9,300	6,919	9,177	9,178	9,188	9,185	9,185	9,187	9,185	9,185	9,185	9,185	9,187	9,187	9,187	9,187	9,187
Trimble County 5	13,020	12,985	11,056	10,939	10,875	11,020	11,105	11,290	11,666	11,788	12,080	12,096	12,072	12,057	12,043	12,034	12,034	12,012
Trimble County 6	12,796	11,958	10,791	10,951	10,911	11,054	11,137	11,322	11,716	11,735	12,034	12,029	12,010	12,010	11,980	11,982	11,980	11,955
Trimble County 7	12,849	12,342	11,043	10,973	10,927	11,087	11,167	11,280	11,732	11,708	11,979	12,026	12,006	11,992	11,972	11,966	11,967	11,942
Trimble County 8	12,590	12,854	11,149	10,988	10,953	11,120	11,195	11,290	11,695	11,645	11,914	11,963	11,947	11,934	11,921	11,913	11,912	11,891
Trimble County 9	12,752	12,491	10,664	11,000	10,972	11,147	11,221	11,298	11,682	11,672	11,865	11,883	11,867	11,860	11,840	11,834	11,834	11,809
Trimble County 10	12,513	12,634	11,331	11,001	10,988	11,180	11,244	11,304	11,650	11,666	11,763	11,763	11,755	11,730	11,719	11,707	11,711	11,689
Zorn 1	25,887	40,436	20,388	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676
2x1 NGCC	NA	NA	NA	NA	NA	NA	NA	NA	6,894	6,983	7,050	7,162	7,146	7,140	7,123	7,117	7,116	7,113

Scenario: Mid Gas - Low Load

E.W. Brown 1	12,033	12,407	12,983	11,049	10,802	10,801	10,743	10,717	10,887	10,864	10,874	10,677	10,611	10,624	10,619	10,605	10,593	10,609
E.W. Brown 2	10,729	10,675	11,142	10,651	10,559	10,493	10,540	10,529	10,589	10,568	10,579	10,447	10,441	10,444	10,442	10,437	10,427	10,433
E.W. Brown 3	11,311	11,397	11,646	11,816	11,605	11,809	11,786	11,708	11,437	11,413	11,528	11,517	11,541	11,432	11,406	11,382	11,334	11,305
E.W. Brown 5	24,417	16,513	13,490	12,524	12,801	13,147	13,570	14,128	14,226	14,240	14,141	14,152	14,111	14,081	14,032	14,041	14,035	14,002
E.W. Brown 6	12,536	12,092	10,609	10,913	11,075	11,275	11,311	11,419	11,635	11,630	11,614	11,612	11,601	11,599	11,592	11,575	11,586	11,566
E.W. Brown 7	12,127	11,182	10,605	10,871	11,018	11,205	11,222	11,403	11,589	11,557	11,589	11,675	11,686	11,631	11,655	11,682	11,637	11,600
E.W. Brown 8	20,979	15,416	12,874	12,739	13,033	13,479	14,509	14,935	14,895	14,894	14,867	14,817	14,794	14,743	14,708	14,631	14,690	14,622
E.W. Brown 9	17,924	16,309	13,215	12,716	13,271	13,623	13,982	14,288	14,232	14,384	14,026	14,225	14,142	14,175	14,035	14,196	14,095	14,082
E.W. Brown 10	40,990	15,629	13,004	12,716	13,152	13,377	13,643	13,702	13,678	13,809	13,529	13,654	13,574	13,621	13,497	13,648	13,557	13,552
E.W. Brown 11	30,238	15,911	13,569	12,733	12,904	13,414	14,070	14,518	14,407	14,386	14,377	14,323	14,301	14,331	14,307	14,235	14,292	14,233
Cane Run 4	11,557	11,161	12,588	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 5	10,858	10,845	11,461	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 6	10,868	10,841	11,043	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 7	NA	NA	6980.3	6,831	6,831	6,852	6,889	6,990	7,128	7,139	7,149	7,180	7,159	7,217	7,247	7,229	7,292	7,348
Cane Run 11	42,874	(5,919)	56,474	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117
Ghent 1	10,784	10,823	10,698	10,757	10,810	10,843	10,811	10,804	10,798	10,793	10,798	10,797	10,793	10,793	10,790	10,794	10,790	10,788
Ghent 2	10,696	10,688	10,629	10,508	10,503	10,498	10,500	10,493	10,501	10,502	10,510	10,511	10,515	10,512	10,513	10,514	10,516	10,514
Ghent 3	11,080	10,912	11,003	11,139	11,170	11,144	11,171	11,172	11,155	11,134	11,138	11,133	11,120	11,119	11,125	11,123	11,117	11,115
Ghent 4	11,051	10,912	10,930	10,966	11,023	10,998	10,964	10,969	10,951	10,933	10,947	10,948	10,941	10,935	10,935	10,938	10,931	10,932
Green River 3	12,992	12,961	13,074	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Green River 4	11,155	11,397	10,712	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Haefling 1-2 (2)	29,444	21,195	21,995	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000
Mill Creek 1	10,658	10,464	10,470	10,302	10,327	10,308	10,325	10,377	10,380	10,380	10,378	10,382	10,380	10,381	10,379	10,381	10,378	10,382
Mill Creek 2	10,671	10,693	10,629	10,526	10,547	10,532	10,558	10,568	10,566	10,568	10,568	10,568	10,567	10,568	10,567	10,568	10,566	10,568
Mill Creek 3	10,500	10,674	10,858	10,470	10,494	10,458	10,473	10,507	10,514	10,508	10,510	10,505	10,507	10,508	10,510	10,508	10,509	10,506
Mill Creek 4	10,827	10,836	10,388	10,644	10,641	10,658	10,652	10,651	10,651	10,655	10,652	10,653	10,652	10,652	10,651	10,650	10,652	10,653
Paddy's Run 11&12	(29,554)	28,983	(13,051)	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242
Paddy's Run 13	11,327	11,145	10,809	10,724	10,746	10,947	10,930	11,520	13,148	13,264	13,247	13,250	13,234	13,235	13,199	13,206	13,201	13,183
Trimble County 1 (75%)	10,762	10,746	8,085	10,418	10,467	10,552	10,455	10,415	10,430	10,437	10,451	10,454	10,465	10,464	10,463	10,464	10,472	10,465
Trimble County 2 (75%)	9,369	9,300	6,919	9,177	9,178	9,186	9,185	9,185	9,187	9,185	9,185	9,185	9,185	9,187	9,187	9,187	9,187	9,187
Trimble County 5	13,020	12,985	11,056	11,014	10,946	11,129	11,219	11,393	11,676	11,837	12,131	12,250	12,358	12,478	12,507	12,515	12,517	12,467
Trimble County 6	12,796	11,958	10,791	11,024	10,993	11,169	11,251	11,411	11,748	11,774	12,061	12,148	12,229	12,383	12,380	12,384	12,387	12,339
Trimble County 7	12,849	12,342	11,043	11,045	11,008	11,207	11,282	11,376	11,753	11,755	12,023	12,074	12,061	12,234	12,233	12,243	12,258	12,251
Trimble County 8	12,590	12,854	11,149	11,059	11,033	11,243	11,310	11,388	11,731	11,676	11,962	11,980	11,944	11,980	11,984	12,008	11,976	11,951
Trimble County 9	12,752	12,491	10,664	11,070	11,050	11,272	11,335	11,397	11,715	11,728	11,917	11,945	11,927	11,909	11,892	11,890	11,885	11,856
Trimble County 10	12,513	12,634	11,331	11,067	11,064	11,305	11,358	11,403	11,695	11,726	11,811	11,820	11,812	11,777	11,765	11,754	11,758	11,731
Zorn 1	25,887	40,436	20,388	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676

Scenario: High Gas - Base Load

E.W. Brown 1	12,033	12,407	12,983	10,659	10,656	10,656	10,833	10,682	10,581	10,556	10,586	10,585	10,562	10,579	10,576	10,566	10,558	10,568
E.W. Brown 2	10,729	10,675	11,142	10,481	10,479	10,458	10,547	10,480	10,425	10,403	10,422	10,412	10,403	10,405	10,411	10,406	10,397	10,403
E.W. Brown 3	11,311	11,397	11,646	11,581	11,533	11,471	11,376	11,425	11,335	11,241	11,291	11,259	11,273	11,227	11,263	11,237	11,225	11,238
E.W. Brown 5	24,417	16,513	13,490	12,791	13,171	13,975	14,142	14,113	14,077	14,088	13,974	13,998	13,952	13,926	13,871	13,883	13,509	13,426
E.W. Brown 6	12,536	12,092	10,609	10,946	11,117	11,492	11,585	11,595	11,593	11,572	11,562	11,559	11,547	11,543	11,538	11,518	11,559	11,542
E.W. Brown 7	12,127	11,182	10,605	10,921	11,086	11,359	11,535	11,570	11,570	11,538	11,569	11,625	11,623	11,568	11,599	11,620	11,603	11,569
E.W. Brown 8	20,979	15,416	12,874	13,011	13,208	14,511	14,749	14,716	14,650	14,651	14,629	14,578	14,559	14,509	14,481	14,397	13,896	13,826
E.W. Brown 9	17,924	16,309	13,215	13,448	14,126	14,394	14,217	14,198	14,153	14,308	13,929	14,140	14,057	14,092	13,943	14,088	13,521	13,359
E.W. Brown 10	40,990	15,629	13,004	13,261	13,860	13,900	13,696	13,677	13,641	13,779	13,474	13,621	13,544	13,590	13,463	13,594	13,258	13,111
E.W. Brown 11	30,238	15,911	13,569	12,889	12,971	14,102	14,291	14,250	14,209	14,187	14,186	14,129	14,113	14,133	14,118	14,037	13,538	13,492
Cane Run 4	11,557	11,161	12,588	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 5	10,858	10,845	11,461	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 6	10,868	10,841	11,043	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 7	NA	NA	6980.3	6,859	6,901	7,058	7,102	7,156	7,245	7,336	7,336	7,317	7,336	7,307	7,323	7,294	7,303	7,306
Cane Run 11	42,874	(5,919)	56,474	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117
Ghent 1	10,784	10,823	10,698	10,760	10,765	10,783	10,781	10,791	10,787	10,785	10,788	10,788	10,785	10,784	10,783	10,787	10,783	10,782
Ghent 2	10,696	10,688	10,629	10,521	10,501	10,504	10,504	10,518	10,521	10,520	10,518	10,518	10,522	10,519	10,520	10,522	10,523	10,521
Ghent 3	11,080	10,912	11,003	11,113	11,132	11,095	11,101	11,109	11,109	11,104	11,115	11,111	11,100	11,100	11,104	11,102	11,100	11,098
Ghent 4	11,051	10,912	10,930	10,925	10,922	10,919	10,912	10,930	10,932	10,916	10,927	10,927	10,922	10,918	10,917	10,921	10,915	10,912
Green River 3	12,992	12,961	13,074	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Green River 4	11,155	11,397	10,712	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Haefling 1-2 (2)	29,444	21,195	21,995	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000
Mill Creek 1	10,658	10,464	10,470	10,315	10,345	10,332	10,359	10,382	10,381	10,382	10,380	10,383	10,382	10,383	10,381	10,382	10,380	10,383
Mill Creek 2	10,671	10,693	10,629	10,534	10,557	10,545	10,566	10,568	10,567	10,569	10,568	10,568	10,568	10,569	10,568	10,568	10,567	10,569
Mill Creek 3	10,500	10,674	10,858	10,474	10,504	10,481	10,499	10,516	10,519	10,515	10,515	10,511	10,513	10,514	10,515	10,514	10,515	10,512
Mill Creek 4	10,827	10,836	10,388	10,636	10,642	10,652	10,651	10,651	10,651	10,655	10,652	10,653	10,652	10,652	10,651	10,650	10,652	10,653
Paddy's Run 11&12	(29,554)	28,983	(13,051)	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242
Paddy's Run 13	11,327	11,145	10,809	10,897	10,791	12,063	13,209	13,192	13,123	13,180	13,167	13,166	13,154	13,149	13,114	13,123	13,133	13,102
Trimble County 1 (75%)	10,762	10,746	8,085	10,445	10,485	10,565	10,503	10,472	10,483	10,486	10,479	10,477	10,487	10,485	10,484	10,485	10,493	10,487
Trimble County 2 (75%)	9,369	9,300	6,919	9,177	9,178	9,186	9,185	9,185	9,187	9,185	9,185	9,185	9,185	9,187	9,187	9,187	9,187	9,187
Trimble County 5	13,020	12,985	11,056	11,026	11,125	11,346	11,692	12,282	12,423	12,473	12,459	12,522	12,440	12,408	12,373	12,455	12,373	12,335
Trimble County 6	12,796	11,958	10,791	11,027	11,139	11,378	11,680	12,153	12,506	12,342	12,322	12,368	12,297	12,286	12,236	12,313	12,247	12,208
Trimble County 7	12,849	12,342	11,043	11,045	11,158	11,413	11,669	12,116	12,373	12,178	12,145	12,268	12,186	12,189	12,159	12,192	12,147	12,117
Trimble County 8	12,590	12,854	11,149	11,056	11,161	11,442	11,661	11,964	12,138	11,918	11,931	12,006	11,916	11,897	11,881	11,900	11,886	11,865
Trimble County 9	12,752	12,491	10,664	11,061	11,168	11,441	11,646	11,910	11,994	11,878	11,830	11,861	11,844	11,817	11,797	11,794	11,795	11,768
Trimble County 10	12,513	12,634	11,331	11,083	11,169	11,451	11,639	11,804	11,839	11,801	11,734	11,733	11,727	11,691	11,680	11,669	11,675	11,651
Zom 1	25,887	40,436	20,388	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676
SCCT	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	9,940	9,940

Scenario: High Gas - High Load

E.W. Brown 1	12,033	12,407	12,983	10,619	10,615	10,611	10,750	10,629	10,537	10,520	10,543	10,543	10,519	10,537	10,535	10,529	10,524	10,529
E.W. Brown 2	10,729	10,675	11,142	10,455	10,451	10,434	10,501	10,444	10,393	10,375	10,391	10,386	10,373	10,376	10,382	10,378	10,370	10,376
E.W. Brown 3	11,311	11,397	11,646	11,554	11,491	11,408	11,314	11,358	11,262	11,173	11,230	11,202	11,203	11,173	11,202	11,179	11,162	11,178
E.W. Brown 5	24,417	16,513	13,490	12,740	13,082	13,832	13,970	13,963	14,281	14,082	14,019	14,000	13,978	13,952	13,915	13,908	13,911	13,883
E.W. Brown 6	12,536	12,092	10,609	10,913	11,090	11,432	11,526	11,539	11,636	11,592	11,580	11,574	11,567	11,569	11,562	11,546	11,555	11,540
E.W. Brown 7	12,127	11,182	10,605	10,895	11,062	11,318	11,479	11,517	11,617	11,565	11,577	11,613	11,623	11,603	11,616	11,630	11,601	11,575
E.W. Brown 8	20,979	15,416	12,874	12,962	13,147	14,285	14,485	14,478	14,702	14,729	14,708	14,657	14,639	14,594	14,563	14,496	14,544	14,487
E.W. Brown 9	17,924	16,309	13,215	13,369	13,994	14,282	14,112	14,130	14,704	14,081	13,895	13,991	13,950	13,977	13,888	13,979	13,926	13,922
E.W. Brown 10	40,990	15,629	13,004	13,194	13,739	13,837	13,642	13,652	14,114	13,581	13,446	13,481	13,448	13,477	13,403	13,482	13,437	13,439
E.W. Brown 11	30,238	15,911	13,569	12,851	12,931	13,907	14,077	14,057	14,243	14,255	14,245	14,190	14,176	14,208	14,186	14,125	14,170	14,121
Cane Run 4	11,557	11,161	12,588	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 5	10,858	10,845	11,461	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 6	10,868	10,841	11,043	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 7	NA	NA	6980.3	6,855	6,888	7,019	7,051	7,109	7,211	7,279	7,294	7,255	7,286	7,251	7,279	7,244	7,251	7,258
Cane Run 11	42,874	(5,919)	56,474	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117
Ghent 1	10,784	10,823	10,698	10,758	10,762	10,779	10,777	10,784	10,782	10,780	10,783	10,782	10,781	10,779	10,781	10,780	10,781	10,780
Ghent 2	10,696	10,688	10,629	10,528	10,507	10,512	10,510	10,524	10,527	10,526	10,524	10,524	10,528	10,525	10,526	10,528	10,529	10,527
Ghent 3	11,080	10,912	11,003	11,099	11,114	11,082	11,086	11,093	11,092	11,088	11,097	11,095	11,085	11,086	11,089	11,088	11,086	11,085
Ghent 4	11,051	10,912	10,930	10,914	10,909	10,911	10,902	10,914	10,921	10,906	10,913	10,914	10,910	10,907	10,905	10,911	10,905	10,901
Green River 3	12,992	12,961	13,074	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Green River 4	11,155	11,397	10,712	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Haeffing 1-2 (2)	29,444	21,195	21,995	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000
Mill Creek 1	10,658	10,464	10,470	10,324	10,352	10,342	10,366	10,383	10,383	10,383	10,382	10,384	10,383	10,384	10,383	10,383	10,381	10,384
Mill Creek 2	10,671	10,693	10,629	10,538	10,560	10,550	10,568	10,569	10,568	10,569	10,569	10,569	10,568	10,569	10,568	10,569	10,568	10,569
Mill Creek 3	10,500	10,674	10,858	10,480	10,509	10,489	10,506	10,520	10,522	10,520	10,520	10,517	10,518	10,518	10,519	10,518	10,519	10,517
Mill Creek 4	10,827	10,836	10,388	10,638	10,644	10,652	10,651	10,651	10,651	10,655	10,652	10,653	10,652	10,652	10,651	10,650	10,652	10,653
Paddy's Run 11&12	(29,554)	28,983	(13,051)	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242
Paddy's Run 13	11,327	11,145	10,809	10,836	10,761	11,969	13,110	13,084	13,194	13,233	13,202	13,203	13,192	13,192	13,157	13,168	13,159	13,131
Trimble County 1 (75%)	10,762	10,746	8,085	10,461	10,498	10,567	10,518	10,492	10,503	10,505	10,500	10,497	10,507	10,504	10,504	10,505	10,511	10,506
Trimble County 2 (75%)	9,369	9,300	6,919	9,177	9,178	9,186	9,185	9,185	9,187	9,185	9,185	9,185	9,185	9,187	9,187	9,187	9,187	9,187
Trimble County 5	13,020	12,985	11,056	10,991	11,083	11,285	11,636	12,186	12,228	12,110	12,090	12,094	12,072	12,057	12,043	12,034	12,034	12,012
Trimble County 6	12,796	11,958	10,791	10,993	11,096	11,313	11,620	12,059	12,499	12,049	12,024	12,029	12,010	12,010	11,980	11,982	11,980	11,955
Trimble County 7	12,849	12,342	11,043	11,013	11,116	11,344	11,605	12,022	12,442	12,037	12,016	12,024	12,006	11,992	11,972	11,966	11,967	11,942
Trimble County 8	12,590	12,854	11,149	11,024	11,119	11,369	11,596	11,873	12,298	11,968	11,967	11,971	11,947	11,934	11,921	11,913	11,912	11,891
Trimble County 9	12,752	12,491	10,664	11,029	11,126	11,367	11,577	11,819	12,161	11,896	11,867	11,882	11,867	11,860	11,840	11,834	11,834	11,809
Trimble County 10	12,513	12,634	11,331	11,049	11,127	11,378	11,568	11,719	11,956	11,818	11,765	11,763	11,755	11,730	11,719	11,707	11,711	11,689
Zom 1	25,887	40,436	20,388	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676
2x1 NGCC	NA	NA	NA	NA	NA	NA	NA	NA	7,082	7,163	7,157	7,168	7,162	7,144	7,132	7,130	7,128	7,109

Scenario: High Gas - Low Load

E.W. Brown 1	12,033	12,407	12,983	10,702	10,699	10,710	10,917	10,738	10,628	10,597	10,630	10,631	10,611	10,623	10,619	10,605	10,593	10,609
E.W. Brown 2	10,729	10,675	11,142	10,509	10,506	10,483	10,592	10,517	10,460	10,434	10,454	10,440	10,436	10,437	10,442	10,436	10,428	10,433
E.W. Brown 3	11,311	11,397	11,646	11,605	11,572	11,535	11,440	11,492	11,404	11,316	11,353	11,321	11,344	11,283	11,326	11,301	11,292	11,299
E.W. Brown 5	24,417	16,513	13,490	12,844	13,264	14,118	14,315	14,262	14,229	14,238	14,141	14,152	14,111	14,081	14,032	14,041	14,035	14,002
E.W. Brown 6	12,536	12,092	10,609	10,980	11,144	11,552	11,646	11,648	11,643	11,630	11,614	11,612	11,601	11,599	11,592	11,575	11,586	11,566
E.W. Brown 7	12,127	11,182	10,605	10,946	11,110	11,398	11,590	11,622	11,619	11,591	11,615	11,674	11,677	11,627	11,655	11,682	11,637	11,600
E.W. Brown 8	20,979	15,416	12,874	13,064	13,272	14,749	15,017	14,955	14,886	14,890	14,867	14,818	14,794	14,743	14,708	14,631	14,690	14,622
E.W. Brown 9	17,924	16,309	13,215	13,531	14,266	14,507	14,320	14,253	14,221	14,379	14,026	14,226	14,142	14,175	14,035	14,196	14,095	14,082
E.W. Brown 10	40,890	15,629	13,004	13,333	13,990	13,960	13,753	13,691	13,666	13,804	13,529	13,654	13,574	13,621	13,497	13,648	13,557	13,552
E.W. Brown 11	30,238	15,911	13,569	12,932	13,011	14,308	14,507	14,441	14,398	14,382	14,377	14,324	14,302	14,331	14,307	14,235	14,292	14,233
Cane Run 4	11,557	11,161	12,588	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 5	10,858	10,845	11,461	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 6	10,868	10,841	11,043	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 7	NA	NA	6980.3	6,861	6,914	7,096	7,157	7,205	7,283	7,391	7,380	7,373	7,384	7,367	7,368	7,347	7,358	7,356
Cane Run 11	42,874	(5,919)	56,474	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117
Ghent 1	10,784	10,823	10,698	10,758	10,768	10,790	10,786	10,801	10,797	10,793	10,798	10,797	10,793	10,793	10,790	10,794	10,790	10,788
Ghent 2	10,696	10,688	10,629	10,515	10,497	10,497	10,497	10,511	10,513	10,512	10,511	10,511	10,515	10,512	10,513	10,514	10,516	10,514
Ghent 3	11,080	10,912	11,003	11,129	11,155	11,112	11,121	11,129	11,132	11,123	11,137	11,130	11,120	11,118	11,125	11,121	11,117	11,115
Ghent 4	11,051	10,912	10,930	10,939	10,938	10,934	10,931	10,952	10,951	10,933	10,947	10,948	10,941	10,935	10,935	10,938	10,931	10,932
Green River 3	12,992	12,961	13,074	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Green River 4	11,155	11,397	10,712	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Haefling 1-2 (2)	29,444	21,195	21,995	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000
Mill Creek 1	10,658	10,464	10,470	10,305	10,338	10,321	10,350	10,381	10,380	10,381	10,378	10,382	10,380	10,381	10,379	10,381	10,378	10,382
Mill Creek 2	10,671	10,693	10,629	10,529	10,554	10,539	10,565	10,568	10,566	10,568	10,568	10,568	10,567	10,568	10,567	10,568	10,566	10,568
Mill Creek 3	10,500	10,674	10,858	10,470	10,500	10,472	10,490	10,511	10,514	10,509	10,510	10,505	10,507	10,508	10,510	10,508	10,509	10,506
Mill Creek 4	10,827	10,836	10,388	10,636	10,641	10,652	10,651	10,651	10,651	10,655	10,652	10,653	10,652	10,652	10,651	10,650	10,652	10,653
Paddy's Run 11&12	(29,554)	28,983	(13,051)	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242
Paddy's Run 13	11,327	11,145	10,809	10,964	10,820	12,163	13,288	13,276	13,225	13,265	13,249	13,250	13,240	13,237	13,206	13,214	13,208	13,181
Trimble County 1 (75%)	10,762	10,746	8,085	10,429	10,473	10,564	10,485	10,450	10,460	10,464	10,457	10,455	10,465	10,463	10,462	10,464	10,472	10,465
Trimble County 2 (75%)	9,369	9,300	6,919	9,177	9,178	9,186	9,185	9,185	9,187	9,185	9,185	9,185	9,185	9,187	9,187	9,187	9,187	9,187
Trimble County 5	13,020	12,985	11,056	11,062	11,169	11,415	11,746	12,370	12,561	12,612	12,586	12,666	12,576	12,544	12,504	12,600	12,500	12,459
Trimble County 6	12,796	11,958	10,791	11,061	11,182	11,450	11,739	12,243	12,628	12,478	12,450	12,507	12,432	12,419	12,368	12,454	12,376	12,334
Trimble County 7	12,849	12,342	11,043	11,081	11,200	11,489	11,733	12,210	12,489	12,304	12,265	12,405	12,326	12,323	12,294	12,331	12,280	12,247
Trimble County 8	12,590	12,854	11,149	11,091	11,204	11,519	11,728	12,057	12,228	12,027	12,030	12,111	12,029	11,998	11,983	12,005	11,976	11,951
Trimble County 9	12,752	12,491	10,664	11,096	11,213	11,520	11,717	12,004	12,077	11,974	11,922	11,956	11,938	11,912	11,892	11,890	11,885	11,856
Trimble County 10	12,513	12,634	11,331	11,121	11,214	11,527	11,711	11,890	11,918	11,892	11,818	11,820	11,812	11,777	11,765	11,754	11,758	11,731
Zorn 1	25,887	40,436	20,388	18,676	18,676	18,876	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676

Scenario: Low Gas - Base Load

E.W. Brown 1	12,033	12,407	12,983	11,522	11,315	10,811	10,700	10,735	10,675	10,641	10,669	10,691	10,656	10,699	10,653	10,644	10,677	10,679
E.W. Brown 2	10,729	10,675	11,142	10,783	10,750	10,496	10,514	10,537	10,508	10,482	10,502	10,473	10,481	10,512	10,481	10,492	10,546	10,504
E.W. Brown 3	11,311	11,397	11,646	11,434	11,583	11,741	11,774	11,745	11,743	11,766	11,769	11,801	11,803	11,704	11,746	11,815	11,804	11,745
E.W. Brown 5	24,417	16,513	13,490	12,509	12,488	12,884	12,964	12,999	13,006	13,036	12,961	12,955	12,912	12,934	12,969	13,183	13,113	12,966
E.W. Brown 6	12,536	12,092	10,609	10,824	11,033	11,225	11,256	11,269	11,248	11,242	11,264	11,245	11,240	11,239	11,237	11,204	11,237	11,276
E.W. Brown 7	12,127	11,182	10,605	10,791	10,973	11,125	11,187	11,180	11,156	11,140	11,185	11,159	11,063	11,142	11,127	11,040	11,135	11,188
E.W. Brown 8	20,979	15,416	12,874	12,702	12,709	12,877	13,196	13,204	13,460	13,357	13,408	13,223	13,224	13,219	13,396	13,582	13,515	13,390
E.W. Brown 9	17,924	16,309	13,215	12,726	12,666	13,132	13,206	13,304	13,419	13,473	13,294	13,323	13,256	13,274	13,314	13,456	13,570	13,302
E.W. Brown 10	40,990	15,629	13,004	12,797	12,875	13,029	13,101	13,167	13,232	13,275	13,131	13,170	13,127	13,139	13,142	13,277	13,348	13,139
E.W. Brown 11	30,238	15,911	13,569	12,704	12,706	12,876	13,163	13,162	13,392	13,274	13,360	13,166	13,165	13,156	13,289	13,454	13,392	13,302
Cane Run 4	11,557	11,161	12,588	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 5	10,858	10,845	11,461	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 6	10,868	10,841	11,043	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 7	NA	NA	6980.3	6,831	6,831	6,840	6,842	6,841	6,840	6,840	6,840	6,842	6,840	6,839	6,840	6,846	6,840	6,839
Cane Run 11	42,874	(5,919)	56,474	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117
Ghent 1	10,784	10,823	10,698	10,752	10,781	10,828	10,813	10,840	10,846	10,834	10,846	10,833	10,835	10,837	10,830	10,818	10,864	10,892
Ghent 2	10,696	10,688	10,629	10,507	10,492	10,498	10,504	10,507	10,511	10,510	10,510	10,505	10,509	10,511	10,506	10,506	10,509	10,512
Ghent 3	11,080	10,912	11,003	11,124	11,165	11,140	11,151	11,166	11,171	11,153	11,169	11,164	11,159	11,159	11,160	11,148	11,164	11,174
Ghent 4	11,051	10,912	10,930	10,942	10,983	10,986	10,990	11,016	11,007	10,997	11,015	11,010	11,005	11,000	11,008	11,003	10,999	11,146
Green River 3	12,992	12,961	13,074	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Green River 4	11,155	11,397	10,712	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Haefling 1-2 (2)	29,444	21,195	21,995	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000
Mill Creek 1	10,658	10,464	10,470	10,290	10,331	10,315	10,331	10,372	10,369	10,369	10,366	10,375	10,372	10,370	10,371	10,378	10,362	10,356
Mill Creek 2	10,671	10,693	10,629	10,516	10,549	10,538	10,559	10,565	10,561	10,564	10,563	10,565	10,564	10,565	10,563	10,566	10,559	10,559
Mill Creek 3	10,500	10,674	10,858	10,466	10,495	10,465	10,476	10,497	10,501	10,493	10,494	10,491	10,488	10,490	10,492	10,494	10,481	10,466
Mill Creek 4	10,827	10,836	10,388	10,633	10,642	10,656	10,652	10,651	10,651	10,651	10,656	10,652	10,653	10,653	10,652	10,651	10,651	10,655
Paddy's Run 11&12	(29,554)	28,983	(13,051)	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242
Paddy's Run 13	11,327	11,145	10,809	10,667	10,627	10,697	10,776	10,865	10,864	10,744	10,815	10,786	10,788	10,836	10,787	10,757	10,744	10,895
Trimble County 1 (75%)	10,762	10,746	8,085	10,406	10,460	10,556	10,463	10,419	10,423	10,426	10,420	10,419	10,424	10,419	10,423	10,430	10,404	10,382
Trimble County 2 (75%)	9,369	9,300	6,919	9,177	9,178	9,186	9,185	9,185	9,187	9,185	9,185	9,185	9,185	9,187	9,187	9,187	9,187	9,187
Trimble County 5	13,020	12,985	11,056	10,906	10,965	11,045	11,131	11,146	11,111	11,119	11,136	11,117	11,105	11,115	11,102	11,080	11,099	11,194
Trimble County 6	12,796	11,958	10,791	10,909	10,989	11,078	11,166	11,184	11,142	11,153	11,169	11,151	11,136	11,145	11,132	11,110	11,135	11,217
Trimble County 7	12,849	12,342	11,043	10,938	10,993	11,113	11,201	11,205	11,172	11,186	11,199	11,183	11,166	11,173	11,160	11,138	11,170	11,238
Trimble County 8	12,590	12,854	11,149	10,951	11,023	11,148	11,234	11,237	11,210	11,211	11,227	11,213	11,206	11,200	11,187	11,165	11,206	11,257
Trimble County 9	12,752	12,491	10,664	10,961	11,033	11,179	11,264	11,267	11,242	11,237	11,251	11,239	11,216	11,224	11,213	11,190	11,242	11,276
Trimble County 10	12,513	12,634	11,331	10,970	11,024	11,217	11,290	11,294	11,271	11,262	11,273	11,273	11,242	11,247	11,236	11,213	11,276	11,295
Zom 1	25,887	40,436	20,388	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676
2x1 NGCC	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	6,618	6,603

Scenario: Low Gas - High Load

E.W. Brown 1	12,033	12,407	12,983	11,456	11,235	10,765	10,658	10,702	10,690	10,661	10,674	10,700	10,677	10,690	10,660	10,669	10,635	10,652
E.W. Brown 2	10,729	10,675	11,142	10,763	10,721	10,475	10,485	10,515	10,524	10,503	10,504	10,490	10,498	10,508	10,487	10,498	10,500	10,488
E.W. Brown 3	11,311	11,397	11,646	11,396	11,547	11,715	11,740	11,717	11,767	11,766	11,741	11,775	11,780	11,709	11,735	11,803	11,732	11,720
E.W. Brown 5	24,417	16,513	13,490	12,473	12,456	12,829	12,908	12,956	13,123	13,004	12,979	12,934	12,919	12,921	12,993	13,211	12,985	12,905
E.W. Brown 6	12,536	12,092	10,609	10,792	11,002	11,174	11,211	11,226	11,194	11,279	11,285	11,274	11,271	11,266	11,264	11,239	11,256	11,242
E.W. Brown 7	12,127	11,182	10,605	10,766	10,952	11,091	11,156	11,147	11,091	11,185	11,205	11,192	11,137	11,181	11,175	11,107	11,167	11,163
E.W. Brown 8	20,979	15,416	12,874	12,674	12,681	12,844	13,127	13,145	13,480	13,389	13,444	13,242	13,252	13,242	13,439	13,644	13,434	13,303
E.W. Brown 9	17,924	16,309	13,215	12,691	12,635	13,083	13,158	13,281	13,709	13,384	13,295	13,256	13,244	13,239	13,309	13,415	13,307	13,236
E.W. Brown 10	40,990	15,629	13,004	12,756	12,646	12,985	13,056	13,144	13,472	13,194	13,132	13,118	13,116	13,114	13,141	13,247	13,139	13,086
E.W. Brown 11	30,238	15,911	13,569	12,676	12,679	12,840	13,094	13,102	13,423	13,302	13,393	13,186	13,189	13,181	13,327	13,507	13,324	13,222
Cane Run 4	11,557	11,161	12,588	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 5	10,858	10,845	11,461	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 6	10,868	10,841	11,043	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 7	NA	NA	6980.3	6,831	6,831	6,840	6,842	6,841	6,840	6,840	6,840	6,842	6,840	6,839	6,840	6,845	6,840	6,839
Cane Run 11	42,874	(5,919)	56,474	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117
Ghent 1	10,784	10,823	10,698	10,750	10,769	10,811	10,798	10,820	10,839	10,846	10,856	10,859	10,869	10,863	10,861	10,830	10,857	10,870
Ghent 2	10,696	10,688	10,629	10,513	10,493	10,503	10,508	10,510	10,506	10,510	10,505	10,504	10,506	10,509	10,507	10,496	10,505	10,509
Ghent 3	11,080	10,912	11,003	11,110	11,146	11,124	11,130	11,147	11,170	11,189	11,203	11,176	11,171	11,178	11,178	11,188	11,173	11,164
Ghent 4	11,051	10,912	10,930	10,924	10,953	10,960	10,957	10,980	10,978	11,018	11,032	11,039	11,046	11,033	11,036	11,006	11,028	11,102
Green River 3	12,992	12,961	13,074	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Green River 4	11,155	11,397	10,712	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Haefling 1-2 (2)	29,444	21,195	21,995	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000
Mill Creek 1	10,658	10,464	10,470	10,296	10,339	10,326	10,342	10,376	10,365	10,358	10,357	10,365	10,358	10,356	10,359	10,371	10,364	10,361
Mill Creek 2	10,671	10,693	10,629	10,517	10,553	10,543	10,561	10,566	10,559	10,557	10,557	10,560	10,558	10,560	10,557	10,563	10,559	10,561
Mill Creek 3	10,500	10,674	10,858	10,468	10,500	10,473	10,485	10,503	10,500	10,481	10,486	10,474	10,472	10,472	10,475	10,482	10,474	10,471
Mill Creek 4	10,827	10,836	10,388	10,632	10,643	10,655	10,652	10,651	10,651	10,656	10,652	10,653	10,653	10,653	10,652	10,651	10,654	10,654
Paddy's Run 11&12	(29,554)	28,983	(13,051)	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242
Paddy's Run 13	11,327	11,145	10,809	10,636	10,591	10,667	10,727	10,817	10,922	10,834	10,895	10,872	10,872	10,901	10,867	10,835	10,849	10,853
Trimble County 1 (75%)	10,762	10,746	8,085	10,413	10,471	10,560	10,481	10,437	10,415	10,395	10,396	10,388	10,393	10,389	10,392	10,398	10,395	10,392
Trimble County 2 (75%)	9,369	9,300	6,919	9,177	9,178	9,186	9,185	9,185	9,187	9,185	9,185	9,185	9,185	9,187	9,187	9,187	9,187	9,187
Trimble County 5	13,020	12,985	11,056	10,872	10,913	10,999	11,070	11,087	11,064	11,190	11,199	11,188	11,174	11,178	11,167	11,146	11,155	11,146
Trimble County 6	12,796	11,958	10,791	10,878	10,939	11,029	11,106	11,126	11,083	11,217	11,223	11,213	11,199	11,201	11,191	11,169	11,180	11,169
Trimble County 7	12,849	12,342	11,043	10,908	10,945	11,059	11,141	11,146	11,119	11,243	11,244	11,235	11,222	11,223	11,213	11,192	11,203	11,191
Trimble County 8	12,590	12,854	11,149	10,922	10,974	11,091	11,173	11,178	11,162	11,260	11,264	11,255	11,253	11,243	11,233	11,213	11,224	11,210
Trimble County 9	12,752	12,491	10,664	10,933	10,987	11,118	11,204	11,208	11,201	11,283	11,281	11,274	11,262	11,261	11,252	11,232	11,243	11,229
Trimble County 10	12,513	12,634	11,331	10,943	10,984	11,154	11,232	11,235	11,240	11,305	11,298	11,300	11,282	11,278	11,269	11,250	11,261	11,247
Zorn 1	25,887	40,436	20,388	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676
2x1 NGCC	NA	NA	NA	NA	NA	NA	NA	NA	6,641	6,616	6,630	6,613	6,610	6,608	6,603	6,626	6,601	6,586

Scenario: Low Gas - Low Load

E.W. Brown 1	12,033	12,407	12,983	11,580	11,393	10,860	10,743	10,767	10,712	10,679	10,703	10,732	10,696	10,726	10,685	10,683	10,655	10,680
E.W. Brown 2	10,729	10,675	11,142	10,800	10,775	10,517	10,542	10,557	10,532	10,510	10,526	10,501	10,508	10,531	10,503	10,515	10,520	10,510
E.W. Brown 3	11,311	11,397	11,646	11,474	11,622	11,764	11,805	11,771	11,768	11,795	11,788	11,825	11,828	11,734	11,774	11,848	11,769	11,758
E.W. Brown 5	24,417	16,513	13,490	12,549	12,521	12,939	13,023	13,041	13,062	13,085	13,025	13,002	12,964	12,977	13,038	13,276	13,033	12,946
E.W. Brown 6	12,536	12,092	10,609	10,859	11,064	11,275	11,301	11,310	11,291	11,288	11,301	11,285	11,280	11,277	11,273	11,243	11,264	11,248
E.W. Brown 7	12,127	11,182	10,605	10,817	10,994	11,159	11,218	11,212	11,190	11,176	11,212	11,190	11,089	11,175	11,160	11,063	11,152	11,157
E.W. Brown 8	20,979	15,416	12,874	12,732	12,740	12,914	13,266	13,265	13,551	13,442	13,498	13,285	13,290	13,282	13,485	13,706	13,482	13,344
E.W. Brown 9	17,924	16,309	13,215	12,761	12,698	13,176	13,256	13,320	13,461	13,519	13,351	13,363	13,307	13,312	13,364	13,516	13,373	13,283
E.W. Brown 10	40,990	15,629	13,004	12,839	12,708	13,073	13,151	13,181	13,264	13,306	13,175	13,199	13,167	13,169	13,179	13,327	13,190	13,122
E.W. Brown 11	30,238	15,911	13,569	12,734	12,733	12,915	13,232	13,222	13,475	13,351	13,446	13,230	13,228	13,219	13,369	13,564	13,369	13,260
Cane Run 4	11,557	11,161	12,588	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 5	10,858	10,845	11,461	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 6	10,868	10,841	11,043	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Cane Run 7	NA	NA	NA	6,831	6,831	6,840	6,843	6,842	6,840	6,840	6,840	6,842	6,840	6,839	6,840	6,847	6,840	6,839
Cane Run 11	42,874	(5,919)	56,474	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117	16,117
Ghent 1	10,784	10,823	10,698	10,751	10,804	10,851	10,835	10,869	10,876	10,864	10,876	10,860	10,864	10,863	10,857	10,841	10,854	10,853
Ghent 2	10,696	10,688	10,629	10,502	10,493	10,496	10,502	10,510	10,515	10,511	10,514	10,507	10,511	10,512	10,507	10,502	10,506	10,511
Ghent 3	11,080	10,912	11,003	11,139	11,187	11,158	11,173	11,186	11,192	11,170	11,189	11,181	11,177	11,178	11,180	11,169	11,172	11,165
Ghent 4	11,051	10,912	10,930	10,966	11,023	11,018	11,033	11,061	11,048	11,036	11,059	11,052	11,050	11,039	11,052	11,043	11,028	11,049
Green River 3	12,992	12,961	13,074	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Green River 4	11,155	11,397	10,712	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Haefling 1-2 (2)	29,444	21,195	21,995	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000
Mill Creek 1	10,658	10,464	10,470	10,286	10,324	10,305	10,321	10,366	10,363	10,364	10,361	10,370	10,366	10,364	10,366	10,375	10,368	10,369
Mill Creek 2	10,671	10,693	10,629	10,514	10,545	10,532	10,557	10,563	10,558	10,561	10,561	10,563	10,562	10,563	10,561	10,565	10,562	10,564
Mill Creek 3	10,500	10,674	10,858	10,466	10,491	10,457	10,468	10,490	10,495	10,486	10,487	10,484	10,481	10,482	10,485	10,486	10,484	10,481
Mill Creek 4	10,827	10,836	10,388	10,637	10,640	10,658	10,652	10,652	10,652	10,657	10,653	10,654	10,654	10,653	10,651	10,651	10,653	10,653
Paddy's Run 11&12	(29,554)	28,983	(13,051)	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242	16,242
Paddy's Run 13	11,327	11,145	10,809	10,699	10,664	10,728	10,829	10,914	10,908	10,791	10,867	10,833	10,837	10,882	10,835	10,801	10,814	10,824
Trimble County 1 (75%)	10,762	10,746	8,085	10,400	10,451	10,551	10,446	10,402	10,404	10,408	10,404	10,402	10,407	10,403	10,406	10,412	10,411	10,406
Trimble County 2 (75%)	9,369	9,300	6,919	9,177	9,178	9,186	9,185	9,185	9,187	9,185	9,185	9,185	9,185	9,187	9,187	9,187	9,187	9,187
Trimble County 5	13,020	12,985	11,056	10,939	11,021	11,097	11,195	11,209	11,173	11,179	11,196	11,178	11,161	11,171	11,157	11,133	11,143	11,135
Trimble County 6	12,796	11,958	10,791	10,939	11,042	11,134	11,231	11,244	11,207	11,214	11,228	11,212	11,193	11,201	11,187	11,163	11,174	11,165
Trimble County 7	12,849	12,342	11,043	10,969	11,044	11,173	11,266	11,268	11,236	11,248	11,257	11,243	11,224	11,230	11,216	11,191	11,204	11,193
Trimble County 8	12,590	12,854	11,149	10,981	11,073	11,212	11,298	11,301	11,274	11,271	11,282	11,271	11,265	11,256	11,243	11,218	11,232	11,219
Trimble County 9	12,752	12,491	10,664	10,991	11,080	11,247	11,327	11,330	11,305	11,297	11,305	11,296	11,272	11,280	11,267	11,243	11,258	11,242
Trimble County 10	12,513	12,634	11,331	11,000	11,066	11,286	11,352	11,355	11,331	11,325	11,325	11,328	11,298	11,301	11,288	11,266	11,280	11,264
Zom 1	25,887	40,436	20,388	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676	18,676

(1) Combustion turbines to be reported as a composite facility.

(2) Haefling 1-2 actuals include Haefling 3

Kentucky Utilities Company and Louisville Gas and Electric Company
 RENEWABLE RESOURCES (MWh)

Sch11

Resource Type (1)	Unit Name	C.O.D.(2)	Build/ Purchase(3)	Life Duration(4)	Size MW (5)	(ACTUAL)			(PROJECTED)																
						2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030		
Hydro	Dix Dam 1-3	11/01/1925	Build	2029+	32	106,623	72,287	97,943	71,000	71,000	71,000	71,000	71,000	71,000	71,000	71,000	71,000	71,000	71,000	71,000	71,000	71,000	71,000	71,000	
Hydro	Ohio Falls 1-8	01/01/1928	Build	2029+	60	193,332	271,888	273,775	234,988	262,834	287,839	287,839	287,839	287,839	287,839	287,839	287,839	287,839	287,839	287,839	287,839	287,839	287,839	287,839	
Solar	Brown Solar	06/01/2016	Planned Build	2029+	9	NA	NA	NA	11,087	15,216	15,216	15,216	15,216	15,216	15,216	15,216	15,216	15,216	15,216	15,216	15,216	15,216	15,216	15,216	
Sub-total					92																				
Total Renewables					92																				

- (1) Per definition of §56-576 of the code of Virginia.
- (2) Commercial operation date.
- (3) Describe as Company built or purchase.
- (4) State expected life of facility or duration of purchase contract.
- (5) Net dependable capability.

10446606

Program Type(1)	Program Name	Date (2)	Life/ Duration(3)	Size MW (4)	(ACTUAL)				
					2006	2007	2008	2009	2010
Energy Efficiency	Residential Conservation Program	1998	2018	11	3,187	8,909	9,969	10,828	12,038
Energy Efficiency	WeCare	2001	2018	5	7,428	11,354	13,481	15,841	17,453
Energy Efficiency	Commercial Conservation/Rebates	1998	2018	156	13,227	17,510	19,469	21,720	53,938
Energy Efficiency	Residential High Efficiency Lighting	2009	2014	26	0	0	142	34,731	113,314
Energy Efficiency	Residential New Construction	2009	2014	6	0	0	0	360	4,441
Energy Efficiency	Residential HVAC Diagnostics & Tune Up	2009	2014	2	0	0	0	699	1,061
Energy Efficiency	Commercial HVAC Diagnostics & Tune Up	2009	2014	1	0	0	0	48	57
Energy Efficiency	Smart Energy Profile	2011	2018	20	0	0	0	0	0
Energy Efficiency	Residential Refrigerator Removal	2011	2018	5	0	0	0	0	0
Energy Efficiency	Residential Incentives	2011	2018	25	0	0	0	0	0
Energy Efficiency	KSBA	2013	2014	0	0	0	0	0	0
subtotal				258	23,842	37,773	43,061	84,228	202,302
Demand Response	Residential Demand Conservation	2008	2018	205	0	0	1,303	4,251	4,043
Demand Response	Commercial Demand Conservation	2008	2018	37	0	0	7	138	137
subtotal				242	0	0	1,310	4,389	4,180
Total				500	23,842	37,773	44,371	88,616	206,482

(1) List each program within the 2 major categories of energy efficiency/conservation/consumption reduction and demand response/peak reduction. Additionally, in the notes provide a description of each.
 (2) Implementation date.
 (3) State expected life of facility or duration of purchase contract.
 (4) Attributable capability and describe in the notes when such reductions are available (i.e. at peak, all hours, on-peak hours, etc.)
 Note: Copy as needed for additional resources.

7600709T

Kentucky Utilities Company and Louisville Gas and Electric Company
Energy Efficiency/Conservation/Demand Side Management/Demand Response (MWh)

Program Type(1)	Program Name	Date (2)	Life/ Duration(3)	Size MW (4)	(ACTUAL)				
					2011	2012	2013	2014	2015
Energy Efficiency	Residential Conservation Program	1998	2018	11	14,049	16,008	23,352	26,801	32,006
Energy Efficiency	WeCare	2001	2018	5	20,411	22,865	25,487	29,829	37,240
Energy Efficiency	Commercial Conservation/Rebates	1998	2018	156	98,628	143,949	202,173	244,729	278,282
Energy Efficiency	Residential High Efficiency Lighting	2009	2014	26	214,217	259,532	308,501	345,520	345,520
Energy Efficiency	Residential New Construction	2009	2014	6	8,398	12,164	17,438	23,244	23,244
Energy Efficiency	Residential HVAC Diagnostics & Tune Up	2009	2014	2	1,798	2,511	3,396	3,609	3,609
Energy Efficiency	Commercial HVAC Diagnostics & Tune Up	2009	2014	1	114	119	123	123	123
Energy Efficiency	Smart Energy Profile	2011	2018	20	0	11,134	31,982	41,474	44,730
Energy Efficiency	Residential Refrigerator Removal	2011	2018	5	0	1,876	9,932	17,850	25,500
Energy Efficiency	Residential Incentives	2011	2018	25	0	8,505	32,587	57,219	77,753
Energy Efficiency	KSBA	2013	2014	0	0	0	12,312	16,577	24,623
subtotal				258	357,615	478,663	667,282	806,974	892,630
Demand Response	Residential Demand Conservation	2008	2018	205	4,043	4,043	4,043	4,043	4,043
Demand Response	Commercial Demand Conservation	2008	2018	37	137	137	137	137	137
subtotal				242	4,180	4,180	4,180	4,180	4,180
Total				500	361,795	482,842	671,462	811,154	896,810

(1) List each program within the 2 major categories of energy efficiency/conservation/consumption reduction and demand re:
 Additionally, in the notes provide a description of each.
 (2) Implementation date.
 (3) State expected life of facility or duration of purchase contract.
 (4) Attributable capability and describe in the notes when such reductions are available (i.e. at peak, all hours, on-peak hours)
 Note: Copy as needed for additional resources.

					(PROJECTED)					
Program Type(1)	Program Name	Date (2)	Life/ Duration(3)	Size MW (4)	2016	2017	2018	2019	2020	2021
Energy Efficiency	Residential Conservation Program	1998	2018	11	37,131	42,295	47,460	47,460	47,460	47,460
Energy Efficiency	WeCare	2001	2018	5	42,770	50,885	60,098	60,098	60,098	60,098
Energy Efficiency	Commercial Conservation/Rebates	1998	2018	156	329,991	374,012	418,033	418,033	418,033	418,033
Energy Efficiency	Residential High Efficiency Lighting	2009	2014	26	345,520	345,520	345,520	345,520	345,520	345,520
Energy Efficiency	Residential New Construction	2009	2014	6	23,244	23,244	23,244	23,244	23,244	23,244
Energy Efficiency	Residential HVAC Diagnostics & Tune Up	2009	2014	2	3,609	3,609	3,609	3,609	3,609	3,609
Energy Efficiency	Commercial HVAC Diagnostics & Tune Up	2009	2014	1	123	123	123	123	123	123
Energy Efficiency	Smart Energy Profile	2011	2018	20	106,475	106,475	106,475	0	0	0
Energy Efficiency	Residential Refrigerator Removal	2011	2018	5	32,850	40,350	47,850	47,850	47,850	47,850
Energy Efficiency	Residential Incentives	2011	2018	25	107,661	132,882	158,103	158,103	158,103	158,103
Energy Efficiency	KSBA	2013	2014	0	0	0	0	0	0	0
subtotal				258	1,029,373	1,119,395	1,210,514	1,104,039	1,104,039	1,104,039
Demand Response	Residential Demand Conservation	2008	2018	205	4,043	4,043	4,043	4,043	4,043	4,043
Demand Response	Commercial Demand Conservation	2008	2018	37	137	137	137	137	137	137
subtotal				242	4,180	4,180	4,180	4,180	4,180	4,180
Total				500	1,033,552	1,123,575	1,214,693	1,108,218	1,108,218	1,108,218

- (1) List each program within the 2 major categories of energy efficiency/conservation/consumption reduction and demand re:
 Additionally, in the notes provide a description of each.
- (2) Implementation date.
- (3) State expected life of facility or duration of purchase contract.
- (4) Attributable capability and describe in the notes when such reductions are available (i.e. at peak, all hours, on-peak hour)
- Note: Copy as needed for additional resources.

Program Type(1)	Program Name	Date (2)	Life/ Duration(3)	Size MW (4)	(PROJECTED)			
					2022	2023	2024	2025
Energy Efficiency	Residential Conservation Program	1998	2018	11	47,460	47,460	47,460	47,460
Energy Efficiency	WeCare	2001	2018	5	60,098	60,098	60,098	60,098
Energy Efficiency	Commercial Conservation/Rebates	1998	2018	156	418,033	418,033	418,033	418,033
Energy Efficiency	Residential High Efficiency Lighting	2009	2014	26	345,520	345,520	345,520	345,520
Energy Efficiency	Residential New Construction	2009	2014	6	23,244	23,244	23,244	23,244
Energy Efficiency	Residential HVAC Diagnostics & Tune Up	2009	2014	2	3,609	3,609	3,609	3,609
Energy Efficiency	Commercial HVAC Diagnostics & Tune Up	2009	2014	1	123	123	123	123
Energy Efficiency	Smart Energy Profile	2011	2018	20	0	0	0	0
Energy Efficiency	Residential Refrigerator Removal	2011	2018	5	47,850	47,850	47,850	47,850
Energy Efficiency	Residential Incentives	2011	2018	25	158,103	158,103	158,103	158,103
Energy Efficiency	KSBA	2013	2014	0	0	0	0	0
subtotal				258	1,104,039	1,104,039	1,104,039	1,104,039
Demand Response	Residential Demand Conservation	2008	2018	205	4,043	4,043	4,043	4,043
Demand Response	Commercial Demand Conservation	2008	2018	37	137	137	137	137
subtotal				242	4,180	4,180	4,180	4,180
Total				500	1,108,218	1,108,218	1,108,218	1,108,218

(1) List each program within the 2 major categories of energy efficiency/conservation/consumption reduction and demand re:
 Additionally, in the notes provide a description of each.
 (2) Implementation date.
 (3) State expected life of facility or duration of purchase contract.
 (4) Attributable capability and describe in the notes when such reductions are available (i.e. at peak, all hours, on-peak hours)
 Note: Copy as needed for additional resources.

Kentucky Utilities Company and Louisville Gas and Electric Company
 UNIT PERFORMANCE DATA (1)

Sch13

Unit Size (MW) Uprate and Derate

Unit Name	(ACTUAL)			(PROJECTED)														
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
E.W. Brown 1																		
E.W. Brown 2																		
E.W. Brown 3		-2			-3													
E.W. Brown 5			-3															
E.W. Brown 6																		
E.W. Brown 7																		
E.W. Brown 8																		
E.W. Brown 9																		
E.W. Brown 10																		
E.W. Brown 11																		
E.W. Brown Solar					8													
Cane Run 4			-155															
Cane Run 5			-168															
Cane Run 6			-240															
Cane Run 7			668															
Cane Run 11																		
Dix Dam 1-3			2															
Ghent 1			-5															
Ghent 2																		
Ghent 3		-6	-4															
Ghent 4			-4															
Green River 3			-68															
Green River 4		-2	-83															
Haefling 1-3		-12																
Mill Creek 1			-3															
Mill Creek 2			-4															
Mill Creek 3					-8													
Mill Creek 4																		
Ohio Falls 1		2																
Ohio Falls 2			2															
Ohio Falls 3		2																
Ohio Falls 4					2													
Ohio Falls 5			2															
Ohio Falls 6																		
Ohio Falls 7																		
Ohio Falls 8					2													
Paddy's Run 11																		
Paddy's Run 12																		
Paddy's Run 13																		
Trimble County 1 (75%)					-4													
Trimble County 2 (75%)																		
Trimble County 5			2															
Trimble County 6			2															
Trimble County 7			2															
Trimble County 8			2															
Trimble County 9			2															
Trimble County 10			2															
Tyrone 3		-71																
Zorn 1																		

(1) Combustion turbines to be reported as composite facility.

160074091

**Kentucky Utilities Company and Louisville Gas and Electric Company
UNIT PERFORMANCE DATA (1)**

Sch14

Existing Supply-side Resource (MW)

<u>Unit Name</u>	<u>Location</u>	<u>Unit Type</u>	<u>Primary Fuel Type</u>	<u>C.O.D. (2)</u>	<u>Size MW (3)</u>
E.W. Brown 1	Harrodsburg, KY	Steam	Coal	05/01/1957	106
E.W. Brown 2	Harrodsburg, KY	Steam	Coal	06/01/1963	166
E.W. Brown 3	Harrodsburg, KY	Steam	Coal	07/01/1971	410
E.W. Brown 5	Harrodsburg, KY	Turbine	Gas	06/08/2001	130
E.W. Brown 6	Harrodsburg, KY	Turbine	Gas	08/11/1999	146
E.W. Brown 7	Harrodsburg, KY	Turbine	Gas	08/08/1999	146
E.W. Brown 8	Harrodsburg, KY	Turbine	Gas	02/01/1995	121
E.W. Brown 9	Harrodsburg, KY	Turbine	Gas	08/01/1994	121
E.W. Brown 10	Harrodsburg, KY	Turbine	Gas	12/01/1995	121
E.W. Brown 11	Harrodsburg, KY	Turbine	Gas	05/01/1996	121
Cane Run 7	Louisville, KY	Turbine	Gas	06/19/2015	668
Cane Run 11	Louisville, KY	Turbine	Gas	06/01/1968	14
Dix Dam 1-3	Harrodsburg, KY	Hydro	Hydro	11/01/1925	32
Ghent 1	Ghent, KY	Steam	Coal	02/01/1974	474
Ghent 2	Ghent, KY	Steam	Coal	04/01/1977	495
Ghent 3	Ghent, KY	Steam	Coal	05/01/1981	485
Ghent 4	Ghent, KY	Steam	Coal	08/01/1984	465
Haefling 1-2	Lexington, KY	Turbine	Gas	10/01/1970	24
Mill Creek 1	Louisville, KY	Steam	Coal	08/01/1972	300
Mill Creek 2	Louisville, KY	Steam	Coal	07/01/1974	297
Mill Creek 3	Louisville, KY	Steam	Coal	08/01/1978	391
Mill Creek 4	Louisville, KY	Steam	Coal	09/01/1982	477
Ohio Falls 1-8	Louisville, KY	Hydro	Hydro	01/01/1928	60
Paddy's Run 11	Louisville, KY	Turbine	Gas	06/01/1968	12
Paddy's Run 12	Louisville, KY	Turbine	Gas	07/01/1968	23
Paddy's Run 13	Louisville, KY	Turbine	Gas	06/27/2001	147
Trimble County 1 (75%)	Bedford, KY	Steam	Coal	12/23/1990	383
Trimble County 2 (75%)	Bedford, KY	Steam	Coal	01/22/2011	549
Trimble County 5	Bedford, KY	Turbine	Gas	05/14/2002	159
Trimble County 6	Bedford, KY	Turbine	Gas	05/14/2002	159
Trimble County 7	Bedford, KY	Turbine	Gas	06/01/2004	159
Trimble County 8	Bedford, KY	Turbine	Gas	06/01/2004	159
Trimble County 9	Bedford, KY	Turbine	Gas	07/01/2004	159
Trimble County 10	Bedford, KY	Turbine	Gas	07/01/2004	159
Zorn 1	Louisville, KY	Turbine	Gas	05/01/1969	14

(1) Combustion turbines to be reported as a composite facility.

(2) Commercial operation date.

(3) Peak net dependable capability as of filing.

UNIT PERFORMANCE DATA (1)

Planned Supply-side Resource (MW)

Scenario: Mid Gas - Base Load

<u>Unit Name</u>	<u>Location</u>	<u>Unit Type</u>	<u>Primary Fuel Type</u>	<u>C.O.D. (2)</u>	<u>Size MW (3)</u>
2x1 NGCC	Unknown	Turbine	Natural Gas	2029	739

Scenario: Mid Gas - High Load

<u>Unit Name</u>	<u>Location</u>	<u>Unit Type</u>	<u>Primary Fuel Type</u>	<u>C.O.D. (2)</u>	<u>Size MW (3)</u>
2x1 NGCC	Unknown	Turbine	Natural Gas	2021	739

Scenario: Mid Gas - Low Load

<u>Unit Name</u>	<u>Location</u>	<u>Unit Type</u>	<u>Primary Fuel Type</u>	<u>C.O.D. (2)</u>	<u>Size MW (3)</u>
NA	NA	NA	NA	NA	NA

Scenario: High Gas - Base Load

<u>Unit Name</u>	<u>Location</u>	<u>Unit Type</u>	<u>Primary Fuel Type</u>	<u>C.O.D. (2)</u>	<u>Size MW (3)</u>
SCCT	Unknown	Turbine	Natural Gas	2029	200

Scenario: High Gas - High Load

<u>Unit Name</u>	<u>Location</u>	<u>Unit Type</u>	<u>Primary Fuel Type</u>	<u>C.O.D. (2)</u>	<u>Size MW (3)</u>
2x1 NGCC	Unknown	Turbine	Natural Gas	2021	739

Scenario: High Gas - Low Load

<u>Unit Name</u>	<u>Location</u>	<u>Unit Type</u>	<u>Primary Fuel Type</u>	<u>C.O.D. (2)</u>	<u>Size MW (3)</u>
NA	NA	NA	NA	NA	NA

Scenario: Low Gas - Base Load

<u>Unit Name</u>	<u>Location</u>	<u>Unit Type</u>	<u>Primary Fuel Type</u>	<u>C.O.D. (2)</u>	<u>Size MW (3)</u>
2x1 NGCC	Unknown	Turbine	Natural Gas	2029	739

Scenario: Low Gas - High Load

<u>Unit Name</u>	<u>Location</u>	<u>Unit Type</u>	<u>Primary Fuel Type</u>	<u>C.O.D. (2)</u>	<u>Size MW (3)</u>
2x1 NGCC	Unknown	Turbine	Natural Gas	2021	739

Scenario: Low Gas - Low Load

<u>Unit Name</u>	<u>Location</u>	<u>Unit Type</u>	<u>Primary Fuel Type</u>	<u>C.O.D. (2)</u>	<u>Size MW (3)</u>
NA	NA	NA	NA	NA	NA

(1) Combustion turbines to be reported as a composite facility.

(2) Commercial operation date.

(3) Peak net dependable capability as of filing.

Kentucky Utilities Company and Louisville Gas and Electric Company
UNIT CAPACITY POSITION (MW)

Sch16

	(ACTUAL)			(PROJECTED)															
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
Scenario: Mid Gas - Base Load																			
Existing Capacity																			
Conventional	7,827	7,821	8,097	8,097	8,084	8,084	8,084	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	8,658	
Renewable	86	88	92	92	100	104	104	104	104	104	104	104	104	104	104	104	104	104	
Total Existing Capacity	7,913	7,909	8,189	8,189	8,184	8,188	8,188	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,762	
Planned Capacity Changes																			
Conventional (1)	0	0	0	-13	0	0	-165	0	0	0	0	0	0	0	0	0	0	0	
Renewable	0	0	0	0	4	0	0	0	0	0	0	0	0	0	0	0	0	0	
Total Planned Capacity Changes	0	0	0	-13	4	0	-165	0	0	0	0	0	0	0	0	0	0	0	
Expected New Capacity																			
Conventional	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	739	0	
Renewable	0	0	0	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Total Expected New Capacity	0	0	0	8	0	0	0	0	0	0	0	0	0	0	0	0	739	0	
Unforced Availability																			
	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
Net Generation Capacity																			
	7,913	7,909	8,189	8,184	8,188	8,188	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,762	8,762	
Existing DSM Reductions																			
Demand response	0	0	0	343	357	372	380	380	380	380	380	380	380	380	380	380	380	380	
Conservation/Efficiency	0	0	0	201	221	244	246	235	235	235	235	235	235	235	235	235	235	235	
Total Existing DSM Reductions	0	0	0	544	578	617	626	616	616	616	616	616	616	616	616	616	616	616	
Expected New DSM Reductions																			
Demand response	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Conservation/Efficiency	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Total Expected New DSM Reductions	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Total Demand-side Reductions																			
	0	0	0	544	578	617	626	616	616	616	616	616	616	616	616	616	616	616	
Net Generation & Demand-side																			
	7,913	7,909	8,189	8,728	8,766	8,804	8,649	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	9,377	9,377	
Capacity Requirement or PJM Capacity Obligation																			
	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Net Utility Capacity Position																			
	7,913	7,909	8,189	8,728	8,766	8,804	8,649	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	9,377	9,377	

16007097

Scenario: Mid Gas - Low Load

Existing Capacity

Conventional	7,827	7,821	8,097	8,097	8,084	8,084	8,084	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	8,658
Renewable	86	88	92	92	100	104	104	104	104	104	104	104	104	104	104	104	104	104
Total Existing Capacity	7,913	7,909	8,189	8,189	8,184	8,188	8,188	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,762

Planned Capacity Changes

Conventional (1)	0	0	0	-13	0	0	-165	0	0	0	0	0	0	0	0	0	0	0
Renewable	0	0	0	0	4	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Planned Capacity Changes	0	0	0	-13	4	0	-165	0	0	0	0	0	0	0	0	0	0	0

Expected New Capacity

Conventional	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Renewable	0	0	0	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Expected New Capacity	0	0	0	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Unforced Availability

	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
--	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----

Net Generation Capacity

	7,913	7,909	8,189	8,184	8,188	8,188	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,762
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Existing DSM Reductions

Demand response	0	0	0	343	357	372	380	380	380	380	380	380	380	380	380	380	380	380
Conservation/Efficiency	0	0	0	201	221	244	246	235	235	235	235	235	235	235	235	235	235	235
Total Existing DSM Reductions	0	0	0	544	578	617	626	616	616	616	616	616	616	616	616	616	616	616

Expected New DSM Reductions

Demand response	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Conservation/Efficiency	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Expected New DSM Reductions	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Total Demand-side Reductions

	0	0	0	544	578	617	626	616	616	616	616	616	616	616	616	616	616	616
--	---	---	---	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Net Generation & Demand-side

	7,913	7,909	8,189	8,728	8,766	8,804	8,649	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	9,377
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

**Capacity Requirement or
PJM Capacity Obligation**

	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
--	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

Net Utility Capacity Position

	7,913	7,909	8,189	8,728	8,766	8,804	8,649	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	9,377
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Scenario: High Gas - Base Load

Existing Capacity

Conventional	7,827	7,821	8,097	8,097	8,084	8,084	8,084	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	8,658
Renewable	86	88	92	92	100	104	104	104	104	104	104	104	104	104	104	104	104	104	104
Total Existing Capacity	7,913	7,909	8,189	8,189	8,184	8,188	8,188	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,762

Planned Capacity Changes

Conventional (1)	0	0	0	-13	0	0	-165	0	0	0	0	0	0	0	0	0	0	0	0
Renewable	0	0	0	0	4	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Planned Capacity Changes	0	0	0	-13	4	0	-165	0	0	0	0	0	0	0	0	0	0	0	0

Expected New Capacity

Conventional	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	200	0	
Renewable	0	0	0	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Total Expected New Capacity	0	0	0	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	200	0.0

Unforced Availability

	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
--	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----

Net Generation Capacity

	7,913	7,909	8,189	8,184	8,188	8,188	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,223	8,762
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Existing DSM Reductions

Demand response	0	0	0	343	357	372	380	380	380	380	380	380	380	380	380	380	380	380	380
Conservation/Efficiency	0	0	0	201	221	244	246	235	235	235	235	235	235	235	235	235	235	235	235
Total Existing DSM Reductions	0	0	0	544	578	617	626	616	616	616	616	616	616	616	616	616	616	616	616

Expected New DSM Reductions

Demand response	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Conservation/Efficiency	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Expected New DSM Reductions	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Total Demand-side Reductions

	0	0	0	544	578	617	626	616	616	616	616	616	616	616	616	616	616	616	616
--	---	---	---	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Net Generation & Demand-side

	7,913	7,909	8,189	8,728	8,766	8,804	8,649	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,838	9,377
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Capacity Requirement or PJM Capacity Obligation

	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
--	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

Net Utility Capacity Position

	7,913	7,909	8,189	8,728	8,766	8,804	8,649	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,838	9,377
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Scenario: High Gas - High Load

Existing Capacity

Conventional	7,827	7,821	8,097	8,097	8,084	8,084	8,084	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	8,658
Renewable	86	88	92	92	100	104	104	104	104	104	104	104	104	104	104	104	104	104
Total Existing Capacity	7,913	7,909	8,189	8,189	8,184	8,188	8,188	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,762

Planned Capacity Changes

Conventional (1)	0	0	0	-13	0	0	-165	0	0	0	0	0	0	0	0	0	0	0
Renewable	0	0	0	0	4	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Planned Capacity Changes	0	0	0	-13	4	0	-165	0	0	0	0	0	0	0	0	0	0	0

Expected New Capacity

Conventional	0	0	0	0	0	0	0	0	739	0	0	0	0	0	0	0	0	0
Renewable	0	0	0	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Expected New Capacity	0	0	0	8	0	0	0	0	739	0	0	0	0	0	0	0	0	0

Unforced Availability

	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
--	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----

Net Generation Capacity

	7,913	7,909	8,189	8,184	8,188	8,188	8,023	8,023	8,762	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,762
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Existing DSM Reductions

Demand response	0	0	0	343	357	372	380	380	380	380	380	380	380	380	380	380	380	380
Conservation/Efficiency	0	0	0	201	221	244	246	235	235	235	235	235	235	235	235	235	235	235
Total Existing DSM Reductions	0	0	0	544	578	617	626	616	616	616	616	616	616	616	616	616	616	616

Expected New DSM Reductions

Demand response	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Conservation/Efficiency	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Expected New DSM Reductions	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Total Demand-side Reductions

	0	0	0	544	578	617	626	616	616	616	616	616	616	616	616	616	616	616
--	---	---	---	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Net Generation & Demand-side

	7,913	7,909	8,189	8,728	8,766	8,804	8,649	8,638	9,377	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	9,377
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

**Capacity Requirement or
PJM Capacity Obligation**

	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
--	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

Net Utility Capacity Position

	7,913	7,909	8,189	8,728	8,766	8,804	8,649	8,638	9,377	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	9,377
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Scenario: High Gas - Low Load

	7,827	7,821	8,097	8,097	8,084	8,084	8,084	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	8,658
Existing Capacity																		
Conventional	7,827	7,821	8,097	8,097	8,084	8,084	8,084	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	8,658
Renewable	86	88	92	92	100	104	104	104	104	104	104	104	104	104	104	104	104	104
Total Existing Capacity	7,913	7,909	8,189	8,189	8,184	8,188	8,188	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,762
Planned Capacity Changes																		
Conventional (1)	0	0	0	-13	0	0	-165	0	0	0	0	0	0	0	0	0	0	0
Renewable	0	0	0	0	4	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Planned Capacity Changes	0	0	0	-13	4	0	-165	0	0	0	0	0	0	0	0	0	0	0
Expected New Capacity																		
Conventional	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Renewable	0	0	0	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Expected New Capacity	0	0	0	8	0	0	0	0	0	0.0	0	0	0	0	0	0	0	0
Unforced Availability	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Net Generation Capacity	7,913	7,909	8,189	8,184	8,188	8,188	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,762
Existing DSM Reductions																		
Demand response	0	0	0	343	357	372	380	380	380	380	380	380	380	380	380	380	380	380
Conservation/Efficiency	0	0	0	201	221	244	246	235	235	235	235	235	235	235	235	235	235	235
Total Existing DSM Reductions	0	0	0	544	578	617	626	616	616	616	616	616	616	616	616	616	616	616
Expected New DSM Reductions																		
Demand response	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Conservation/Efficiency	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Expected New DSM Reductions	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Demand-side Reductions	0	0	0	544	578	617	626	616	616	616	616	616	616	616	616	616	616	616
Net Generation & Demand-side	7,913	7,909	8,189	8,728	8,766	8,804	8,649	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	9,377
Capacity Requirement or PJM Capacity Obligation	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Net Utility Capacity Position	7,913	7,909	8,189	8,728	8,766	8,804	8,649	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	9,377

Scenario: Low Gas - Base Load

Existing Capacity

Conventional	7,827	7,821	8,097	8,097	8,084	8,084	8,084	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	8,658
Renewable	86	88	92	92	100	104	104	104	104	104	104	104	104	104	104	104	104	104
Total Existing Capacity	7,913	7,909	8,189	8,189	8,184	8,188	8,188	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,762

Planned Capacity Changes

Conventional (1)	0	0	0	-13	0	0	-165	0	0	0	0	0	0	0	0	0	0	0
Renewable	0	0	0	0	4	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Planned Capacity Changes	0	0	0	-13	4	0	-165	0	0	0	0	0	0	0	0	0	0	0

Expected New Capacity

Conventional	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	739	0
Renewable	0	0	0	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Expected New Capacity	0	0	0	8	0	0	0	0	0	0	0	0	0	0	0	0	739	0

Unforced Availability

	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
--	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----

Net Generation Capacity

	7,913	7,909	8,189	8,184	8,188	8,188	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,762	8,762
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Existing DSM Reductions

Demand response	0	0	0	343	357	372	380	380	380	380	380	380	380	380	380	380	380	380
Conservation/Efficiency	0	0	0	201	221	244	246	235	235	235	235	235	235	235	235	235	235	235
Total Existing DSM Reductions	0	0	0	544	578	617	626	616	616	616	616	616	616	616	616	616	616	616

Expected New DSM Reductions

Demand response	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Conservation/Efficiency	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Expected New DSM Reductions	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Total Demand-side Reductions

	0	0	0	544	578	617	626	616	616	616	616	616	616	616	616	616	616	616
--	---	---	---	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Net Generation & Demand-side

	7,913	7,909	8,189	8,728	8,766	8,804	8,649	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	9,377	9,377
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Capacity Requirement or PJM Capacity Obligation

	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
--	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

Net Utility Capacity Position

	7,913	7,909	8,189	8,728	8,766	8,804	8,649	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	9,377	9,377
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Scenario: Low Gas - High Load

Existing Capacity

Conventional	7,827	7,821	8,097	8,097	8,084	8,084	8,084	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	8,658
Renewable	86	88	92	92	100	104	104	104	104	104	104	104	104	104	104	104	104	104
Total Existing Capacity	7,913	7,909	8,189	8,189	8,184	8,188	8,188	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,762

Planned Capacity Changes

Conventional (1)	0	0	0	-13	0	0	-165	0	0	0	0	0	0	0	0	0	0	0
Renewable	0	0	0	0	4	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Planned Capacity Changes	0	0	0	-13	4	0	-165	0	0	0	0	0	0	0	0	0	0	0

Expected New Capacity

Conventional	0	0	0	0	0	0	0	0	739	0	0	0	0	0	0	0	0	0
Renewable	0	0	0	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Expected New Capacity	0	0	0	8	0	0	0	0	739	0	0	0	0	0	0	0	0	0

Unforced Availability

	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
--	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----

Net Generation Capacity

	7,913	7,909	8,189	8,184	8,188	8,188	8,023	8,023	8,762	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,762
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Existing DSM Reductions

Demand response	0	0	0	343	357	372	380	380	380	380	380	380	380	380	380	380	380	380
Conservation/Efficiency	0	0	0	201	221	244	246	235	235	235	235	235	235	235	235	235	235	235
Total Existing DSM Reductions	0	0	0	544	578	617	626	616	616	616	616	616	616	616	616	616	616	616

Expected New DSM Reductions

Demand response	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Conservation/Efficiency	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Expected New DSM Reductions	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Total Demand-side Reductions

	0	0	0	544	578	617	626	616	616	616	616	616	616	616	616	616	616	616
--	---	---	---	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Net Generation & Demand-side

	7,913	7,909	8,189	8,728	8,766	8,804	8,649	8,638	9,377	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	9,377
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

**Capacity Requirement or
PJM Capacity Obligation**

	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
--	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

Net Utility Capacity Position

	7,913	7,909	8,189	8,728	8,766	8,804	8,649	8,638	9,377	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	9,377
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Scenario: Low Gas - Low Load

Existing Capacity																		
Conventional	7,827	7,821	8,097	8,097	8,084	8,084	8,084	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	7,919	8,658
Renewable	86	88	92	92	100	104	104	104	104	104	104	104	104	104	104	104	104	104
Total Existing Capacity	7,913	7,909	8,189	8,189	8,184	8,188	8,188	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,762
Planned Capacity Changes																		
Conventional (1)	0	0	0	-13	0	0	-165	0	0	0	0	0	0	0	0	0	0	0
Renewable	0	0	0	0	4	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Planned Capacity Changes	0	0	0	-13	4	0	-165	0	0	0	0	0	0	0	0	0	0	0
Expected New Capacity																		
Conventional	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Renewable	0	0	0	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Expected New Capacity	0	0	0	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Unforced Availability	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Net Generation Capacity	7,913	7,909	8,189	8,184	8,188	8,188	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,023	8,762
Existing DSM Reductions																		
Demand response	0	0	0	343	357	372	380	380	380	380	380	380	380	380	380	380	380	380
Conservation/Efficiency	0	0	0	201	221	244	246	235	235	235	235	235	235	235	235	235	235	235
Total Existing DSM Reductions	0	0	0	544	578	617	626	616	616	616	616	616	616	616	616	616	616	616
Expected New DSM Reductions																		
Demand response	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Conservation/Efficiency	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Expected New DSM Reductions	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Demand-side Reductions	0	0	0	544	578	617	626	616	616	616	616	616	616	616	616	616	616	616
Net Generation & Demand-side	7,913	7,909	8,189	8,728	8,766	8,804	8,649	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	9,377
Capacity Requirement or PJM Capacity Obligation																		
	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Net Utility Capacity Position	7,913	7,909	8,189	8,728	8,766	8,804	8,649	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	8,638	9,377

(1) In 2014, Planned Capacity Changes for Conventional resources include updates to unit rating assumptions.

Kentucky Utilities Company and Louisville Gas and Electric Company
CONSTRUCTION FORECAST (Million Dollars)

Sch17

	ACTUAL EXPENDITURES			PROJECTED EXPENDITURES (1)														
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
I. New Traditional Generating Facilities																		
a. Capital Investment (Exclusive of AFUDC)	0	0	0	222	281	346	271	262	0	0	0	0	0	0	0	0	0	0
b. AFUDC	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
c. Annual Total	0	0	0	222	281	346	271	262	0	0	0	0	0	0	0	0	0	0
d. Cumulative Total	0	0	0	222	503	849	1120	1382	1382	1382	1382	1382	1382	1382	1382	1382	1382	1382
II. New Renewable Generating Facilities (2)																		
a. Capital Investment (Exclusive of AFUDC)	0	0	0	6	0	0	0	0	0	0	0	0	0	0	0	0	0	0
b. AFUDC	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
c. Annual Total	0	0	0	6	0	0	0	0	0	0	0	0	0	0	0	0	0	0
d. Cumulative Total	0	0	0	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6
III. Other Facilities																		
a. Transmission	38	40	39	68	79	82	83	149	0	0	0	0	0	0	0	0	0	0
b. Distribution	59	72	55	93	109	103	121	122	0	0	0	0	0	0	0	0	0	0
c. Energy conservation/efficiency & demand response	131	705	933	39	40	33	28	30	0	0	0	0	0	0	0	0	0	0
d. AFUDC	-	-	-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
e. Annual Total	228	817	1,027	200	228	218	232	301	-	-	-	-	-	-	-	-	-	-
f. Cumulative Total	228	1,045	2,073	200	428	646	878	1179	1179	1179	1179	1179	1179	1179	1179	1179	1179	1179
IV. Total Construction Expenditures																		
a. Annual	228	817	1,027	428	509	564	503	563	0	0	0	0	0	0	0	0	0	0
b. Cumulative	228	1,045	2,073	428	937	1501	2004	2567	2567	2567	2567	2567	2567	2567	2567	2567	2567	2567
V. Percent of Funds for Total Construction																		
Provided from External Financing (3)	45%	38%	46%	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

(1) This information is provided for 2016-2019 and represents major generation and environmental projects at the Cane Run, Trimble County, Green River, and E.W. Brown facilities
(2) Construction of a 10 MW solar photovoltaic facility at the E.W. Brown facility
(3) Actual expenses for 2013-2015 include generation, distribution, transmission, environmental, and other capital projects
(4) Represents year ending total debt divided by total capitalization

160077091

CONFIDENTIAL INFORMATION REDACTED

Scenario: Mid Gas - Base Load	(ACTUAL)			(PROJECTED)																
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030		
Delivered Fuel Price (cents/MBtu)*	[REDACTED]																			
a. Nuclear																				
b. Coal																				
c. Heavy Fuel Oil																				
d. Light Fuel Oil																				
e. Natural Gas																				
f. Renewable**																				
Primary Fuel Expenses (cents/kWh)*	[REDACTED]																			
a. Nuclear																				
b. Coal																				
c. Heavy Fuel Oil																				
d. Light Fuel Oil																				
e. Natural Gas																				
f. Renewable**																				
g. Purchases Energy Charges Only																				
h. Purchases Energy and Capacity Charges																				
Scenario: Mid Gas - High Load	(ACTUAL)			(PROJECTED)																
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030		
Delivered Fuel Price (cents/MBtu)*	[REDACTED]																			
a. Nuclear																				
b. Coal																				
c. Heavy Fuel Oil																				
d. Light Fuel Oil																				
e. Natural Gas																				
f. Renewable**																				
Primary Fuel Expenses (cents/kWh)*	[REDACTED]																			
a. Nuclear																				
b. Coal																				
c. Heavy Fuel Oil																				
d. Light Fuel Oil																				
e. Natural Gas																				
f. Renewable**																				
g. Purchases Energy Charges Only																				
h. Purchases Energy and Capacity Charges																				

* To reflect total dispatch costs, including any variable O and environmental or compliance costs.
 ** Per definition of §56-576 of the Code of Virginia.

CONFIDENTIAL INFORMATION HIGHLIGHTED

2016 IRP

Kentucky Utilities Company and Louisville Gas and Electric Company
FUEL DATA

Sch18

CONFIDENTIAL INFORMATION REDACTED

Scenario: Mid Gas - Low Load

(ACTUAL)

(PROJECTED)

2013 2014 2015 2016 2017 2018 2019 2020 2021 2022 2023 2024 2025 2026 2027 2028 2029 2030

Delivered Fuel Price (cents/MBtu)*

- a. Nuclear
- b. Coal
- c. Heavy Fuel Oil
- d. Light Fuel Oil
- e. Natural Gas
- f. Renewable**

[REDACTED]																
------------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

Primary Fuel Expenses (cents/kWh)*

- a. Nuclear
- b. Coal
- c. Heavy Fuel Oil
- d. Light Fuel Oil
- e. Natural Gas
- f. Renewable**
- g. Purchases Energy Charges Only
- h. Purchases Energy and Capacity Charges

[REDACTED]																
------------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

Scenario: High Gas - Base Load

(ACTUAL)

(PROJECTED)

2013 2014 2015 2016 2017 2018 2019 2020 2021 2022 2023 2024 2025 2026 2027 2028 2029 2030

Delivered Fuel Price (cents/MBtu)*

- a. Nuclear
- b. Coal
- c. Heavy Fuel Oil
- d. Light Fuel Oil
- e. Natural Gas
- f. Renewable**

[REDACTED]																
------------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--


Primary Fuel Expenses (cents/kWh)*

- a. Nuclear
- b. Coal
- c. Heavy Fuel Oil
- d. Light Fuel Oil
- e. Natural Gas
- f. Renewable**
- g. Purchases Energy Charges Only
- h. Purchases Energy and Capacity Charges

[REDACTED]																
------------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

* To reflect total dispatch costs, including any variable O and environmental or compliance costs.
 ** Per definition of §56-576 of the Code of Virginia.

CONFIDENTIAL INFORMATION HIGHLIGHTED



2016 IRP

Kentucky Utilities Company and Louisville Gas and Electric Company
 FUEL DATA

Sch18

CONFIDENTIAL INFORMATION REDACTED

Scenario: High Gas - High Load

(ACTUAL)

(PROJECTED)

2013 2014 2015 2016 2017 2018 2019 2020 2021 2022 2023 2024 2025 2026 2027 2028 2029 2030

Delivered Fuel Price (cents/MBtu)*

a. Nuclear	[REDACTED]																
b. Coal	[REDACTED]																
c. Heavy Fuel Oil	[REDACTED]																
d. Light Fuel Oil	[REDACTED]																
e. Natural Gas	[REDACTED]																
f. Renewable**	[REDACTED]																

Primary Fuel Expenses (cents/kWh)*

a. Nuclear	[REDACTED]																
b. Coal	[REDACTED]																
c. Heavy Fuel Oil	[REDACTED]																
d. Light Fuel Oil	[REDACTED]																
e. Natural Gas	[REDACTED]																
f. Renewable**	[REDACTED]																
g. Purchases Energy Charges Only	[REDACTED]																
h. Purchases Energy and Capacity Charges	[REDACTED]																

Scenario: High Gas - Low Load

(ACTUAL)

(PROJECTED)

2013 2014 2015 2016 2017 2018 2019 2020 2021 2022 2023 2024 2025 2026 2027 2028 2029 2030

Delivered Fuel Price (cents/MBtu)*

a. Nuclear	[REDACTED]																
b. Coal	[REDACTED]																
c. Heavy Fuel Oil	[REDACTED]																
d. Light Fuel Oil	[REDACTED]																
e. Natural Gas	[REDACTED]																
f. Renewable**	[REDACTED]																

Primary Fuel Expenses (cents/kWh)*

a. Nuclear	[REDACTED]																
b. Coal	[REDACTED]																
c. Heavy Fuel Oil	[REDACTED]																
d. Light Fuel Oil	[REDACTED]																
e. Natural Gas	[REDACTED]																
f. Renewable**	[REDACTED]																
g. Purchases Energy Charges Only	[REDACTED]																
h. Purchases Energy and Capacity Charges	[REDACTED]																

* To reflect total dispatch costs, including any variable O and environmental or compliance costs.
 ** Per definition of §56-576 of the Code of Virginia.

CONFIDENTIAL INFORMATION HIGHLIGHTED

76007091

2016 IRP

Kentucky Utilities Company and Louisville Gas and Electric Company
 FUEL DATA

Sch18

CONFIDENTIAL INFORMATION REDACTED

Scenario: Low Gas - Base Load	(ACTUAL)			(PROJECTED)																
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030		
Delivered Fuel Price (cents/MBtu)*	[REDACTED]																			
a. Nuclear																				
b. Coal																				
c. Heavy Fuel Oil																				
d. Light Fuel Oil																				
e. Natural Gas																				
f. Renewable**																				
Primary Fuel Expenses (cents/kWh)*	[REDACTED]																			
a. Nuclear																				
b. Coal																				
c. Heavy Fuel Oil																				
d. Light Fuel Oil																				
e. Natural Gas																				
f. Renewable**																				
g. Purchases Energy Charges Only																				
h. Purchases Energy and Capacity Charges																				
Scenario: Low Gas - High Load	(ACTUAL)			(PROJECTED)																
	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030		
Delivered Fuel Price (cents/MBtu)*	[REDACTED]																			
a. Nuclear																				
b. Coal																				
c. Heavy Fuel Oil																				
d. Light Fuel Oil																				
e. Natural Gas																				
f. Renewable**																				
Primary Fuel Expenses (cents/kWh)*	[REDACTED]																			
a. Nuclear																				
b. Coal																				
c. Heavy Fuel Oil																				
d. Light Fuel Oil																				
e. Natural Gas																				
f. Renewable**																				
g. Purchases Energy Charges Only																				
h. Purchases Energy and Capacity Charges																				

* To reflect total dispatch costs, including any variable O and environmental or compliance costs.
 ** Per definition of §56-576 of the Code of Virginia.

CONFIDENTIAL INFORMATION HIGHLIGHTED

2016 IRP

Kentucky Utilities Company and Louisville Gas and Electric Company
 FUEL DATA

Sch18

CONFIDENTIAL INFORMATION REDACTED

Scenario: Low Gas - Low Load

(ACTUAL)

(PROJECTED)

2013 2014 2015 2016 2017 2018 2019 2020 2021 2022 2023 2024 2025 2026 2027 2028 2029 2030

Delivered Fuel Price (cents/MBtu)*

a. Nuclear	[REDACTED]																
b. Coal	[REDACTED]																
c. Heavy Fuel Oil	[REDACTED]																
d. Light Fuel Oil	[REDACTED]																
e. Natural Gas	[REDACTED]																
f. Renewable**	[REDACTED]																

Primary Fuel Expenses (cents/kWh)*

a. Nuclear	[REDACTED]																
b. Coal	[REDACTED]																
c. Heavy Fuel Oil	[REDACTED]																
d. Light Fuel Oil	[REDACTED]																
e. Natural Gas	[REDACTED]																
f. Renewable**	[REDACTED]																
g. Purchases Energy Charges Only	[REDACTED]																
h. Purchases Energy and Capacity Charges	[REDACTED]																

* To reflect total dispatch costs, including any variable O and environmental or compliance costs.
 ** Per definition of §§6-576 of the Code of Virginia.

CONFIDENTIAL INFORMATION HIGHLIGHTED

76007697