Richmond County Public Schools

Virginia HB 2278 (2025 Session)



Purpose: To ensure school divisions assess and report on accessibility barriers in school buildings and grounds, access to programming, and the progress on eliminating these challenges.

Mackey Thompson Learning Center (PreSchool)

		<u> </u>
Area	Barriers Identified	Proposed Resolutions/Actions Steps
Physical Accessibility	 Restroom stall lacks the required 60-inch turning radius. Inadequate/missing braille/tactile signs identifying rooms. 	 The capital improvement plan will need to include upgrading the stall. Procure vendor and replace all signs throughout the school by the 26-27 school year.
Programming & Supports	 None identified at this time 	Current Inclusive Action Plan with increased general education access for ALL students

Richmond County Elementary/Middle School (K-7)

Area	Barriers Identified	Proposed Resolutions/Actions Steps
Physical Accessibility	 Inadequate/missing braille/tactile signs identifying rooms in the older wing. 	Procure vendor and replace all signs throughout the school by the 26-27 school year.
Programming & Supports	None identified at this time	Current Inclusive Action Plan with increased general education access for ALL students

Rappahannock High School (8-12)

Area	Barriers Identified	Proposed Resolutions/Actions Steps
Physical Accessibility	 Inadequate/missing braille/tactile signs identifying rooms in the older wing. Gravel surface needs to have a sidewalk leading to the football field 	 Procure vendor and replace all signs throughout the school by the 26-27 school year. Construct a sidewalk to the football field and to the pavilion during the 2026-27 school year.
Programming & Supports	None at this time	Current Inclusive Action Plan with increased general education access for ALL students